

 Eagle Mountain – Woodfibre Gas Pipeline Project Waste Discharge Permit PE-110163 Report	Reporting Week	June 22 to June 28, 2026
	Report #	118
	Page	1 of 6

Eagle Mountain – Woodfibre Gas Pipeline Project

BCER Waste Discharge Permit Weekly Report

 Eagle Mountain – Woodfibre Gas Pipeline Project Waste Discharge Permit PE-110163 Report	Reporting Week	June 22 to June 28, 2026
	Report #	118
	Page	2 of 6

Contents

Preamble.....

3

Introduction

3

Sampling Methodology.....

3

Summary-BC Rail Site

4

Site Activities

4

Discharge from Water Treatment Plant.....

5

Receiving Environment Monitoring-Squamish River

5

Summary-Woodfibre Site

5

Site Activities

5

Exceedances.....

5

Discharge from Water Treatment Plant.....

6

Receiving Environment Monitoring-East Creek.....

6

Appendix A: BC Rail Point of Discharge from Water Treatment System Documentation

Appendix B: BC Rail Receiving Environment Documentation

Appendix C: Woodfibre Point of Discharge from Water Treatment System Documentation

Appendix D: Woodfibre Receiving Environment Documentation

Appendix E: Lab Documentation

 Eagle Mountain – Woodfibre Gas Pipeline Project Waste Discharge Permit PE-110163 Report	Reporting Week	June 22 to June 28, 2026
	Report #	118
	Page	3 of 6

Preamble

This weekly report for the British Columbia Energy Regulator (BCER) Waste Discharge Permit (BCER number PE-110163) for the FortisBC Eagle Mountain – Woodfibre Gas Pipeline (EGP) Project includes the results of water quality monitoring and sampling of the receiving environments (upstream and downstream) and points of discharge during the reporting period.

FortisBC has retained Hatfield Consultants as the Qualified Professional to implement and oversee the monitoring and sampling programs. The data represented below, including laboratory reported exceedances, represent conditions measured from final discharge points and the associated receiving environments, as required under the Waste Discharge Permit.

Introduction

The results provided in this document have been submitted to BCER by FortisBC as per the requirements listed in Section 4.2 of the Waste Discharge Permit PE-110163:

The Permittee shall summarize the results of the discharge and receiving environment compliance sampling and monitoring program in a report that shall be submitted weekly over the term of this permit. The sampling and monitoring results shall be suitably tabulated and include comparison to the respective British Columbia Approved and Working Water Quality Guidelines for Freshwater & Marine Aquatic Life, as published by the Ministry of Environment & Climate Change Strategy. Any exceedance of regulatory guidelines shall be clearly highlighted, and any missed sampling events/missing data shall be identified with an explanation provided. Reporting frequency may be reduced upon a history of compliance and by written confirmation from the BCER. These reports shall be submitted to Waste.Management@bc-er.ca. A copy of the reports shall be provided to each First Nation consulted with regarding the subject permit, and also made publicly available on the FortisBC Eagle Mountain-Woodfibre Gas Pipeline Project | Talking Energy webpage.

Sampling Methodology

The monitoring and sampling has been carried out in accordance with the procedures described in the most recent edition of the “British Columbia Field Sampling Manual” using field equipment and laboratory samples to meet daily and real-time requirements for the Waste Discharge Permit.

In the receiving environments, real-time and daily readings were monitored at the same time with one piece of equipment, allowing real-time daily readings. Visible sheen was monitored through visual inspections during times of discharge or sampling.

At the point of discharges, parameters are monitored using field equipment and water quality sondes, as well as discrete weekly water quality sampling events for laboratory analyses. Table 1 and Table 2 below describe this monitoring.



**Eagle Mountain – Woodfibre Gas Pipeline Project
Waste Discharge Permit PE-110163 Report**

Reporting Week

June 22 to
June 28, 2026

Report #

118

Page

4 of 6

Table 1. Monitor Details for the Point of Discharge from the Water Treatment System-BC Rail and Woodfibre

Permit Frequency	Parameters	Details
During discharges	Visible Sheen	In field inspection
Daily (or per batch)	DO	Monitoring using YSI ProDSS
	ORP	Monitoring using YSI ProDSS
	Salinity	Monitoring using YSI ProDSS
Real-time (or per batch)	pH	Monitoring using GF Dryloc pH Series NPT
	Temperature	Monitoring using LevelPro PT100 Temperature and Signet 2350 Temp sensor
	NTU	Monitoring using Observer NEP9504GPI
	Electrical Conductivity	Monitoring using ProCon C450
Weekly (or per batch) Lab Samples	List prescribed in permit	Lab samples*

* Indicates that weekly lab samples are currently only collected at the Woodfibre site, as approved by BCER, given that there is currently no discharge from the BC Rail site.

Table 2. Monitor Details for the Receiving Environment (upstream and downstream)-BC Rail and Woodfibre

Permit Frequency	Parameters	Details
During discharges	Visible Sheen	In field inspection
Daily	DO	Monitoring using Sonde- AquaTROLL 600 datalogger
	ORP	Monitoring using Sonde- AquaTROLL 600 datalogger
	Salinity	Monitoring using Sonde- AquaTROLL 600 datalogger
Real-time	pH	Monitoring using Sonde- AquaTROLL 600 datalogger
	Temperature	Monitoring using Sonde- AquaTROLL 600 datalogger
	NTU	Monitoring using Sonde- AquaTROLL 600 datalogger
	Electrical Conductivity	Monitoring using Sonde- AquaTROLL 600 datalogger
Weekly Lab Samples	List prescribed in permit	Lab samples*

* Indicates that weekly lab samples are currently only collected at the Woodfibre site, as approved by BCER, given that there is currently no discharge from the BC Rail site.

Summary-BC Rail Site

Site Activities

- The soft ground tunnel has been completed and FortisBC is in the process of demobilizing equipment and preparations for pipe stringing.



Eagle Mountain – Woodfibre Gas Pipeline Project Waste Discharge Permit PE-110163 Report

Reporting Week

June 22 to
June 28, 2026

Report #

118

Page

5 of 6

Discharge from Water Treatment Plant

- There was no discharges this week from the BC Rail Site.

Receiving Environment Monitoring-Squamish River

Tables 3 and 4 below provide information on water quality monitoring. Lab sampling has been put on hold with permission from BCER as there are no discharges. Appendix B includes a full set of results with real-time data. The receiving environment is being monitored as outlined in the permit and confirmed by BCER, with additional oversight by the QP.

Table 3. Upstream Monitoring Information

Location	Date of Lab Sample	Real-time Monitored	Results
Squamish River Upstream	N/A	Yes *	Full set of real time monitoring results are provided in Appendix B. **

Table 4. Downstream Monitoring Information

Location	Date of Lab Sample	Real-time Monitored	Results
Squamish River Downstream	N/A	Yes *	Full set of real time monitoring results are provided in Appendix B. **

* Sondes set up to log temperature, specific conductivity, salinity (in PSU), pH, ORP, DO (mg/L), and turbidity (NTU) at 15-minute intervals.

** Data gaps in available in-situ continuous monitoring data, included:

- SQU US
 - Temperature, specific conductivity, ORP, pH, dissolved oxygen, turbidity, and salinity data was missing for the following dates and time periods: 6/22/2026: 12:15
- SQU DS
 - Temperature, specific conductivity, ORP, pH, dissolved oxygen, turbidity, and salinity data was missing for the following dates and time periods:
 - 2026/06/22 to 2026/06/28: Sensor set to 60-minute recording interval rather than 15-minute recording interval, therefore creating three data gaps an hour.

Summary-Woodfibre Site

Site Activities

- Weekly upstream, downstream, and end of pipe water quality sampling performed by the QP.
- On-going tunnelling at WLNG and grouting works to mitigate water ingress.

Exceedances

No reportable exceedances were reported during the June 22 to June 28, 2026, reporting period.



**Eagle Mountain – Woodfibre Gas Pipeline Project
Waste Discharge Permit PE-110163 Report**

Reporting Week

June 22 to
June 28, 2026

Report #

118

Page

6 of 6

Discharge from Water Treatment Plant

Appendix C includes volume information and real-time/field samples from the discharge.

Receiving Environment Monitoring-East Creek

Tables 5 and 6 below provide information on water quality monitoring. Appendix D includes a full set of results with real-time data. The receiving environment is being monitored as outlined in the permit with additional oversight by the QP.

Table 5. Upstream Monitoring Information

Location	Date of Lab Sample	Real-time Monitored	Results
East Creek Upstream	2026-06-23	Yes *	Full set of results are provided in Appendix D.**

Table 6. Downstream Monitoring Information

Location	Date of Lab Sample	Real-time Monitored	Results
East Creek Downstream	2026-06-23	Yes *	Full set of results are provided in Appendix D.**

* Sondes set up to log temperature, specific conductivity, salinity (in PSU), pH, ORP, DO (mg/L), and turbidity (NTU) at 15-minute intervals.

**No data gaps were observed in available in-situ continuous monitoring data at either EAS US or EAS DS.

 Eagle Mountain – Woodfibre Gas Pipeline Project Waste Discharge Permit PE-110163 Report	Reporting Week	June 22 to June 28, 2026
	Report #	118
	Appendix A	A-1

Appendix A: BCR Site Point of Discharge from Water Treatment Plant Documentation

 Eagle Mountain – Woodfibre Gas Pipeline Project Waste Discharge Permit PE-110163 Report	Reporting Week	June 22 to June 28, 2026
	Report #	118
	Appendix A	A-2

BCR Site Batch Sample Analysis

No Discharges

 Eagle Mountain – Woodfibre Gas Pipeline Project Waste Discharge Permit PE-110163 Report	Reporting Week	June 22 to June 28, 2026
	Report #	118
	Appendix A	A-3

BCR Site WTP Discharge Field Notes and Logs

No Discharge

 Eagle Mountain – Woodfibre Gas Pipeline Project Waste Discharge Permit PE-110163 Report	Reporting Week	June 22 to June 28, 2026
	Report #	118
	Appendix B	B-1

Appendix B: BCR Site Receiving Environment Documentation

 Eagle Mountain – Woodfibre Gas Pipeline Project Waste Discharge Permit PE-110163 Report	Reporting Week	June 22 to June 28, 2026
	Report #	118
	Appendix B	B-2

BCR Site Receiving Environment Sample Analysis
No Lab Sample

 Eagle Mountain – Woodfibre Gas Pipeline Project Waste Discharge Permit PE-110163 Report	Reporting Week	June 22 to June 28, 2026
	Report #	118
	Appendix B	B-3

BCR Site Receiving Environment
Field Notes and Logs

Squamish River								
Station	Date/Time	Temperature (C)	Specific Conductivity (µS/cm)	ORP (V)	pH (pH units)	Dissolved Oxygen (mg/L)	Turbidity (NTU)	Salinity (PSU)
SQU-DS	2026-06-22 00:00:00	11.78	21.14	0.53	7.48	9.94	14.39	0.01
SQU-DS	2026-06-22 00:15:00							
SQU-DS	2026-06-22 00:30:00							
SQU-DS	2026-06-22 00:45:00							
SQU-DS	2026-06-22 01:00:00	11.52	21.45	0.53	7.51	9.94	14.36	0.01
SQU-DS	2026-06-22 01:15:00							
SQU-DS	2026-06-22 01:30:00							
SQU-DS	2026-06-22 01:45:00							
SQU-DS	2026-06-22 02:00:00	11.27	19.82	0.54	7.47	10.00	14.54	0.01
SQU-DS	2026-06-22 02:15:00							
SQU-DS	2026-06-22 02:30:00							
SQU-DS	2026-06-22 02:45:00							
SQU-DS	2026-06-22 03:00:00	11.03	18.91	0.54	7.36	10.03	13.66	0.01
SQU-DS	2026-06-22 03:15:00							
SQU-DS	2026-06-22 03:30:00							
SQU-DS	2026-06-22 03:45:00							
SQU-DS	2026-06-22 04:00:00	10.80	19.16	0.54	7.31	10.08	15.35	0.01
SQU-DS	2026-06-22 04:15:00							
SQU-DS	2026-06-22 04:30:00							
SQU-DS	2026-06-22 04:45:00							
SQU-DS	2026-06-22 05:00:00	10.63	19.54	0.53	7.35	10.12	15.15	0.01
SQU-DS	2026-06-22 05:15:00							
SQU-DS	2026-06-22 05:30:00							
SQU-DS	2026-06-22 05:45:00							
SQU-DS	2026-06-22 06:00:00	10.46	21.73	0.53	7.35	10.17	8.40	0.01
SQU-DS	2026-06-22 06:15:00							
SQU-DS	2026-06-22 06:30:00							
SQU-DS	2026-06-22 06:45:00							
SQU-DS	2026-06-22 07:00:00	10.34	21.49	0.54	7.35	10.22	24.76	0.01
SQU-DS	2026-06-22 07:15:00							
SQU-DS	2026-06-22 07:30:00							
SQU-DS	2026-06-22 07:45:00							
SQU-DS	2026-06-22 08:00:00	10.34	21.44	0.53	7.36	10.28	48.35	0.01
SQU-DS	2026-06-22 08:15:00							
SQU-DS	2026-06-22 08:30:00							
SQU-DS	2026-06-22 08:45:00							
SQU-DS	2026-06-22 09:00:00	10.43	21.78	0.53	7.37	10.30	22.09	0.01
SQU-DS	2026-06-22 09:15:00							
SQU-DS	2026-06-22 09:30:00							
SQU-DS	2026-06-22 09:45:00							
SQU-DS	2026-06-22 10:00:00	10.60	22.21	0.53	7.35	10.33	13.07	0.01
SQU-DS	2026-06-22 10:15:00							
SQU-DS	2026-06-22 10:30:00							
SQU-DS	2026-06-22 10:45:00							
SQU-DS	2026-06-22 11:00:00	10.79	22.17	0.53	7.36	10.34	14.72	0.01
SQU-DS	2026-06-22 11:15:00							
SQU-DS	2026-06-22 11:30:00							
SQU-DS	2026-06-22 11:45:00							
SQU-DS	2026-06-22 12:00:00	11.04	22.06	0.53	7.39	10.35	27.78	0.01
SQU-DS	2026-06-22 12:15:00							
SQU-DS	2026-06-22 12:30:00							
SQU-DS	2026-06-22 12:45:00							
SQU-DS	2026-06-22 13:00:00	11.28	22.34	0.53	7.39	10.35	6.89	0.01
SQU-DS	2026-06-22 13:15:00							
SQU-DS	2026-06-22 13:30:00							

Squamish River								
Station	Date/Time	Temperature (C)	Specific Conductivity (µS/cm)	ORP (V)	pH (pH units)	Dissolved Oxygen (mg/L)	Turbidity (NTU)	Salinity (PSU)
SQU-DS	2026-06-22 13:45:00							
SQU-DS	2026-06-22 14:00:00	11.55	22.21	0.53	7.40	10.31	5.48	0.01
SQU-DS	2026-06-22 14:15:00							
SQU-DS	2026-06-22 14:30:00							
SQU-DS	2026-06-22 14:45:00							
SQU-DS	2026-06-22 15:00:00	11.83	21.85	0.52	7.43	10.28	4.81	0.01
SQU-DS	2026-06-22 15:15:00							
SQU-DS	2026-06-22 15:30:00							
SQU-DS	2026-06-22 15:45:00							
SQU-DS	2026-06-22 16:00:00	12.06	22.19	0.53	7.38	10.25	5.74	0.01
SQU-DS	2026-06-22 16:15:00							
SQU-DS	2026-06-22 16:30:00							
SQU-DS	2026-06-22 16:45:00							
SQU-DS	2026-06-22 17:00:00	12.23	22.43	0.53	7.34	10.19	6.43	0.01
SQU-DS	2026-06-22 17:15:00							
SQU-DS	2026-06-22 17:30:00							
SQU-DS	2026-06-22 17:45:00							
SQU-DS	2026-06-22 18:00:00	12.45	22.70	0.53	7.41	10.13	6.14	0.01
SQU-DS	2026-06-22 18:15:00							
SQU-DS	2026-06-22 18:30:00							
SQU-DS	2026-06-22 18:45:00							
SQU-DS	2026-06-22 19:00:00	12.53	23.33	0.53	7.37	10.04	7.27	0.01
SQU-DS	2026-06-22 19:15:00							
SQU-DS	2026-06-22 19:30:00							
SQU-DS	2026-06-22 19:45:00							
SQU-DS	2026-06-22 20:00:00	12.51	23.42	0.53	7.37	9.97	7.69	0.01
SQU-DS	2026-06-22 20:15:00							
SQU-DS	2026-06-22 20:30:00							
SQU-DS	2026-06-22 20:45:00							
SQU-DS	2026-06-22 21:00:00	12.44	23.84	0.53	7.39	9.91	10.97	0.01
SQU-DS	2026-06-22 21:15:00							
SQU-DS	2026-06-22 21:30:00							
SQU-DS	2026-06-22 21:45:00							
SQU-DS	2026-06-22 22:00:00	12.35	23.51	0.53	7.38	9.88	6.08	0.01
SQU-DS	2026-06-22 22:15:00							
SQU-DS	2026-06-22 22:30:00							
SQU-DS	2026-06-22 22:45:00							
SQU-DS	2026-06-22 23:00:00	12.22	23.23	0.53	7.41	9.87	3.17	0.01
SQU-DS	2026-06-22 23:15:00							
SQU-DS	2026-06-22 23:30:00							
SQU-DS	2026-06-22 23:45:00							
SQU-DS	2026-06-23 00:00:00	12.01	22.07	0.53	7.48	9.89	2.28	0.01
SQU-DS	2026-06-23 00:15:00							
SQU-DS	2026-06-23 00:30:00							
SQU-DS	2026-06-23 00:45:00							
SQU-DS	2026-06-23 01:00:00	11.75	21.24	0.54	7.48	9.93	1.79	0.01
SQU-DS	2026-06-23 01:15:00							
SQU-DS	2026-06-23 01:30:00							
SQU-DS	2026-06-23 01:45:00							
SQU-DS	2026-06-23 02:00:00	11.50	19.89	0.55	7.44	9.96	1.66	0.01
SQU-DS	2026-06-23 02:15:00							
SQU-DS	2026-06-23 02:30:00							
SQU-DS	2026-06-23 02:45:00							
SQU-DS	2026-06-23 03:00:00	11.26	18.71	0.54	7.42	10.00	1.31	0.01
SQU-DS	2026-06-23 03:15:00							

Squamish River								
Station	Date/Time	Temperature (C)	Specific Conductivity (µS/cm)	ORP (V)	pH (pH units)	Dissolved Oxygen (mg/L)	Turbidity (NTU)	Salinity (PSU)
SQU-DS	2026-06-23 03:30:00							
SQU-DS	2026-06-23 03:45:00							
SQU-DS	2026-06-23 04:00:00	11.04	18.17	0.54	7.37	10.04	0.85	0.01
SQU-DS	2026-06-23 04:15:00							
SQU-DS	2026-06-23 04:30:00							
SQU-DS	2026-06-23 04:45:00							
SQU-DS	2026-06-23 05:00:00	10.87	18.03	0.54	7.33	10.09	2.73	0.01
SQU-DS	2026-06-23 05:15:00							
SQU-DS	2026-06-23 05:30:00							
SQU-DS	2026-06-23 05:45:00							
SQU-DS	2026-06-23 06:00:00	10.70	17.91	0.54	7.36	10.14	2.34	0.01
SQU-DS	2026-06-23 06:15:00							
SQU-DS	2026-06-23 06:30:00							
SQU-DS	2026-06-23 06:45:00							
SQU-DS	2026-06-23 07:00:00	10.63	19.54	0.54	7.34	10.19	2.08	0.01
SQU-DS	2026-06-23 07:15:00							
SQU-DS	2026-06-23 07:30:00							
SQU-DS	2026-06-23 07:45:00							
SQU-DS	2026-06-23 08:00:00	10.63	19.54	0.54	7.32	10.23	2.46	0.01
SQU-DS	2026-06-23 08:15:00							
SQU-DS	2026-06-23 08:30:00							
SQU-DS	2026-06-23 08:45:00							
SQU-DS	2026-06-23 09:00:00	10.71	20.15	0.54	7.33	10.26	2.04	0.01
SQU-DS	2026-06-23 09:15:00							
SQU-DS	2026-06-23 09:30:00							
SQU-DS	2026-06-23 09:45:00							
SQU-DS	2026-06-23 10:00:00	10.83	19.80	0.54	7.33	10.28	1.39	0.01
SQU-DS	2026-06-23 10:15:00							
SQU-DS	2026-06-23 10:30:00							
SQU-DS	2026-06-23 10:45:00							
SQU-DS	2026-06-23 11:00:00	11.01	19.49	0.53	7.37	10.29	1.08	0.01
SQU-DS	2026-06-23 11:15:00							
SQU-DS	2026-06-23 11:30:00							
SQU-DS	2026-06-23 11:45:00							
SQU-DS	2026-06-23 12:00:00	11.21	20.02	0.53	7.37	10.31	0.85	0.01
SQU-DS	2026-06-23 12:15:00							
SQU-DS	2026-06-23 12:30:00							
SQU-DS	2026-06-23 12:45:00							
SQU-DS	2026-06-23 13:00:00	11.49	20.61	0.53	7.39	10.31	0.69	0.01
SQU-DS	2026-06-23 13:15:00							
SQU-DS	2026-06-23 13:30:00							
SQU-DS	2026-06-23 13:45:00							
SQU-DS	2026-06-23 14:00:00	11.80	19.78	0.52	7.46	10.29	0.69	0.01
SQU-DS	2026-06-23 14:15:00							
SQU-DS	2026-06-23 14:30:00							
SQU-DS	2026-06-23 14:45:00							
SQU-DS	2026-06-23 15:00:00	12.09	19.79	0.53	7.44	10.24	0.54	0.01
SQU-DS	2026-06-23 15:15:00							
SQU-DS	2026-06-23 15:30:00							
SQU-DS	2026-06-23 15:45:00							
SQU-DS	2026-06-23 16:00:00	12.25	19.84	0.53	7.43	10.20	0.59	0.01
SQU-DS	2026-06-23 16:15:00							
SQU-DS	2026-06-23 16:30:00							
SQU-DS	2026-06-23 16:45:00							
SQU-DS	2026-06-23 17:00:00	12.47	20.17	0.53	7.45	10.15	0.38	0.01

Squamish River								
Station	Date/Time	Temperature (C)	Specific Conductivity (µS/cm)	ORP (V)	pH (pH units)	Dissolved Oxygen (mg/L)	Turbidity (NTU)	Salinity (PSU)
SQU-DS	2026-06-23 17:15:00							
SQU-DS	2026-06-23 17:30:00							
SQU-DS	2026-06-23 17:45:00							
SQU-DS	2026-06-23 18:00:00	12.62	20.66	0.53	7.39	10.05	0.32	0.01
SQU-DS	2026-06-23 18:15:00							
SQU-DS	2026-06-23 18:30:00							
SQU-DS	2026-06-23 18:45:00							
SQU-DS	2026-06-23 19:00:00	12.73	21.04	0.53	7.40	10.00	0.29	0.01
SQU-DS	2026-06-23 19:15:00							
SQU-DS	2026-06-23 19:30:00							
SQU-DS	2026-06-23 19:45:00							
SQU-DS	2026-06-23 20:00:00	12.66	22.00	0.53	7.36	9.93	0.25	0.01
SQU-DS	2026-06-23 20:15:00							
SQU-DS	2026-06-23 20:30:00							
SQU-DS	2026-06-23 20:45:00							
SQU-DS	2026-06-23 21:00:00	12.52	21.91	0.53	7.39	9.88	0.24	0.01
SQU-DS	2026-06-23 21:15:00							
SQU-DS	2026-06-23 21:30:00							
SQU-DS	2026-06-23 21:45:00							
SQU-DS	2026-06-23 22:00:00	12.37	21.99	0.53	7.42	9.86	0.12	0.01
SQU-DS	2026-06-23 22:15:00							
SQU-DS	2026-06-23 22:30:00							
SQU-DS	2026-06-23 22:45:00							
SQU-DS	2026-06-23 23:00:00	12.19	20.53	0.54	7.35	9.87	0.13	0.01
SQU-DS	2026-06-23 23:15:00							
SQU-DS	2026-06-23 23:30:00							
SQU-DS	2026-06-23 23:45:00							
SQU-DS	2026-06-24 00:00:00	11.97	18.78	0.54	7.45	9.89	0.13	0.01
SQU-DS	2026-06-24 00:15:00							
SQU-DS	2026-06-24 00:30:00							
SQU-DS	2026-06-24 00:45:00							
SQU-DS	2026-06-24 01:00:00	11.73	18.25	0.54	7.46	9.92	0.00	0.01
SQU-DS	2026-06-24 01:15:00							
SQU-DS	2026-06-24 01:30:00							
SQU-DS	2026-06-24 01:45:00							
SQU-DS	2026-06-24 02:00:00	11.51	17.58	0.54	7.45	9.96	0.00	0.01
SQU-DS	2026-06-24 02:15:00							
SQU-DS	2026-06-24 02:30:00							
SQU-DS	2026-06-24 02:45:00							
SQU-DS	2026-06-24 03:00:00	11.31	16.81	0.55	7.43	9.99	0.00	0.01
SQU-DS	2026-06-24 03:15:00							
SQU-DS	2026-06-24 03:30:00							
SQU-DS	2026-06-24 03:45:00							
SQU-DS	2026-06-24 04:00:00	11.10	16.26	0.55	7.37	10.04	0.00	0.01
SQU-DS	2026-06-24 04:15:00							
SQU-DS	2026-06-24 04:30:00							
SQU-DS	2026-06-24 04:45:00							
SQU-DS	2026-06-24 05:00:00	10.93	16.51	0.55	7.41	10.09	0.00	0.01
SQU-DS	2026-06-24 05:15:00							
SQU-DS	2026-06-24 05:30:00							
SQU-DS	2026-06-24 05:45:00							
SQU-DS	2026-06-24 06:00:00	10.82	15.89	0.55	7.31	10.11	0.00	0.01
SQU-DS	2026-06-24 06:15:00							
SQU-DS	2026-06-24 06:30:00							
SQU-DS	2026-06-24 06:45:00							

Squamish River								
Station	Date/Time	Temperature (C)	Specific Conductivity (µS/cm)	ORP (V)	pH (pH units)	Dissolved Oxygen (mg/L)	Turbidity (NTU)	Salinity (PSU)
SQU-DS	2026-06-24 07:00:00	10.76	15.50	0.54	7.37	10.14	0.00	0.01
SQU-DS	2026-06-24 07:15:00							
SQU-DS	2026-06-24 07:30:00							
SQU-DS	2026-06-24 07:45:00							
SQU-DS	2026-06-24 08:00:00	10.77	16.10	0.54	7.38	10.17	0.00	0.01
SQU-DS	2026-06-24 08:15:00							
SQU-DS	2026-06-24 08:30:00							
SQU-DS	2026-06-24 08:45:00							
SQU-DS	2026-06-24 09:00:00	10.83	15.94	0.54	7.41	10.20	0.00	0.01
SQU-DS	2026-06-24 09:15:00							
SQU-DS	2026-06-24 09:30:00							
SQU-DS	2026-06-24 09:45:00							
SQU-DS	2026-06-24 10:00:00	10.86	15.51	0.54	7.38	10.24	0.00	0.01
SQU-DS	2026-06-24 10:15:00							
SQU-DS	2026-06-24 10:30:00							
SQU-DS	2026-06-24 10:45:00							
SQU-DS	2026-06-24 11:00:00	10.93	15.65	0.54	7.42	10.27	0.00	0.01
SQU-DS	2026-06-24 11:15:00							
SQU-DS	2026-06-24 11:30:00							
SQU-DS	2026-06-24 11:45:00							
SQU-DS	2026-06-24 12:00:00	11.17	15.70	0.54	7.37	10.29	0.00	0.01
SQU-DS	2026-06-24 12:15:00							
SQU-DS	2026-06-24 12:30:00							
SQU-DS	2026-06-24 12:45:00							
SQU-DS	2026-06-24 13:00:00	11.36	16.07	0.54	7.40	10.28	0.00	0.01
SQU-DS	2026-06-24 13:15:00							
SQU-DS	2026-06-24 13:30:00							
SQU-DS	2026-06-24 13:45:00							
SQU-DS	2026-06-24 14:00:00	11.52	15.62	0.53	7.44	10.28	0.00	0.01
SQU-DS	2026-06-24 14:15:00							
SQU-DS	2026-06-24 14:30:00							
SQU-DS	2026-06-24 14:45:00							
SQU-DS	2026-06-24 15:00:00	11.81	15.70	0.53	7.45	10.27	0.00	0.01
SQU-DS	2026-06-24 15:15:00							
SQU-DS	2026-06-24 15:30:00							
SQU-DS	2026-06-24 15:45:00							
SQU-DS	2026-06-24 16:00:00	12.06	15.69	0.54	7.43	10.23	0.00	0.01
SQU-DS	2026-06-24 16:15:00							
SQU-DS	2026-06-24 16:30:00							
SQU-DS	2026-06-24 16:45:00							
SQU-DS	2026-06-24 17:00:00	12.32	15.78	0.54	7.44	10.15	0.00	0.01
SQU-DS	2026-06-24 17:15:00							
SQU-DS	2026-06-24 17:30:00							
SQU-DS	2026-06-24 17:45:00							
SQU-DS	2026-06-24 18:00:00	12.50	16.09	0.54	7.41	10.08	0.00	0.01
SQU-DS	2026-06-24 18:15:00							
SQU-DS	2026-06-24 18:30:00							
SQU-DS	2026-06-24 18:45:00							
SQU-DS	2026-06-24 19:00:00	12.59	16.23	0.54	7.42	10.00	0.00	0.01
SQU-DS	2026-06-24 19:15:00							
SQU-DS	2026-06-24 19:30:00							
SQU-DS	2026-06-24 19:45:00							
SQU-DS	2026-06-24 20:00:00	12.53	17.29	0.54	7.34	9.93	0.00	0.01
SQU-DS	2026-06-24 20:15:00							
SQU-DS	2026-06-24 20:30:00							

Squamish River								
Station	Date/Time	Temperature (C)	Specific Conductivity (µS/cm)	ORP (V)	pH (pH units)	Dissolved Oxygen (mg/L)	Turbidity (NTU)	Salinity (PSU)
SQU-DS	2026-06-24 20:45:00							
SQU-DS	2026-06-24 21:00:00	12.38	16.98	0.54	7.40	9.89	0.00	0.01
SQU-DS	2026-06-24 21:15:00							
SQU-DS	2026-06-24 21:30:00							
SQU-DS	2026-06-24 21:45:00							
SQU-DS	2026-06-24 22:00:00	12.29	17.29	0.54	7.39	9.85	0.00	0.01
SQU-DS	2026-06-24 22:15:00							
SQU-DS	2026-06-24 22:30:00							
SQU-DS	2026-06-24 22:45:00							
SQU-DS	2026-06-24 23:00:00	12.14	16.95	0.54	7.39	9.85	0.00	0.01
SQU-DS	2026-06-24 23:15:00							
SQU-DS	2026-06-24 23:30:00							
SQU-DS	2026-06-24 23:45:00							
SQU-DS	2026-06-25 00:00:00	11.95	16.73	0.54	7.46	9.86	0.00	0.01
SQU-DS	2026-06-25 00:15:00							
SQU-DS	2026-06-25 00:30:00							
SQU-DS	2026-06-25 00:45:00							
SQU-DS	2026-06-25 01:00:00	11.72	16.29	0.55	7.44	9.89	0.00	0.01
SQU-DS	2026-06-25 01:15:00							
SQU-DS	2026-06-25 01:30:00							
SQU-DS	2026-06-25 01:45:00							
SQU-DS	2026-06-25 02:00:00	11.45	16.26	0.55	7.45	9.93	0.00	0.01
SQU-DS	2026-06-25 02:15:00							
SQU-DS	2026-06-25 02:30:00							
SQU-DS	2026-06-25 02:45:00							
SQU-DS	2026-06-25 03:00:00	11.23	16.17	0.55	7.43	9.96	0.00	0.01
SQU-DS	2026-06-25 03:15:00							
SQU-DS	2026-06-25 03:30:00							
SQU-DS	2026-06-25 03:45:00							
SQU-DS	2026-06-25 04:00:00	11.08	15.34	0.56	7.40	10.00	0.00	0.01
SQU-DS	2026-06-25 04:15:00							
SQU-DS	2026-06-25 04:30:00							
SQU-DS	2026-06-25 04:45:00							
SQU-DS	2026-06-25 05:00:00	10.95	15.48	0.56	7.37	10.03	0.00	0.01
SQU-DS	2026-06-25 05:15:00							
SQU-DS	2026-06-25 05:30:00							
SQU-DS	2026-06-25 05:45:00							
SQU-DS	2026-06-25 06:00:00	10.87	15.06	0.56	7.43	10.05	0.00	0.01
SQU-DS	2026-06-25 06:15:00							
SQU-DS	2026-06-25 06:30:00							
SQU-DS	2026-06-25 06:45:00							
SQU-DS	2026-06-25 07:00:00	10.81	15.63	0.56	7.38	10.08	0.00	0.01
SQU-DS	2026-06-25 07:15:00							
SQU-DS	2026-06-25 07:30:00							
SQU-DS	2026-06-25 07:45:00							
SQU-DS	2026-06-25 08:00:00	10.80	15.63	0.56	7.43	10.11	0.00	0.01
SQU-DS	2026-06-25 08:15:00							
SQU-DS	2026-06-25 08:30:00							
SQU-DS	2026-06-25 08:45:00							
SQU-DS	2026-06-25 09:00:00	10.82	15.55	0.56	7.40	10.14	0.00	0.01
SQU-DS	2026-06-25 09:15:00							
SQU-DS	2026-06-25 09:30:00							
SQU-DS	2026-06-25 09:45:00							
SQU-DS	2026-06-25 10:00:00	10.79	16.02	0.56	7.37	10.19	0.00	0.01
SQU-DS	2026-06-25 10:15:00							

Squamish River								
Station	Date/Time	Temperature (C)	Specific Conductivity (µS/cm)	ORP (V)	pH (pH units)	Dissolved Oxygen (mg/L)	Turbidity (NTU)	Salinity (PSU)
SQU-DS	2026-06-25 10:30:00							
SQU-DS	2026-06-25 10:45:00							
SQU-DS	2026-06-25 11:00:00	10.78	15.16	0.56	7.46	10.24	0.00	0.01
SQU-DS	2026-06-25 11:15:00							
SQU-DS	2026-06-25 11:30:00							
SQU-DS	2026-06-25 11:45:00							
SQU-DS	2026-06-25 12:00:00	10.83	15.13	0.55	7.38	10.27	0.00	0.01
SQU-DS	2026-06-25 12:15:00							
SQU-DS	2026-06-25 12:30:00							
SQU-DS	2026-06-25 12:45:00							
SQU-DS	2026-06-25 13:00:00	10.79	15.92	0.55	7.40	10.27	0.00	0.01
SQU-DS	2026-06-25 13:15:00							
SQU-DS	2026-06-25 13:30:00							
SQU-DS	2026-06-25 13:45:00							
SQU-DS	2026-06-25 14:00:00	10.79	15.21	0.55	7.43	10.28	0.00	0.01
SQU-DS	2026-06-25 14:15:00							
SQU-DS	2026-06-25 14:30:00							
SQU-DS	2026-06-25 14:45:00							
SQU-DS	2026-06-25 15:00:00	10.84	21.62	0.49	7.46	10.27	46.40	0.01
SQU-DS	2026-06-25 15:15:00							
SQU-DS	2026-06-25 15:30:00							
SQU-DS	2026-06-25 15:45:00							
SQU-DS	2026-06-25 16:00:00	10.88	20.49	0.50	7.42	10.28	42.56	0.01
SQU-DS	2026-06-25 16:15:00							
SQU-DS	2026-06-25 16:30:00							
SQU-DS	2026-06-25 16:45:00							
SQU-DS	2026-06-25 17:00:00	10.89	21.06	0.52	7.41	10.26	42.14	0.01
SQU-DS	2026-06-25 17:15:00							
SQU-DS	2026-06-25 17:30:00							
SQU-DS	2026-06-25 17:45:00							
SQU-DS	2026-06-25 18:00:00	10.92	21.17	0.52	7.45	10.24	50.73	0.01
SQU-DS	2026-06-25 18:15:00							
SQU-DS	2026-06-25 18:30:00							
SQU-DS	2026-06-25 18:45:00							
SQU-DS	2026-06-25 19:00:00	10.88	21.11	0.53	7.41	10.20	33.31	0.01
SQU-DS	2026-06-25 19:15:00							
SQU-DS	2026-06-25 19:30:00							
SQU-DS	2026-06-25 19:45:00							
SQU-DS	2026-06-25 20:00:00	10.85	20.93	0.52	7.39	10.15	36.82	0.01
SQU-DS	2026-06-25 20:15:00							
SQU-DS	2026-06-25 20:30:00							
SQU-DS	2026-06-25 20:45:00							
SQU-DS	2026-06-25 21:00:00	10.80	20.10	0.52	7.38	10.12	33.86	0.01
SQU-DS	2026-06-25 21:15:00							
SQU-DS	2026-06-25 21:30:00							
SQU-DS	2026-06-25 21:45:00							
SQU-DS	2026-06-25 22:00:00	10.74	19.80	0.52	7.38	10.11	43.03	0.01
SQU-DS	2026-06-25 22:15:00							
SQU-DS	2026-06-25 22:30:00							
SQU-DS	2026-06-25 22:45:00							
SQU-DS	2026-06-25 23:00:00	10.66	19.29	0.53	7.37	10.10	40.75	0.01
SQU-DS	2026-06-25 23:15:00							
SQU-DS	2026-06-25 23:30:00							
SQU-DS	2026-06-25 23:45:00							
SQU-DS	2026-06-26 00:00:00	10.57	18.46	0.53	7.38	10.11	31.00	0.01

Squamish River								
Station	Date/Time	Temperature (C)	Specific Conductivity (µS/cm)	ORP (V)	pH (pH units)	Dissolved Oxygen (mg/L)	Turbidity (NTU)	Salinity (PSU)
SQU-DS	2026-06-26 00:15:00							
SQU-DS	2026-06-26 00:30:00							
SQU-DS	2026-06-26 00:45:00							
SQU-DS	2026-06-26 01:00:00	10.48	17.96	0.53	7.38	10.12	33.25	0.01
SQU-DS	2026-06-26 01:15:00							
SQU-DS	2026-06-26 01:30:00							
SQU-DS	2026-06-26 01:45:00							
SQU-DS	2026-06-26 02:00:00	10.38	17.38	0.53	7.39	10.13	27.40	0.01
SQU-DS	2026-06-26 02:15:00							
SQU-DS	2026-06-26 02:30:00							
SQU-DS	2026-06-26 02:45:00							
SQU-DS	2026-06-26 03:00:00	10.28	17.10	0.54	7.42	10.13	33.78	0.01
SQU-DS	2026-06-26 03:15:00							
SQU-DS	2026-06-26 03:30:00							
SQU-DS	2026-06-26 03:45:00							
SQU-DS	2026-06-26 04:00:00	10.18	17.27	0.54	7.37	10.14	31.10	0.01
SQU-DS	2026-06-26 04:15:00							
SQU-DS	2026-06-26 04:30:00							
SQU-DS	2026-06-26 04:45:00							
SQU-DS	2026-06-26 05:00:00	10.10	16.90	0.54	7.37	10.14	38.77	0.01
SQU-DS	2026-06-26 05:15:00							
SQU-DS	2026-06-26 05:30:00							
SQU-DS	2026-06-26 05:45:00							
SQU-DS	2026-06-26 06:00:00	10.05	17.83	0.54	7.30	10.14	34.47	0.01
SQU-DS	2026-06-26 06:15:00							
SQU-DS	2026-06-26 06:30:00							
SQU-DS	2026-06-26 06:45:00							
SQU-DS	2026-06-26 07:00:00	10.02	17.90	0.54	7.30	10.16	39.53	0.01
SQU-DS	2026-06-26 07:15:00							
SQU-DS	2026-06-26 07:30:00							
SQU-DS	2026-06-26 07:45:00							
SQU-DS	2026-06-26 08:00:00	10.01	18.05	0.54	7.34	10.19	24.80	0.01
SQU-DS	2026-06-26 08:15:00							
SQU-DS	2026-06-26 08:30:00							
SQU-DS	2026-06-26 08:45:00							
SQU-DS	2026-06-26 09:00:00	10.03	18.37	0.54	7.38	10.22	35.12	0.01
SQU-DS	2026-06-26 09:15:00							
SQU-DS	2026-06-26 09:30:00							
SQU-DS	2026-06-26 09:45:00							
SQU-DS	2026-06-26 10:00:00	10.03	18.35	0.54	7.38	10.25	30.62	0.01
SQU-DS	2026-06-26 10:15:00							
SQU-DS	2026-06-26 10:30:00							
SQU-DS	2026-06-26 10:45:00							
SQU-DS	2026-06-26 11:00:00	10.07	18.19	0.54	7.36	10.28	36.51	0.01
SQU-DS	2026-06-26 11:15:00							
SQU-DS	2026-06-26 11:30:00							
SQU-DS	2026-06-26 11:45:00							
SQU-DS	2026-06-26 12:00:00	10.08	18.46	0.54	7.33	10.29	25.52	0.01
SQU-DS	2026-06-26 12:15:00							
SQU-DS	2026-06-26 12:30:00							
SQU-DS	2026-06-26 12:45:00							
SQU-DS	2026-06-26 13:00:00	10.11	18.23	0.53	7.40	10.31	26.45	0.01
SQU-DS	2026-06-26 13:15:00							
SQU-DS	2026-06-26 13:30:00							
SQU-DS	2026-06-26 13:45:00							

Squamish River								
Station	Date/Time	Temperature (C)	Specific Conductivity (µS/cm)	ORP (V)	pH (pH units)	Dissolved Oxygen (mg/L)	Turbidity (NTU)	Salinity (PSU)
SQU-DS	2026-06-26 14:00:00	10.10	18.13	0.53	7.40	10.33	28.15	0.01
SQU-DS	2026-06-26 14:15:00							
SQU-DS	2026-06-26 14:30:00							
SQU-DS	2026-06-26 14:45:00							
SQU-DS	2026-06-26 15:00:00	10.14	17.50	0.54	7.36	10.35	31.15	0.01
SQU-DS	2026-06-26 15:15:00							
SQU-DS	2026-06-26 15:30:00							
SQU-DS	2026-06-26 15:45:00							
SQU-DS	2026-06-26 16:00:00	10.14	16.54	0.53	7.46	10.36	37.08	0.01
SQU-DS	2026-06-26 16:15:00							
SQU-DS	2026-06-26 16:30:00							
SQU-DS	2026-06-26 16:45:00							
SQU-DS	2026-06-26 17:00:00	10.16	16.32	0.54	7.47	10.37	28.60	0.01
SQU-DS	2026-06-26 17:15:00							
SQU-DS	2026-06-26 17:30:00							
SQU-DS	2026-06-26 17:45:00							
SQU-DS	2026-06-26 18:00:00	10.19	16.52	0.54	7.50	10.37	31.01	0.01
SQU-DS	2026-06-26 18:15:00							
SQU-DS	2026-06-26 18:30:00							
SQU-DS	2026-06-26 18:45:00							
SQU-DS	2026-06-26 19:00:00	10.22	16.57	0.54	7.50	10.36	27.67	0.01
SQU-DS	2026-06-26 19:15:00							
SQU-DS	2026-06-26 19:30:00							
SQU-DS	2026-06-26 19:45:00							
SQU-DS	2026-06-26 20:00:00	10.19	16.72	0.54	7.49	10.34	29.28	0.01
SQU-DS	2026-06-26 20:15:00							
SQU-DS	2026-06-26 20:30:00							
SQU-DS	2026-06-26 20:45:00							
SQU-DS	2026-06-26 21:00:00	10.12	16.80	0.54	7.47	10.31	27.37	0.01
SQU-DS	2026-06-26 21:15:00							
SQU-DS	2026-06-26 21:30:00							
SQU-DS	2026-06-26 21:45:00							
SQU-DS	2026-06-26 22:00:00	10.04	16.85	0.54	7.44	10.29	36.25	0.01
SQU-DS	2026-06-26 22:15:00							
SQU-DS	2026-06-26 22:30:00							
SQU-DS	2026-06-26 22:45:00							
SQU-DS	2026-06-26 23:00:00	9.97	16.68	0.54	7.44	10.29	37.11	0.01
SQU-DS	2026-06-26 23:15:00							
SQU-DS	2026-06-26 23:30:00							
SQU-DS	2026-06-26 23:45:00							
SQU-DS	2026-06-27 00:00:00	9.90	16.26	0.54	7.43	10.30	38.85	0.01
SQU-DS	2026-06-27 00:15:00							
SQU-DS	2026-06-27 00:30:00							
SQU-DS	2026-06-27 00:45:00							
SQU-DS	2026-06-27 01:00:00	9.82	16.04	0.54	7.43	10.31	40.04	0.01
SQU-DS	2026-06-27 01:15:00							
SQU-DS	2026-06-27 01:30:00							
SQU-DS	2026-06-27 01:45:00							
SQU-DS	2026-06-27 02:00:00	9.69	15.81	0.55	7.43	10.34	38.71	0.01
SQU-DS	2026-06-27 02:15:00							
SQU-DS	2026-06-27 02:30:00							
SQU-DS	2026-06-27 02:45:00							
SQU-DS	2026-06-27 03:00:00	9.54	15.21	0.55	7.42	10.38	44.52	0.01
SQU-DS	2026-06-27 03:15:00							
SQU-DS	2026-06-27 03:30:00							

Squamish River								
Station	Date/Time	Temperature (C)	Specific Conductivity (µS/cm)	ORP (V)	pH (pH units)	Dissolved Oxygen (mg/L)	Turbidity (NTU)	Salinity (PSU)
SQU-DS	2026-06-27 03:45:00							
SQU-DS	2026-06-27 04:00:00	9.38	15.37	0.55	7.41	10.41	41.79	0.01
SQU-DS	2026-06-27 04:15:00							
SQU-DS	2026-06-27 04:30:00							
SQU-DS	2026-06-27 04:45:00							
SQU-DS	2026-06-27 05:00:00	9.26	15.39	0.55	7.39	10.44	45.22	0.01
SQU-DS	2026-06-27 05:15:00							
SQU-DS	2026-06-27 05:30:00							
SQU-DS	2026-06-27 05:45:00							
SQU-DS	2026-06-27 06:00:00	9.16	15.36	0.55	7.39	10.48	46.73	0.01
SQU-DS	2026-06-27 06:15:00							
SQU-DS	2026-06-27 06:30:00							
SQU-DS	2026-06-27 06:45:00							
SQU-DS	2026-06-27 07:00:00	9.08	14.99	0.55	7.38	10.51	52.85	0.01
SQU-DS	2026-06-27 07:15:00							
SQU-DS	2026-06-27 07:30:00							
SQU-DS	2026-06-27 07:45:00							
SQU-DS	2026-06-27 08:00:00	9.10	15.43	0.55	7.36	10.54	53.96	0.01
SQU-DS	2026-06-27 08:15:00							
SQU-DS	2026-06-27 08:30:00							
SQU-DS	2026-06-27 08:45:00							
SQU-DS	2026-06-27 09:00:00	9.25	14.97	0.54	7.37	10.56	70.08	0.01
SQU-DS	2026-06-27 09:15:00							
SQU-DS	2026-06-27 09:30:00							
SQU-DS	2026-06-27 09:45:00							
SQU-DS	2026-06-27 10:00:00	9.48	14.57	0.54	7.37	10.56	57.48	0.01
SQU-DS	2026-06-27 10:15:00							
SQU-DS	2026-06-27 10:30:00							
SQU-DS	2026-06-27 10:45:00							
SQU-DS	2026-06-27 11:00:00	9.69	14.50	0.54	7.38	10.57	45.79	0.01
SQU-DS	2026-06-27 11:15:00							
SQU-DS	2026-06-27 11:30:00							
SQU-DS	2026-06-27 11:45:00							
SQU-DS	2026-06-27 12:00:00	9.90	14.32	0.54	7.39	10.56	47.94	0.01
SQU-DS	2026-06-27 12:15:00							
SQU-DS	2026-06-27 12:30:00							
SQU-DS	2026-06-27 12:45:00							
SQU-DS	2026-06-27 13:00:00	10.20	14.60	0.54	7.40	10.55	44.38	0.01
SQU-DS	2026-06-27 13:15:00							
SQU-DS	2026-06-27 13:30:00							
SQU-DS	2026-06-27 13:45:00							
SQU-DS	2026-06-27 14:00:00	10.39	14.20	0.54	7.36	10.51	47.09	0.01
SQU-DS	2026-06-27 14:15:00							
SQU-DS	2026-06-27 14:30:00							
SQU-DS	2026-06-27 14:45:00							
SQU-DS	2026-06-27 15:00:00	10.53	14.40	0.54	7.38	10.47	43.47	0.01
SQU-DS	2026-06-27 15:15:00							
SQU-DS	2026-06-27 15:30:00							
SQU-DS	2026-06-27 15:45:00							
SQU-DS	2026-06-27 16:00:00	10.72	14.37	0.54	7.41	10.43	40.58	0.01
SQU-DS	2026-06-27 16:15:00							
SQU-DS	2026-06-27 16:30:00							
SQU-DS	2026-06-27 16:45:00							
SQU-DS	2026-06-27 17:00:00	10.95	14.15	0.54	7.43	10.38	39.06	0.01
SQU-DS	2026-06-27 17:15:00							

Squamish River								
Station	Date/Time	Temperature (C)	Specific Conductivity (µS/cm)	ORP (V)	pH (pH units)	Dissolved Oxygen (mg/L)	Turbidity (NTU)	Salinity (PSU)
SQU-DS	2026-06-27 17:30:00							
SQU-DS	2026-06-27 17:45:00							
SQU-DS	2026-06-27 18:00:00	11.16	14.16	0.54	7.47	10.32	36.39	0.01
SQU-DS	2026-06-27 18:15:00							
SQU-DS	2026-06-27 18:30:00							
SQU-DS	2026-06-27 18:45:00							
SQU-DS	2026-06-27 19:00:00	11.16	14.15	0.54	7.47	10.23	36.90	0.01
SQU-DS	2026-06-27 19:15:00							
SQU-DS	2026-06-27 19:30:00							
SQU-DS	2026-06-27 19:45:00							
SQU-DS	2026-06-27 20:00:00	11.14	14.21	0.55	7.46	10.17	35.28	0.01
SQU-DS	2026-06-27 20:15:00							
SQU-DS	2026-06-27 20:30:00							
SQU-DS	2026-06-27 20:45:00							
SQU-DS	2026-06-27 21:00:00	11.01	14.46	0.55	7.43	10.11	36.02	0.01
SQU-DS	2026-06-27 21:15:00							
SQU-DS	2026-06-27 21:30:00							
SQU-DS	2026-06-27 21:45:00							
SQU-DS	2026-06-27 22:00:00	10.92	15.03	0.55	7.38	10.06	33.80	0.01
SQU-DS	2026-06-27 22:15:00							
SQU-DS	2026-06-27 22:30:00							
SQU-DS	2026-06-27 22:45:00							
SQU-DS	2026-06-27 23:00:00	10.85	15.20	0.54	7.36	10.03	38.13	0.01
SQU-DS	2026-06-27 23:15:00							
SQU-DS	2026-06-27 23:30:00							
SQU-DS	2026-06-27 23:45:00							
SQU-DS	2026-06-28 00:00:00	10.76	15.20	0.54	7.36	10.03	34.30	0.01
SQU-DS	2026-06-28 00:15:00							
SQU-DS	2026-06-28 00:30:00							
SQU-DS	2026-06-28 00:45:00							
SQU-DS	2026-06-28 01:00:00	10.64	15.27	0.55	7.35	10.05	33.10	0.01
SQU-DS	2026-06-28 01:15:00							
SQU-DS	2026-06-28 01:30:00							
SQU-DS	2026-06-28 01:45:00							
SQU-DS	2026-06-28 02:00:00	10.50	15.32	0.55	7.36	10.09	32.09	0.01
SQU-DS	2026-06-28 02:15:00							
SQU-DS	2026-06-28 02:30:00							
SQU-DS	2026-06-28 02:45:00							
SQU-DS	2026-06-28 03:00:00	10.33	15.22	0.55	7.35	10.11	35.52	0.01
SQU-DS	2026-06-28 03:15:00							
SQU-DS	2026-06-28 03:30:00							
SQU-DS	2026-06-28 03:45:00							
SQU-DS	2026-06-28 04:00:00	10.20	14.95	0.55	7.37	10.12	35.35	0.01
SQU-DS	2026-06-28 04:15:00							
SQU-DS	2026-06-28 04:30:00							
SQU-DS	2026-06-28 04:45:00							
SQU-DS	2026-06-28 05:00:00	10.10	14.99	0.55	7.35	10.13	38.45	0.01
SQU-DS	2026-06-28 05:15:00							
SQU-DS	2026-06-28 05:30:00							
SQU-DS	2026-06-28 05:45:00							
SQU-DS	2026-06-28 06:00:00	10.01	15.23	0.55	7.33	10.15	25.88	0.01
SQU-DS	2026-06-28 06:15:00							
SQU-DS	2026-06-28 06:30:00							
SQU-DS	2026-06-28 06:45:00							
SQU-DS	2026-06-28 07:00:00	9.96	15.81	0.55	7.33	10.21	33.63	0.01

Squamish River								
Station	Date/Time	Temperature (C)	Specific Conductivity (µS/cm)	ORP (V)	pH (pH units)	Dissolved Oxygen (mg/L)	Turbidity (NTU)	Salinity (PSU)
SQU-DS	2026-06-28 07:15:00							
SQU-DS	2026-06-28 07:30:00							
SQU-DS	2026-06-28 07:45:00							
SQU-DS	2026-06-28 08:00:00	9.95	16.39	0.55	7.33	10.27	34.59	0.01
SQU-DS	2026-06-28 08:15:00							
SQU-DS	2026-06-28 08:30:00							
SQU-DS	2026-06-28 08:45:00							
SQU-DS	2026-06-28 09:00:00	10.02	15.86	0.55	7.33	10.33	33.03	0.01
SQU-DS	2026-06-28 09:15:00							
SQU-DS	2026-06-28 09:30:00							
SQU-DS	2026-06-28 09:45:00							
SQU-DS	2026-06-28 10:00:00	10.17	16.40	0.54	7.35	10.34	31.47	0.01
SQU-DS	2026-06-28 10:15:00							
SQU-DS	2026-06-28 10:30:00							
SQU-DS	2026-06-28 10:45:00							
SQU-DS	2026-06-28 11:00:00	10.26	16.50	0.54	7.36	10.36	32.32	0.01
SQU-DS	2026-06-28 11:15:00							
SQU-DS	2026-06-28 11:30:00							
SQU-DS	2026-06-28 11:45:00							
SQU-DS	2026-06-28 12:00:00	10.48	17.17	0.54	7.38	10.36	37.26	0.01
SQU-DS	2026-06-28 12:15:00							
SQU-DS	2026-06-28 12:30:00							
SQU-DS	2026-06-28 12:45:00							
SQU-DS	2026-06-28 13:00:00	10.72	17.38	0.54	7.38	10.35	33.57	0.01
SQU-DS	2026-06-28 13:15:00							
SQU-DS	2026-06-28 13:30:00							
SQU-DS	2026-06-28 13:45:00							
SQU-DS	2026-06-28 14:00:00	10.82	17.68	0.54	7.37	10.34	32.41	0.01
SQU-DS	2026-06-28 14:15:00							
SQU-DS	2026-06-28 14:30:00							
SQU-DS	2026-06-28 14:45:00							
SQU-DS	2026-06-28 15:00:00	10.92	18.00	0.54	7.37	10.31	38.17	0.01
SQU-DS	2026-06-28 15:15:00							
SQU-DS	2026-06-28 15:30:00							
SQU-DS	2026-06-28 15:45:00							
SQU-DS	2026-06-28 16:00:00	11.12	18.03	0.54	7.39	10.31	28.75	0.01
SQU-DS	2026-06-28 16:15:00							
SQU-DS	2026-06-28 16:30:00							
SQU-DS	2026-06-28 16:45:00							
SQU-DS	2026-06-28 17:00:00	11.43	17.88	0.54	7.44	10.30	27.79	0.01
SQU-DS	2026-06-28 17:15:00							
SQU-DS	2026-06-28 17:30:00							
SQU-DS	2026-06-28 17:45:00							
SQU-DS	2026-06-28 18:00:00	11.73	16.64	0.54	7.46	10.24	22.01	0.01
SQU-DS	2026-06-28 18:15:00							
SQU-DS	2026-06-28 18:30:00							
SQU-DS	2026-06-28 18:45:00							
SQU-DS	2026-06-28 19:00:00	11.78	16.36	0.54	7.48	10.19	15.90	0.01
SQU-DS	2026-06-28 19:15:00							
SQU-DS	2026-06-28 19:30:00							
SQU-DS	2026-06-28 19:45:00							
SQU-DS	2026-06-28 20:00:00	11.81	16.65	0.54	7.47	10.11	12.10	0.01
SQU-DS	2026-06-28 20:15:00							
SQU-DS	2026-06-28 20:30:00							
SQU-DS	2026-06-28 20:45:00							

Squamish River								
Station	Date/Time	Temperature (C)	Specific Conductivity (µS/cm)	ORP (V)	pH (pH units)	Dissolved Oxygen (mg/L)	Turbidity (NTU)	Salinity (PSU)
SQU-DS	2026-06-28 21:00:00	11.85	16.69	0.54	7.48	10.01	16.28	0.01
SQU-DS	2026-06-28 21:15:00							
SQU-DS	2026-06-28 21:30:00							
SQU-DS	2026-06-28 21:45:00							
SQU-DS	2026-06-28 22:00:00	11.77	16.99	0.54	7.45	9.95	20.32	0.01
SQU-DS	2026-06-28 22:15:00							
SQU-DS	2026-06-28 22:30:00							
SQU-DS	2026-06-28 22:45:00							
SQU-DS	2026-06-28 23:00:00	11.69	17.01	0.54	7.41	9.91	27.40	0.01
SQU-DS	2026-06-28 23:15:00							
SQU-DS	2026-06-28 23:30:00							
SQU-DS	2026-06-28 23:45:00							
SQU-US	2026-06-22 00:00:00							
SQU-US	2026-06-22 00:15:00	11.77	26.16	428.57	7.21	10.81	31.86	0.01
SQU-US	2026-06-22 00:30:00	11.70	26.40	428.68	7.22	10.82	36.30	0.01
SQU-US	2026-06-22 00:45:00	11.63	26.42	429.03	7.22	10.83	32.00	0.01
SQU-US	2026-06-22 01:00:00	11.55	26.77	428.14	7.23	10.85	35.03	0.01
SQU-US	2026-06-22 01:15:00	11.49	26.41	430.11	7.21	10.85	34.44	0.01
SQU-US	2026-06-22 01:30:00	11.42	26.48	430.79	7.23	10.86	33.16	0.01
SQU-US	2026-06-22 01:45:00	11.36	26.55	431.71	7.23	10.88	33.11	0.01
SQU-US	2026-06-22 02:00:00	11.29	26.20	433.00	7.21	10.89	32.06	0.01
SQU-US	2026-06-22 02:15:00	11.22	25.90	434.85	7.20	10.91	32.44	0.01
SQU-US	2026-06-22 02:30:00	11.17	25.62	435.58	7.19	10.92	31.68	0.01
SQU-US	2026-06-22 02:45:00	11.10	24.94	436.73	7.17	10.93	33.10	0.01
SQU-US	2026-06-22 03:00:00	11.05	25.36	435.34	7.15	10.93	34.92	0.01
SQU-US	2026-06-22 03:15:00	10.98	25.35	433.14	7.13	10.93	33.02	0.01
SQU-US	2026-06-22 03:30:00	10.94	24.99	429.63	7.12	10.94	33.90	0.01
SQU-US	2026-06-22 03:45:00	10.87	25.22	423.98	7.14	10.95	32.84	0.01
SQU-US	2026-06-22 04:00:00	10.81	25.49	419.54	7.13	10.96	35.90	0.01
SQU-US	2026-06-22 04:15:00	10.77	24.79	418.20	7.10	10.98	32.92	0.01
SQU-US	2026-06-22 04:30:00	10.71	25.18	415.88	7.11	11.00	34.49	0.01
SQU-US	2026-06-22 04:45:00	10.65	25.00	415.33	7.12	11.01	34.54	0.01
SQU-US	2026-06-22 05:00:00	10.60	24.48	416.77	7.10	11.03	39.24	0.01
SQU-US	2026-06-22 05:15:00	10.55	24.59	416.45	7.13	11.05	35.14	0.01
SQU-US	2026-06-22 05:30:00	10.50	24.54	417.73	7.15	11.08	37.12	0.01
SQU-US	2026-06-22 05:45:00	10.46	24.19	420.32	7.13	11.08	37.72	0.01
SQU-US	2026-06-22 06:00:00	10.42	24.25	421.59	7.14	11.11	38.11	0.01
SQU-US	2026-06-22 06:15:00	10.37	24.52	423.50	7.14	11.12	35.32	0.01
SQU-US	2026-06-22 06:30:00	10.34	24.17	423.99	7.15	11.16	36.58	0.01
SQU-US	2026-06-22 06:45:00	10.31	24.09	425.23	7.14	11.16	38.76	0.01
SQU-US	2026-06-22 07:00:00	10.30	24.27	424.94	7.15	11.18	39.76	0.01
SQU-US	2026-06-22 07:15:00	10.28	24.23	424.91	7.15	11.19	37.16	0.01
SQU-US	2026-06-22 07:30:00	10.28	24.01	424.54	7.14	11.21	36.54	0.01
SQU-US	2026-06-22 07:45:00	10.30	23.86	424.07	7.14	11.22	36.25	0.01
SQU-US	2026-06-22 08:00:00	10.27	24.27	422.50	7.15	11.25	36.12	0.01
SQU-US	2026-06-22 08:15:00	10.32	24.00	421.48	7.16	11.24	40.53	0.01
SQU-US	2026-06-22 08:30:00	10.34	23.92	419.89	7.17	11.25	37.53	0.01
SQU-US	2026-06-22 08:45:00	10.39	23.75	421.02	7.16	11.26	36.24	0.01
SQU-US	2026-06-22 09:00:00	10.42	23.96	417.92	7.19	11.28	34.77	0.01
SQU-US	2026-06-22 09:15:00	10.47	24.18	417.52	7.19	11.28	38.63	0.01
SQU-US	2026-06-22 09:30:00	10.51	24.20	415.95	7.19	11.29	35.42	0.01
SQU-US	2026-06-22 09:45:00	10.57	25.05	415.08	7.18	11.29	35.32	0.01
SQU-US	2026-06-22 10:00:00	10.63	24.66	414.67	7.18	11.28	36.00	0.01
SQU-US	2026-06-22 10:15:00	10.68	24.79	411.43	7.19	11.30	34.56	0.01
SQU-US	2026-06-22 10:30:00	10.76	24.19	410.58	7.20	11.30	38.15	0.01

Squamish River								
Station	Date/Time	Temperature (C)	Specific Conductivity (µS/cm)	ORP (V)	pH (pH units)	Dissolved Oxygen (mg/L)	Turbidity (NTU)	Salinity (PSU)
SQU-US	2026-06-22 10:45:00	10.80	24.71	411.36	7.17	11.29	41.77	0.01
SQU-US	2026-06-22 11:00:00	10.86	24.66	409.04	7.19	11.31	36.67	0.01
SQU-US	2026-06-22 11:15:00	10.92	25.01	408.53	7.19	11.30	36.01	0.01
SQU-US	2026-06-22 11:30:00	11.00	24.75	407.24	7.20	11.31	33.94	0.01
SQU-US	2026-06-22 11:45:00	11.08	24.17	407.08	7.20	11.30	36.27	0.01
SQU-US	2026-06-22 12:00:00	11.14	24.78	406.83	7.18	11.30	31.54	0.01
SQU-US	2026-06-22 12:15:00	11.22	24.82	406.12	7.19	11.29	31.65	0.01
SQU-US	2026-06-22 12:30:00	11.29	24.23	405.46	7.20	11.29	34.75	0.01
SQU-US	2026-06-22 12:45:00	11.37	24.47	405.48	7.19	11.29	33.98	0.01
SQU-US	2026-06-22 13:00:00	11.44	24.32	402.17	7.24	11.29	29.87	0.01
SQU-US	2026-06-22 13:15:00	11.52	24.88	404.06	7.19	11.28	31.63	0.01
SQU-US	2026-06-22 13:30:00	11.59	24.56	402.71	7.21	11.27	31.41	0.01
SQU-US	2026-06-22 13:45:00	11.68	24.68	404.73	7.17	11.26	30.29	0.01
SQU-US	2026-06-22 14:00:00	11.75	24.90	402.27	7.19	11.25	31.55	0.01
SQU-US	2026-06-22 14:15:00	11.83	25.26	401.59	7.17	11.22	32.45	0.01
SQU-US	2026-06-22 14:30:00	11.91	25.30	397.82	7.17	11.21	33.65	0.01
SQU-US	2026-06-22 14:45:00	11.98	24.95	394.96	7.19	11.20	31.23	0.01
SQU-US	2026-06-22 15:00:00	12.06	24.71	398.12	7.18	11.20	35.46	0.01
SQU-US	2026-06-22 15:15:00	12.11	24.31	398.92	7.20	11.19	34.96	0.01
SQU-US	2026-06-22 15:30:00	12.17	24.12	401.24	7.17	11.17	32.93	0.01
SQU-US	2026-06-22 15:45:00	12.25	25.06	400.50	7.19	11.15	35.95	0.01
SQU-US	2026-06-22 16:00:00	12.28	24.48	398.74	7.17	11.15	34.60	0.01
SQU-US	2026-06-22 16:15:00	12.33	24.68	396.38	7.22	11.12	33.52	0.01
SQU-US	2026-06-22 16:30:00	12.38	25.05	398.56	7.23	11.11	34.60	0.01
SQU-US	2026-06-22 16:45:00	12.41	24.84	399.65	7.24	11.09	32.19	0.01
SQU-US	2026-06-22 17:00:00	12.44	24.64	402.27	7.20	11.08	34.23	0.01
SQU-US	2026-06-22 17:15:00	12.52	25.14	402.69	7.19	11.06	32.95	0.01
SQU-US	2026-06-22 17:30:00	12.56	24.79	402.70	7.21	11.06	36.83	0.01
SQU-US	2026-06-22 17:45:00	12.61	24.88	402.74	7.24	11.04	33.11	0.01
SQU-US	2026-06-22 18:00:00	12.65	25.07	402.47	7.25	11.01	31.77	0.01
SQU-US	2026-06-22 18:15:00	12.67	24.89	403.19	7.25	10.99	33.15	0.01
SQU-US	2026-06-22 18:30:00	12.68	25.16	404.12	7.25	10.97	35.72	0.01
SQU-US	2026-06-22 18:45:00	12.69	25.39	405.28	7.24	10.94	32.13	0.01
SQU-US	2026-06-22 19:00:00	12.70	25.53	406.07	7.23	10.91	30.93	0.01
SQU-US	2026-06-22 19:15:00	12.69	25.18	408.57	7.21	10.90	33.68	0.01
SQU-US	2026-06-22 19:30:00	12.68	25.36	408.82	7.23	10.87	32.41	0.01
SQU-US	2026-06-22 19:45:00	12.66	25.45	410.33	7.23	10.86	35.26	0.01
SQU-US	2026-06-22 20:00:00	12.66	25.35	410.05	7.25	10.84	32.03	0.01
SQU-US	2026-06-22 20:15:00	12.64	25.58	413.15	7.21	10.81	32.15	0.01
SQU-US	2026-06-22 20:30:00	12.62	25.52	413.73	7.23	10.79	32.37	0.01
SQU-US	2026-06-22 20:45:00	12.60	25.58	417.25	7.20	10.78	34.97	0.01
SQU-US	2026-06-22 21:00:00	12.57	25.69	417.00	7.24	10.76	31.20	0.01
SQU-US	2026-06-22 21:15:00	12.55	25.48	419.45	7.23	10.77	35.07	0.01
SQU-US	2026-06-22 21:30:00	12.52	25.40	421.86	7.23	10.76	33.74	0.01
SQU-US	2026-06-22 21:45:00	12.50	25.67	425.80	7.22	10.75	33.87	0.01
SQU-US	2026-06-22 22:00:00	12.47	25.23	428.97	7.21	10.75	34.33	0.01
SQU-US	2026-06-22 22:15:00	12.44	25.28	431.54	7.22	10.74	32.23	0.01
SQU-US	2026-06-22 22:30:00	12.40	25.42	433.92	7.21	10.73	32.63	0.01
SQU-US	2026-06-22 22:45:00	12.36	25.39	435.19	7.22	10.74	33.81	0.01
SQU-US	2026-06-22 23:00:00	12.31	25.22	436.96	7.20	10.73	34.02	0.01
SQU-US	2026-06-22 23:15:00	12.26	25.40	436.50	7.23	10.74	34.52	0.01
SQU-US	2026-06-22 23:30:00	12.20	25.03	439.57	7.20	10.77	32.00	0.01
SQU-US	2026-06-22 23:45:00	12.14	25.60	440.47	7.21	10.76	32.38	0.01
SQU-US	2026-06-23 00:00:00	12.07	25.12	441.89	7.20	10.77	32.83	0.01
SQU-US	2026-06-23 00:15:00	12.00	25.22	444.81	7.18	10.78	33.97	0.01

Squamish River								
Station	Date/Time	Temperature (C)	Specific Conductivity (µS/cm)	ORP (V)	pH (pH units)	Dissolved Oxygen (mg/L)	Turbidity (NTU)	Salinity (PSU)
SQU-US	2026-06-23 00:30:00	11.93	25.22	444.70	7.20	10.79	37.07	0.01
SQU-US	2026-06-23 00:45:00	11.86	25.04	446.95	7.19	10.80	36.69	0.01
SQU-US	2026-06-23 01:00:00	11.81	25.02	446.55	7.20	10.81	35.30	0.01
SQU-US	2026-06-23 01:15:00	11.72	25.16	447.76	7.21	10.83	33.66	0.01
SQU-US	2026-06-23 01:30:00	11.66	24.94	449.94	7.18	10.84	39.27	0.01
SQU-US	2026-06-23 01:45:00	11.59	25.10	450.43	7.20	10.84	41.21	0.01
SQU-US	2026-06-23 02:00:00	11.52	25.14	450.05	7.20	10.86	40.49	0.01
SQU-US	2026-06-23 02:15:00	11.46	24.99	451.59	7.19	10.87	38.33	0.01
SQU-US	2026-06-23 02:30:00	11.40	24.74	453.74	7.17	10.88	39.42	0.01
SQU-US	2026-06-23 02:45:00	11.33	24.50	454.31	7.17	10.91	38.59	0.01
SQU-US	2026-06-23 03:00:00	11.26	24.69	452.88	7.20	10.91	41.01	0.01
SQU-US	2026-06-23 03:15:00	11.20	24.47	455.29	7.15	10.91	40.34	0.01
SQU-US	2026-06-23 03:30:00	11.15	24.39	454.67	7.16	10.92	43.04	0.01
SQU-US	2026-06-23 03:45:00	11.10	24.22	454.73	7.13	10.94	37.66	0.01
SQU-US	2026-06-23 04:00:00	11.06	23.73	453.56	7.10	10.95	41.51	0.01
SQU-US	2026-06-23 04:15:00	10.98	24.14	449.61	7.13	10.97	40.37	0.01
SQU-US	2026-06-23 04:30:00	10.96	23.75	449.33	7.11	10.98	40.75	0.01
SQU-US	2026-06-23 04:45:00	10.87	23.92	449.33	7.12	10.99	38.80	0.01
SQU-US	2026-06-23 05:00:00	10.80	24.14	448.02	7.14	11.01	42.06	0.01
SQU-US	2026-06-23 05:15:00	10.77	23.90	447.60	7.14	11.03	42.59	0.01
SQU-US	2026-06-23 05:30:00	10.73	23.66	448.27	7.14	11.04	42.91	0.01
SQU-US	2026-06-23 05:45:00	10.70	23.54	448.48	7.14	11.05	44.31	0.01
SQU-US	2026-06-23 06:00:00	10.66	23.66	448.90	7.12	11.07	42.68	0.01
SQU-US	2026-06-23 06:15:00	10.64	23.53	448.59	7.13	11.10	47.73	0.01
SQU-US	2026-06-23 06:30:00	10.60	23.54	448.10	7.14	11.11	48.25	0.01
SQU-US	2026-06-23 06:45:00	10.60	23.33	446.21	7.16	11.12	44.64	0.01
SQU-US	2026-06-23 07:00:00	10.56	23.29	445.93	7.15	11.14	46.08	0.01
SQU-US	2026-06-23 07:15:00	10.56	23.60	443.91	7.17	11.14	44.97	0.01
SQU-US	2026-06-23 07:30:00	10.54	23.42	442.40	7.18	11.16	46.18	0.01
SQU-US	2026-06-23 07:45:00	10.55	23.09	443.46	7.15	11.18	48.48	0.01
SQU-US	2026-06-23 08:00:00	10.56	23.43	442.16	7.14	11.18	44.37	0.01
SQU-US	2026-06-23 08:15:00	10.58	23.44	440.60	7.16	11.20	47.46	0.01
SQU-US	2026-06-23 08:30:00	10.60	23.27	439.54	7.15	11.21	49.42	0.01
SQU-US	2026-06-23 08:45:00	10.61	23.75	438.61	7.14	11.22	45.73	0.01
SQU-US	2026-06-23 09:00:00	10.68	23.12	436.26	7.14	11.23	49.05	0.01
SQU-US	2026-06-23 09:15:00	10.69	23.79	432.82	7.19	11.23	49.56	0.01
SQU-US	2026-06-23 09:30:00	10.74	23.59	431.96	7.17	11.25	50.75	0.01
SQU-US	2026-06-23 09:45:00	10.80	23.59	429.53	7.19	11.24	48.79	0.01
SQU-US	2026-06-23 10:00:00	10.81	24.16	427.32	7.19	11.25	45.35	0.01
SQU-US	2026-06-23 10:15:00	10.86	24.31	426.78	7.18	11.26	46.41	0.01
SQU-US	2026-06-23 10:30:00	10.94	23.63	427.08	7.16	11.25	50.59	0.01
SQU-US	2026-06-23 10:45:00	11.00	23.61	425.20	7.17	11.26	48.39	0.01
SQU-US	2026-06-23 11:00:00	11.06	23.80	423.53	7.17	11.26	45.67	0.01
SQU-US	2026-06-23 11:15:00	11.11	23.78	424.14	7.15	11.27	45.70	0.01
SQU-US	2026-06-23 11:30:00	11.18	23.49	422.36	7.16	11.26	44.31	0.01
SQU-US	2026-06-23 11:45:00	11.21	23.74	420.80	7.19	11.27	46.20	0.01
SQU-US	2026-06-23 12:00:00	11.30	23.74	416.87	7.22	11.27	43.73	0.01
SQU-US	2026-06-23 12:15:00	11.37	23.61	418.46	7.20	11.26	40.20	0.01
SQU-US	2026-06-23 12:30:00	11.44	23.85	417.47	7.20	11.26	44.26	0.01
SQU-US	2026-06-23 12:45:00	11.54	23.64	418.64	7.17	11.27	46.02	0.01
SQU-US	2026-06-23 13:00:00	11.63	23.89	413.54	7.24	11.25	42.20	0.01
SQU-US	2026-06-23 13:15:00	11.72	23.71	415.58	7.20	11.24	46.36	0.01
SQU-US	2026-06-23 13:30:00	11.81	23.58	414.99	7.21	11.24	44.45	0.01
SQU-US	2026-06-23 13:45:00	11.90	23.61	414.51	7.21	11.23	45.07	0.01
SQU-US	2026-06-23 14:00:00	11.99	23.88	413.73	7.21	11.22	45.66	0.01

Squamish River								
Station	Date/Time	Temperature (C)	Specific Conductivity (µS/cm)	ORP (V)	pH (pH units)	Dissolved Oxygen (mg/L)	Turbidity (NTU)	Salinity (PSU)
SQU-US	2026-06-23 14:15:00	12.09	23.78	415.38	7.19	11.20	40.49	0.01
SQU-US	2026-06-23 14:30:00	12.18	23.76	413.10	7.24	11.18	38.34	0.01
SQU-US	2026-06-23 14:45:00	12.24	23.90	413.48	7.22	11.17	39.94	0.01
SQU-US	2026-06-23 15:00:00	12.29	24.11	414.06	7.20	11.15	39.73	0.01
SQU-US	2026-06-23 15:15:00	12.34	24.75	415.02	7.21	11.14	39.68	0.01
SQU-US	2026-06-23 15:30:00	12.36	24.28	415.13	7.22	11.12	41.00	0.01
SQU-US	2026-06-23 15:45:00	12.40	24.18	415.57	7.21	11.11	40.07	0.01
SQU-US	2026-06-23 16:00:00	12.46	23.85	413.21	7.24	11.10	42.06	0.01
SQU-US	2026-06-23 16:15:00	12.53	24.63	415.77	7.22	11.07	39.35	0.01
SQU-US	2026-06-23 16:30:00	12.58	24.37	416.95	7.20	11.07	41.35	0.01
SQU-US	2026-06-23 16:45:00	12.65	24.70	416.10	7.22	11.03	38.91	0.01
SQU-US	2026-06-23 17:00:00	12.67	24.68	416.14	7.21	11.02	40.46	0.01
SQU-US	2026-06-23 17:15:00	12.65	24.54	417.49	7.21	10.98	40.13	0.01
SQU-US	2026-06-23 17:30:00	12.73	24.74	417.85	7.22	10.98	43.54	0.01
SQU-US	2026-06-23 17:45:00	12.79	24.91	418.52	7.21	10.95	40.39	0.01
SQU-US	2026-06-23 18:00:00	12.81	24.59	417.15	7.23	10.94	41.21	0.01
SQU-US	2026-06-23 18:15:00	12.83	24.02	419.15	7.22	10.93	37.77	0.01
SQU-US	2026-06-23 18:30:00	12.87	24.70	420.36	7.21	10.90	39.42	0.01
SQU-US	2026-06-23 18:45:00	12.90	25.00	420.99	7.22	10.87	42.13	0.01
SQU-US	2026-06-23 19:00:00	12.92	25.08	420.86	7.23	10.84	36.05	0.01
SQU-US	2026-06-23 19:15:00	12.91	24.63	423.02	7.21	10.85	43.98	0.01
SQU-US	2026-06-23 19:30:00	12.90	24.72	424.14	7.21	10.83	40.39	0.01
SQU-US	2026-06-23 19:45:00	12.85	24.97	426.07	7.20	10.81	39.59	0.01
SQU-US	2026-06-23 20:00:00	12.81	25.15	426.29	7.20	10.79	43.57	0.01
SQU-US	2026-06-23 20:15:00	12.77	25.20	427.72	7.21	10.77	40.30	0.01
SQU-US	2026-06-23 20:30:00	12.73	25.28	430.64	7.19	10.76	40.92	0.01
SQU-US	2026-06-23 20:45:00	12.69	25.03	431.18	7.21	10.76	40.01	0.01
SQU-US	2026-06-23 21:00:00	12.65	25.66	434.11	7.18	10.74	42.93	0.01
SQU-US	2026-06-23 21:15:00	12.60	25.04	434.42	7.21	10.74	42.07	0.01
SQU-US	2026-06-23 21:30:00	12.57	25.18	436.55	7.21	10.73	44.14	0.01
SQU-US	2026-06-23 21:45:00	12.52	24.97	439.55	7.19	10.73	45.26	0.01
SQU-US	2026-06-23 22:00:00	12.49	24.94	439.44	7.21	10.73	42.92	0.01
SQU-US	2026-06-23 22:15:00	12.44	24.98	444.29	7.17	10.72	42.70	0.01
SQU-US	2026-06-23 22:30:00	12.39	24.84	442.51	7.23	10.72	43.02	0.01
SQU-US	2026-06-23 22:45:00	12.33	24.74	445.52	7.20	10.74	44.88	0.01
SQU-US	2026-06-23 23:00:00	12.28	24.43	445.66	7.20	10.73	41.18	0.01
SQU-US	2026-06-23 23:15:00	12.21	24.68	447.31	7.21	10.74	46.49	0.01
SQU-US	2026-06-23 23:30:00	12.15	24.63	449.47	7.18	10.76	47.98	0.01
SQU-US	2026-06-23 23:45:00	12.09	24.60	449.63	7.20	10.76	48.85	0.01
SQU-US	2026-06-24 00:00:00	12.02	24.58	448.92	7.21	10.77	46.67	0.01
SQU-US	2026-06-24 00:15:00	11.95	24.10	451.41	7.21	10.79	51.65	0.01
SQU-US	2026-06-24 00:30:00	11.89	24.32	453.10	7.20	10.80	50.50	0.01
SQU-US	2026-06-24 00:45:00	11.83	24.32	454.44	7.19	10.81	48.74	0.01
SQU-US	2026-06-24 01:00:00	11.75	23.99	454.54	7.20	10.82	48.19	0.01
SQU-US	2026-06-24 01:15:00	11.69	24.03	455.70	7.20	10.83	50.87	0.01
SQU-US	2026-06-24 01:30:00	11.63	24.23	458.21	7.17	10.83	51.28	0.01
SQU-US	2026-06-24 01:45:00	11.57	23.79	457.50	7.19	10.86	50.38	0.01
SQU-US	2026-06-24 02:00:00	11.49	23.76	458.05	7.19	10.87	51.86	0.01
SQU-US	2026-06-24 02:15:00	11.47	23.39	458.66	7.20	10.87	51.36	0.01
SQU-US	2026-06-24 02:30:00	11.38	23.36	460.79	7.18	10.89	52.25	0.01
SQU-US	2026-06-24 02:45:00	11.32	23.68	461.96	7.17	10.90	55.51	0.01
SQU-US	2026-06-24 03:00:00	11.28	23.53	461.42	7.17	10.91	56.72	0.01
SQU-US	2026-06-24 03:15:00	11.22	23.11	463.48	7.15	10.93	57.62	0.01
SQU-US	2026-06-24 03:30:00	11.16	22.97	463.64	7.16	10.95	55.90	0.01
SQU-US	2026-06-24 03:45:00	11.11	22.78	462.86	7.18	10.96	57.60	0.01

Squamish River								
Station	Date/Time	Temperature (C)	Specific Conductivity (µS/cm)	ORP (V)	pH (pH units)	Dissolved Oxygen (mg/L)	Turbidity (NTU)	Salinity (PSU)
SQU-US	2026-06-24 04:00:00	11.05	22.97	465.03	7.13	10.97	59.77	0.01
SQU-US	2026-06-24 04:15:00	11.00	22.95	464.61	7.16	10.98	60.82	0.01
SQU-US	2026-06-24 04:30:00	10.96	22.68	465.89	7.13	11.00	59.83	0.01
SQU-US	2026-06-24 04:45:00	10.92	22.71	464.09	7.17	11.01	58.59	0.01
SQU-US	2026-06-24 05:00:00	10.87	22.58	465.14	7.14	11.00	60.53	0.01
SQU-US	2026-06-24 05:15:00	10.86	22.08	464.48	7.16	11.02	61.71	0.01
SQU-US	2026-06-24 05:30:00	10.79	22.61	467.13	7.11	11.03	61.37	0.01
SQU-US	2026-06-24 05:45:00	10.76	22.43	465.53	7.14	11.05	62.77	0.01
SQU-US	2026-06-24 06:00:00	10.74	22.25	463.92	7.13	11.06	63.47	0.01
SQU-US	2026-06-24 06:15:00	10.69	22.67	463.21	7.15	11.06	66.67	0.01
SQU-US	2026-06-24 06:30:00	10.71	22.30	461.86	7.15	11.07	65.93	0.01
SQU-US	2026-06-24 06:45:00	10.71	22.11	462.34	7.12	11.08	66.30	0.01
SQU-US	2026-06-24 07:00:00	10.71	21.84	459.94	7.13	11.10	66.98	0.01
SQU-US	2026-06-24 07:15:00	10.69	22.07	457.26	7.15	11.10	64.60	0.01
SQU-US	2026-06-24 07:30:00	10.68	22.37	455.38	7.16	11.11	65.37	0.01
SQU-US	2026-06-24 07:45:00	10.68	22.19	455.45	7.14	11.13	66.23	0.01
SQU-US	2026-06-24 08:00:00	10.74	21.60	453.06	7.12	11.12	67.04	0.01
SQU-US	2026-06-24 08:15:00	10.72	22.31	452.70	7.13	11.15	74.00	0.01
SQU-US	2026-06-24 08:30:00	10.73	22.49	450.63	7.13	11.14	75.03	0.01
SQU-US	2026-06-24 08:45:00	10.71	22.74	447.60	7.15	11.17	77.04	0.01
SQU-US	2026-06-24 09:00:00	10.77	22.20	446.31	7.13	11.19	72.73	0.01
SQU-US	2026-06-24 09:15:00	10.76	22.78	444.95	7.13	11.18	73.39	0.01
SQU-US	2026-06-24 09:30:00	10.78	22.39	443.65	7.12	11.20	68.28	0.01
SQU-US	2026-06-24 09:45:00	10.82	22.66	439.99	7.16	11.19	62.58	0.01
SQU-US	2026-06-24 10:00:00	10.84	22.81	437.94	7.15	11.21	66.95	0.01
SQU-US	2026-06-24 10:15:00	10.85	22.52	436.59	7.16	11.23	60.01	0.01
SQU-US	2026-06-24 10:30:00	10.89	22.53	435.58	7.15	11.22	64.55	0.01
SQU-US	2026-06-24 10:45:00	10.88	23.03	435.42	7.13	11.24	61.18	0.01
SQU-US	2026-06-24 11:00:00	10.97	22.37	430.80	7.17	11.23	65.89	0.01
SQU-US	2026-06-24 11:15:00	11.01	23.15	431.50	7.14	11.24	60.39	0.01
SQU-US	2026-06-24 11:30:00	11.11	22.87	429.22	7.15	11.24	61.79	0.01
SQU-US	2026-06-24 11:45:00	11.19	22.84	427.48	7.15	11.22	64.07	0.01
SQU-US	2026-06-24 12:00:00	11.27	22.80	425.67	7.15	11.24	57.73	0.01
SQU-US	2026-06-24 12:15:00	11.33	22.83	425.59	7.14	11.23	56.60	0.01
SQU-US	2026-06-24 12:30:00	11.40	22.96	423.63	7.17	11.22	57.18	0.01
SQU-US	2026-06-24 12:45:00	11.47	22.80	422.90	7.17	11.23	60.38	0.01
SQU-US	2026-06-24 13:00:00	11.48	23.10	422.69	7.16	11.21	61.80	0.01
SQU-US	2026-06-24 13:15:00	11.48	22.73	424.28	7.15	11.22	60.47	0.01
SQU-US	2026-06-24 13:30:00	11.52	22.68	422.95	7.17	11.21	58.57	0.01
SQU-US	2026-06-24 13:45:00	11.62	23.14	421.22	7.21	11.21	60.03	0.01
SQU-US	2026-06-24 14:00:00	11.71	23.09	419.23	7.22	11.20	59.55	0.01
SQU-US	2026-06-24 14:15:00	11.81	22.82	421.02	7.19	11.19	55.83	0.01
SQU-US	2026-06-24 14:30:00	11.90	22.87	418.76	7.23	11.20	55.79	0.01
SQU-US	2026-06-24 14:45:00	11.96	22.93	419.23	7.22	11.18	54.06	0.01
SQU-US	2026-06-24 15:00:00	12.04	22.60	417.90	7.23	11.18	54.86	0.01
SQU-US	2026-06-24 15:15:00	12.12	22.86	418.89	7.23	11.17	57.23	0.01
SQU-US	2026-06-24 15:30:00	12.19	22.99	418.96	7.24	11.16	55.78	0.01
SQU-US	2026-06-24 15:45:00	12.24	23.11	417.80	7.26	11.14	57.98	0.01
SQU-US	2026-06-24 16:00:00	12.33	23.13	419.81	7.22	11.12	57.47	0.01
SQU-US	2026-06-24 16:15:00	12.41	22.91	421.00	7.22	11.11	52.73	0.01
SQU-US	2026-06-24 16:30:00	12.49	23.31	419.23	7.26	11.08	54.48	0.01
SQU-US	2026-06-24 16:45:00	12.56	23.48	421.48	7.22	11.06	54.08	0.01
SQU-US	2026-06-24 17:00:00	12.58	23.10	421.75	7.22	11.02	57.73	0.01
SQU-US	2026-06-24 17:15:00	12.62	23.80	425.35	7.18	10.99	54.87	0.01
SQU-US	2026-06-24 17:30:00	12.68	23.83	424.95	7.20	10.98	57.01	0.01

Squamish River								
Station	Date/Time	Temperature (C)	Specific Conductivity (µS/cm)	ORP (V)	pH (pH units)	Dissolved Oxygen (mg/L)	Turbidity (NTU)	Salinity (PSU)
SQU-US	2026-06-24 17:45:00	12.75	23.88	427.53	7.17	10.94	53.67	0.01
SQU-US	2026-06-24 18:00:00	12.76	24.02	426.17	7.19	10.94	52.56	0.01
SQU-US	2026-06-24 18:15:00	12.78	23.91	427.24	7.20	10.91	54.69	0.01
SQU-US	2026-06-24 18:30:00	12.79	24.33	428.21	7.20	10.90	52.72	0.01
SQU-US	2026-06-24 18:45:00	12.81	24.31	429.48	7.19	10.88	51.84	0.01
SQU-US	2026-06-24 19:00:00	12.80	24.61	430.87	7.17	10.84	54.21	0.01
SQU-US	2026-06-24 19:15:00	12.78	24.65	432.00	7.18	10.83	56.96	0.01
SQU-US	2026-06-24 19:30:00	12.75	24.64	433.32	7.17	10.80	52.35	0.01
SQU-US	2026-06-24 19:45:00	12.73	25.06	434.00	7.19	10.79	52.64	0.01
SQU-US	2026-06-24 20:00:00	12.67	24.60	434.53	7.18	10.78	53.44	0.01
SQU-US	2026-06-24 20:15:00	12.62	24.69	435.87	7.20	10.76	53.81	0.01
SQU-US	2026-06-24 20:30:00	12.57	24.77	438.13	7.19	10.76	53.08	0.01
SQU-US	2026-06-24 20:45:00	12.53	24.81	439.01	7.19	10.74	55.86	0.01
SQU-US	2026-06-24 21:00:00	12.49	24.54	439.79	7.20	10.74	53.22	0.01
SQU-US	2026-06-24 21:15:00	12.45	24.61	441.90	7.19	10.73	53.16	0.01
SQU-US	2026-06-24 21:30:00	12.42	24.67	444.95	7.18	10.73	52.99	0.01
SQU-US	2026-06-24 21:45:00	12.39	23.96	444.97	7.21	10.73	53.62	0.01
SQU-US	2026-06-24 22:00:00	12.35	24.19	448.23	7.17	10.72	55.01	0.01
SQU-US	2026-06-24 22:15:00	12.31	24.33	447.86	7.21	10.71	51.85	0.01
SQU-US	2026-06-24 22:30:00	12.28	23.89	450.12	7.20	10.72	55.92	0.01
SQU-US	2026-06-24 22:45:00	12.23	24.27	451.11	7.20	10.71	52.35	0.01
SQU-US	2026-06-24 23:00:00	12.17	23.76	451.07	7.21	10.74	53.57	0.01
SQU-US	2026-06-24 23:15:00	12.11	23.92	453.12	7.20	10.73	55.14	0.01
SQU-US	2026-06-24 23:30:00	12.08	23.76	455.01	7.18	10.73	53.48	0.01
SQU-US	2026-06-24 23:45:00	12.02	23.76	456.86	7.16	10.74	55.01	0.01
SQU-US	2026-06-25 00:00:00	11.96	23.36	456.20	7.17	10.75	57.04	0.01
SQU-US	2026-06-25 00:15:00	11.90	23.61	457.46	7.18	10.75	60.18	0.01
SQU-US	2026-06-25 00:30:00	11.83	23.58	458.11	7.18	10.77	58.43	0.01
SQU-US	2026-06-25 00:45:00	11.78	23.30	459.43	7.18	10.78	58.80	0.01
SQU-US	2026-06-25 01:00:00	11.70	23.54	459.70	7.18	10.79	57.03	0.01
SQU-US	2026-06-25 01:15:00	11.65	23.19	460.48	7.18	10.80	62.62	0.01
SQU-US	2026-06-25 01:30:00	11.57	23.21	461.80	7.18	10.82	56.06	0.01
SQU-US	2026-06-25 01:45:00	11.49	23.26	461.76	7.20	10.83	56.73	0.01
SQU-US	2026-06-25 02:00:00	11.43	23.18	463.25	7.17	10.84	60.12	0.01
SQU-US	2026-06-25 02:15:00	11.37	23.09	464.24	7.18	10.84	57.74	0.01
SQU-US	2026-06-25 02:30:00	11.33	22.78	464.70	7.18	10.87	59.59	0.01
SQU-US	2026-06-25 02:45:00	11.25	23.03	466.03	7.18	10.88	65.97	0.01
SQU-US	2026-06-25 03:00:00	11.20	22.76	465.69	7.18	10.89	63.08	0.01
SQU-US	2026-06-25 03:15:00	11.12	23.20	468.56	7.15	10.90	64.46	0.01
SQU-US	2026-06-25 03:30:00	11.10	22.64	468.81	7.15	10.90	67.69	0.01
SQU-US	2026-06-25 03:45:00	11.04	22.58	468.72	7.16	10.91	60.18	0.01
SQU-US	2026-06-25 04:00:00	11.02	22.12	469.26	7.15	10.93	62.57	0.01
SQU-US	2026-06-25 04:15:00	10.97	22.33	471.10	7.13	10.93	63.06	0.01
SQU-US	2026-06-25 04:30:00	10.92	22.10	471.09	7.13	10.95	61.02	0.01
SQU-US	2026-06-25 04:45:00	10.91	21.65	471.53	7.13	10.95	63.53	0.01
SQU-US	2026-06-25 05:00:00	10.88	21.81	470.99	7.13	10.96	67.45	0.01
SQU-US	2026-06-25 05:15:00	10.88	21.55	471.55	7.13	10.96	64.52	0.01
SQU-US	2026-06-25 05:30:00	10.80	21.94	473.11	7.11	10.97	65.02	0.01
SQU-US	2026-06-25 05:45:00	10.80	21.70	470.66	7.14	10.98	65.63	0.01
SQU-US	2026-06-25 06:00:00	10.77	21.76	471.23	7.11	10.98	71.60	0.01
SQU-US	2026-06-25 06:15:00	10.76	21.44	469.32	7.14	11.00	65.63	0.01
SQU-US	2026-06-25 06:30:00	10.71	21.94	469.33	7.12	11.01	67.82	0.01
SQU-US	2026-06-25 06:45:00	10.73	21.66	469.39	7.10	11.01	68.01	0.01
SQU-US	2026-06-25 07:00:00	10.70	21.93	467.03	7.11	11.03	69.23	0.01
SQU-US	2026-06-25 07:15:00	10.73	21.35	465.19	7.11	11.04	69.76	0.01

Squamish River								
Station	Date/Time	Temperature (C)	Specific Conductivity (µS/cm)	ORP (V)	pH (pH units)	Dissolved Oxygen (mg/L)	Turbidity (NTU)	Salinity (PSU)
SQU-US	2026-06-25 07:30:00	10.73	21.73	465.54	7.08	11.05	64.79	0.01
SQU-US	2026-06-25 07:45:00	10.71	21.79	461.48	7.12	11.06	65.46	0.01
SQU-US	2026-06-25 08:00:00	10.71	21.43	458.33	7.13	11.08	64.87	0.01
SQU-US	2026-06-25 08:15:00	10.73	21.88	458.83	7.10	11.08	69.26	0.01
SQU-US	2026-06-25 08:30:00	10.71	22.19	457.02	7.11	11.11	67.26	0.01
SQU-US	2026-06-25 08:45:00	10.74	22.14	454.56	7.11	11.12	65.83	0.01
SQU-US	2026-06-25 09:00:00	10.76	21.66	452.40	7.10	11.12	70.00	0.01
SQU-US	2026-06-25 09:15:00	10.76	21.62	451.86	7.10	11.12	69.08	0.01
SQU-US	2026-06-25 09:30:00	10.74	22.07	448.59	7.14	11.14	64.74	0.01
SQU-US	2026-06-25 09:45:00	10.76	21.91	449.09	7.11	11.15	69.11	0.01
SQU-US	2026-06-25 10:00:00	10.79	22.12	447.31	7.11	11.14	65.94	0.01
SQU-US	2026-06-25 10:15:00	10.74	22.29	447.36	7.11	11.16	65.92	0.01
SQU-US	2026-06-25 10:30:00	10.76	21.89	446.08	7.11	11.18	67.58	0.01
SQU-US	2026-06-25 10:45:00	10.76	22.28	445.63	7.10	11.18	64.51	0.01
SQU-US	2026-06-25 11:00:00	10.79	22.06	442.47	7.12	11.20	67.12	0.01
SQU-US	2026-06-25 11:15:00	10.81	22.33	441.35	7.13	11.19	64.66	0.01
SQU-US	2026-06-25 11:30:00	10.86	22.29	440.44	7.13	11.21	62.21	0.01
SQU-US	2026-06-25 11:45:00	10.87	22.20	439.81	7.12	11.19	61.00	0.01
SQU-US	2026-06-25 12:00:00	10.89	22.02	438.96	7.13	11.20	66.61	0.01
SQU-US	2026-06-25 12:15:00	10.89	22.35	438.46	7.15	11.20	66.54	0.01
SQU-US	2026-06-25 12:30:00	10.88	22.52	441.07	7.11	11.20	63.89	0.01
SQU-US	2026-06-25 12:45:00	10.86	22.39	442.75	7.10	11.19	66.32	0.01
SQU-US	2026-06-25 13:00:00	10.85	21.88	442.21	7.12	11.20	61.64	0.01
SQU-US	2026-06-25 13:15:00	10.87	22.15	442.64	7.12	11.20	62.93	0.01
SQU-US	2026-06-25 13:30:00	10.89	22.04	441.71	7.14	11.19	64.62	0.01
SQU-US	2026-06-25 13:45:00	10.88	22.27	442.61	7.13	11.20	66.02	0.01
SQU-US	2026-06-25 14:00:00	10.88	22.33	443.09	7.13	11.21	62.93	0.01
SQU-US	2026-06-25 14:15:00	10.89	22.35	442.87	7.16	11.21	67.10	0.01
SQU-US	2026-06-25 14:30:00	10.91	22.56	440.22	7.21	11.20	62.10	0.01
SQU-US	2026-06-25 14:45:00	10.95	22.47	440.31	7.21	11.20	57.87	0.01
SQU-US	2026-06-25 15:00:00	10.95	22.44	438.01	7.25	11.21	64.71	0.01
SQU-US	2026-06-25 15:15:00	10.95	22.29	439.47	7.25	11.19	63.07	0.01
SQU-US	2026-06-25 15:30:00	10.96	22.37	440.36	7.25	11.20	60.53	0.01
SQU-US	2026-06-25 15:45:00	10.99	22.59	441.60	7.23	11.20	64.51	0.01
SQU-US	2026-06-25 16:00:00	11.00	22.69	438.59	7.28	11.19	62.51	0.01
SQU-US	2026-06-25 16:15:00	11.00	22.46	440.17	7.27	11.19	56.10	0.01
SQU-US	2026-06-25 16:30:00	11.00	22.98	441.09	7.27	11.19	56.18	0.01
SQU-US	2026-06-25 16:45:00	11.01	22.99	441.86	7.27	11.19	63.34	0.01
SQU-US	2026-06-25 17:00:00	11.03	23.26	441.39	7.28	11.17	57.91	0.01
SQU-US	2026-06-25 17:15:00	11.06	22.99	442.79	7.27	11.18	62.31	0.01
SQU-US	2026-06-25 17:30:00	11.07	22.94	442.32	7.28	11.17	57.88	0.01
SQU-US	2026-06-25 17:45:00	11.05	22.73	443.66	7.27	11.17	57.04	0.01
SQU-US	2026-06-25 18:00:00	11.04	23.34	444.77	7.26	11.14	63.96	0.01
SQU-US	2026-06-25 18:15:00	11.03	23.29	446.77	7.26	11.12	64.72	0.01
SQU-US	2026-06-25 18:30:00	11.02	23.55	450.39	7.21	11.09	58.31	0.01
SQU-US	2026-06-25 18:45:00	11.01	23.62	449.63	7.24	11.08	59.79	0.01
SQU-US	2026-06-25 19:00:00	11.00	23.97	448.88	7.22	11.07	58.98	0.01
SQU-US	2026-06-25 19:15:00	11.00	24.35	449.41	7.20	11.04	56.92	0.01
SQU-US	2026-06-25 19:30:00	10.99	24.23	449.86	7.16	11.02	57.80	0.01
SQU-US	2026-06-25 19:45:00	10.99	24.83	449.44	7.16	10.99	56.66	0.01
SQU-US	2026-06-25 20:00:00	10.97	24.47	448.82	7.16	10.98	59.80	0.01
SQU-US	2026-06-25 20:15:00	10.96	24.59	449.21	7.15	10.97	59.52	0.01
SQU-US	2026-06-25 20:30:00	10.94	24.31	451.14	7.15	10.97	59.92	0.01
SQU-US	2026-06-25 20:45:00	10.93	24.64	454.16	7.12	10.97	57.91	0.01
SQU-US	2026-06-25 21:00:00	10.92	24.51	451.97	7.15	10.95	57.53	0.01

Squamish River								
Station	Date/Time	Temperature (C)	Specific Conductivity (µS/cm)	ORP (V)	pH (pH units)	Dissolved Oxygen (mg/L)	Turbidity (NTU)	Salinity (PSU)
SQU-US	2026-06-25 21:15:00	10.91	24.70	453.97	7.14	10.95	59.63	0.01
SQU-US	2026-06-25 21:30:00	10.88	25.17	454.09	7.15	10.95	58.03	0.01
SQU-US	2026-06-25 21:45:00	10.87	24.00	456.39	7.13	10.96	58.92	0.01
SQU-US	2026-06-25 22:00:00	10.85	24.68	455.04	7.16	10.96	57.37	0.01
SQU-US	2026-06-25 22:15:00	10.83	24.03	456.71	7.16	10.96	56.01	0.01
SQU-US	2026-06-25 22:30:00	10.81	24.78	456.50	7.17	10.95	52.81	0.01
SQU-US	2026-06-25 22:45:00	10.78	24.21	459.40	7.14	10.96	55.43	0.01
SQU-US	2026-06-25 23:00:00	10.76	24.67	459.18	7.16	10.96	55.76	0.01
SQU-US	2026-06-25 23:15:00	10.73	24.73	459.20	7.17	10.96	52.95	0.01
SQU-US	2026-06-25 23:30:00	10.71	24.85	461.13	7.17	10.96	53.30	0.01
SQU-US	2026-06-25 23:45:00	10.69	24.36	462.14	7.18	10.97	53.74	0.01
SQU-US	2026-06-26 00:00:00	10.67	24.58	462.50	7.21	10.99	54.69	0.01
SQU-US	2026-06-26 00:15:00	10.64	24.30	461.49	7.25	10.99	54.78	0.01
SQU-US	2026-06-26 00:30:00	10.62	24.10	465.19	7.20	11.00	53.46	0.01
SQU-US	2026-06-26 00:45:00	10.59	24.23	464.62	7.24	11.00	52.74	0.01
SQU-US	2026-06-26 01:00:00	10.57	24.19	465.43	7.24	11.01	51.65	0.01
SQU-US	2026-06-26 01:15:00	10.53	24.48	465.88	7.22	11.01	53.82	0.01
SQU-US	2026-06-26 01:30:00	10.50	24.52	465.04	7.24	11.01	54.48	0.01
SQU-US	2026-06-26 01:45:00	10.48	24.15	463.53	7.22	11.03	50.77	0.01
SQU-US	2026-06-26 02:00:00	10.44	24.20	463.21	7.20	11.04	52.74	0.01
SQU-US	2026-06-26 02:15:00	10.43	24.19	461.83	7.21	11.02	55.80	0.01
SQU-US	2026-06-26 02:30:00	10.39	24.05	460.75	7.24	11.04	51.96	0.01
SQU-US	2026-06-26 02:45:00	10.37	24.07	463.37	7.22	11.04	53.67	0.01
SQU-US	2026-06-26 03:00:00	10.34	24.00	463.81	7.23	11.03	51.22	0.01
SQU-US	2026-06-26 03:15:00	10.31	24.44	466.59	7.19	11.04	51.33	0.01
SQU-US	2026-06-26 03:30:00	10.29	24.55	467.39	7.19	11.04	53.33	0.01
SQU-US	2026-06-26 03:45:00	10.26	24.45	468.28	7.19	11.03	52.89	0.01
SQU-US	2026-06-26 04:00:00	10.25	24.56	469.76	7.16	11.02	53.76	0.01
SQU-US	2026-06-26 04:15:00	10.22	25.16	470.73	7.14	10.99	55.54	0.01
SQU-US	2026-06-26 04:30:00	10.20	25.21	470.63	7.12	10.99	54.68	0.01
SQU-US	2026-06-26 04:45:00	10.18	25.32	470.17	7.11	10.98	54.04	0.01
SQU-US	2026-06-26 05:00:00	10.16	25.56	468.43	7.10	10.98	52.63	0.01
SQU-US	2026-06-26 05:15:00	10.16	24.99	463.25	7.10	10.98	52.49	0.01
SQU-US	2026-06-26 05:30:00	10.12	25.51	462.86	7.10	10.99	50.22	0.01
SQU-US	2026-06-26 05:45:00	10.11	24.98	462.73	7.10	11.01	51.76	0.01
SQU-US	2026-06-26 06:00:00	10.10	24.86	462.38	7.10	11.01	49.54	0.01
SQU-US	2026-06-26 06:15:00	10.08	24.85	460.68	7.09	11.03	50.66	0.01
SQU-US	2026-06-26 06:30:00	10.07	24.70	459.11	7.13	11.04	51.37	0.01
SQU-US	2026-06-26 06:45:00	10.06	24.72	460.87	7.12	11.04	51.13	0.01
SQU-US	2026-06-26 07:00:00	10.06	24.60	460.75	7.13	11.05	51.34	0.01
SQU-US	2026-06-26 07:15:00	10.06	24.52	452.86	7.12	11.07	50.15	0.01
SQU-US	2026-06-26 07:30:00	10.05	24.58	453.53	7.14	11.09	52.91	0.01
SQU-US	2026-06-26 07:45:00	10.04	24.68	454.20	7.16	11.10	52.09	0.01
SQU-US	2026-06-26 08:00:00	10.04	24.40	455.87	7.15	11.12	54.46	0.01
SQU-US	2026-06-26 08:15:00	10.06	23.95	453.54	7.15	11.14	52.49	0.01
SQU-US	2026-06-26 08:30:00	10.06	24.44	453.30	7.16	11.14	50.46	0.01
SQU-US	2026-06-26 08:45:00	10.07	24.53	454.61	7.16	11.14	52.35	0.01
SQU-US	2026-06-26 09:00:00	10.06	24.71	455.73	7.16	11.17	56.02	0.01
SQU-US	2026-06-26 09:15:00	10.07	24.81	445.23	7.19	11.16	50.82	0.01
SQU-US	2026-06-26 09:30:00	10.06	24.83	448.30	7.16	11.17	52.17	0.01
SQU-US	2026-06-26 09:45:00	10.07	25.07	450.49	7.15	11.17	54.17	0.01
SQU-US	2026-06-26 10:00:00	10.08	25.10	451.25	7.14	11.17	55.20	0.01
SQU-US	2026-06-26 10:15:00	10.10	24.58	444.71	7.18	11.19	51.57	0.01
SQU-US	2026-06-26 10:30:00	10.11	24.93	445.01	7.19	11.19	51.29	0.01
SQU-US	2026-06-26 10:45:00	10.13	25.03	445.75	7.18	11.20	53.93	0.01


Squamish River								
Station	Date/Time	Temperature (C)	Specific Conductivity (µS/cm)	ORP (V)	pH (pH units)	Dissolved Oxygen (mg/L)	Turbidity (NTU)	Salinity (PSU)
SQU-US	2026-06-26 11:00:00	10.13	27.05	445.29	7.19	11.22	94.89	0.01
SQU-US	2026-06-26 11:15:00	10.13	27.08	443.26	7.18	11.22	50.67	0.01
SQU-US	2026-06-26 11:30:00	10.15	27.22	444.65	7.17	11.21	48.81	0.01
SQU-US	2026-06-26 11:45:00	10.14	27.31	446.27	7.16	11.22	53.56	0.01
SQU-US	2026-06-26 12:00:00	10.15	26.58	446.73	7.18	11.23	56.85	0.01
SQU-US	2026-06-26 12:15:00	10.17	26.57	446.34	7.17	11.23	53.73	0.01
SQU-US	2026-06-26 12:30:00	10.20	26.59	446.83	7.16	11.23	50.19	0.01
SQU-US	2026-06-26 12:45:00	10.21	27.11	444.66	7.19	11.23	54.49	0.01
SQU-US	2026-06-26 13:00:00	10.20	27.72	444.87	7.20	11.24	53.37	0.01
SQU-US	2026-06-26 13:15:00	10.20	27.25	445.49	7.19	11.25	49.74	0.01
SQU-US	2026-06-26 13:30:00	10.20	27.28	445.55	7.20	11.25	54.89	0.01
SQU-US	2026-06-26 13:45:00	10.20	27.49	446.49	7.19	11.25	50.65	0.01
SQU-US	2026-06-26 14:00:00	10.20	26.07	449.79	7.18	11.26	55.27	0.01
SQU-US	2026-06-26 14:15:00	10.21	26.67	446.89	7.19	11.26	49.98	0.01
SQU-US	2026-06-26 14:30:00	10.23	26.59	445.77	7.21	11.27	47.13	0.01
SQU-US	2026-06-26 14:45:00	10.24	26.62	444.20	7.22	11.27	50.91	0.01
SQU-US	2026-06-26 15:00:00	10.25	27.36	443.96	7.23	11.28	54.18	0.01
SQU-US	2026-06-26 15:15:00	10.25	27.11	442.72	7.22	11.29	50.41	0.01
SQU-US	2026-06-26 15:30:00	10.25	27.14	441.69	7.25	11.29	52.40	0.01
SQU-US	2026-06-26 15:45:00	10.25	26.51	442.20	7.25	11.30	55.31	0.01
SQU-US	2026-06-26 16:00:00	10.24	27.04	443.14	7.25	11.30	206.67	0.01
SQU-US	2026-06-26 16:15:00	10.24	27.70	442.82	7.28	11.29	238.92	0.01
SQU-US	2026-06-26 16:30:00	10.24	27.21	443.85	7.28	11.30	259.94	0.01
SQU-US	2026-06-26 16:45:00	10.25	27.81	444.08	7.29	11.28	278.38	0.01
SQU-US	2026-06-26 17:00:00	10.26	27.99	445.68	7.28	11.30	51.41	0.01
SQU-US	2026-06-26 17:15:00	10.27	28.24	445.77	7.27	11.30	52.26	0.01
SQU-US	2026-06-26 17:30:00	10.28	28.16	446.41	7.26	11.30	53.70	0.01
SQU-US	2026-06-26 17:45:00	10.28	28.42	446.72	7.27	11.30	53.64	0.01
SQU-US	2026-06-26 18:00:00	10.28	28.08	445.47	7.31	11.28	53.60	0.01
SQU-US	2026-06-26 18:15:00	10.27	28.27	448.66	7.29	11.27	52.30	0.01
SQU-US	2026-06-26 18:30:00	10.27	28.72	449.54	7.30	11.28	49.78	0.01
SQU-US	2026-06-26 18:45:00	10.28	28.80	451.81	7.28	11.28	49.87	0.01
SQU-US	2026-06-26 19:00:00	10.29	29.27	452.38	7.27	11.28	51.87	0.01
SQU-US	2026-06-26 19:15:00	10.28	29.04	453.09	7.25	11.27	51.87	0.01
SQU-US	2026-06-26 19:30:00	10.28	28.84	454.46	7.24	11.26	49.37	0.01
SQU-US	2026-06-26 19:45:00	10.27	29.26	453.40	7.27	11.25	50.67	0.01
SQU-US	2026-06-26 20:00:00	10.25	29.36	455.04	7.30	11.25	259.70	0.01
SQU-US	2026-06-26 20:15:00	10.24	29.37	455.12	7.26	11.24	274.15	0.01
SQU-US	2026-06-26 20:30:00	10.22	30.07	454.42	7.29	11.23	295.12	0.01
SQU-US	2026-06-26 20:45:00	10.20	29.64	457.18	7.25	11.22	305.39	0.01
SQU-US	2026-06-26 21:00:00	10.19	29.33	459.46	7.24	11.22	68.14	0.01
SQU-US	2026-06-26 21:15:00	10.16	29.91	460.01	7.23	11.21	68.66	0.01
SQU-US	2026-06-26 21:30:00	10.15	29.28	460.70	7.23	11.21	70.57	0.01
SQU-US	2026-06-26 21:45:00	10.12	29.34	461.72	7.23	11.19	75.84	0.01
SQU-US	2026-06-26 22:00:00	10.10	29.47	462.17	7.24	11.19	250.35	0.01
SQU-US	2026-06-26 22:15:00	10.07	28.68	462.26	7.23	11.19	282.99	0.01
SQU-US	2026-06-26 22:30:00	10.06	29.04	462.92	7.22	11.19	286.44	0.01
SQU-US	2026-06-26 22:45:00	10.04	27.61	463.13	7.23	11.19	302.59	0.01
SQU-US	2026-06-26 23:00:00	10.01	28.42	465.44	7.20	11.20	74.11	0.01
SQU-US	2026-06-26 23:15:00	9.99	27.89	463.79	7.21	11.21	68.63	0.01
SQU-US	2026-06-26 23:30:00	9.99	27.31	463.98	7.22	11.21	73.36	0.01
SQU-US	2026-06-26 23:45:00	9.96	27.60	464.11	7.23	11.22	70.79	0.01
SQU-US	2026-06-27 00:00:00	9.94	27.21	466.14	7.23	11.22	305.52	0.01
SQU-US	2026-06-27 00:15:00	9.92	26.83	466.69	7.22	11.23	330.12	0.01
SQU-US	2026-06-27 00:30:00	9.88	27.27	467.15	7.23	11.22	360.90	0.01

Squamish River								
Station	Date/Time	Temperature (C)	Specific Conductivity (µS/cm)	ORP (V)	pH (pH units)	Dissolved Oxygen (mg/L)	Turbidity (NTU)	Salinity (PSU)
SQU-US	2026-06-27 00:45:00	9.86	27.28	467.42	7.24	11.24	412.38	0.01
SQU-US	2026-06-27 01:00:00	9.84	26.97	471.84	7.20	11.25	74.06	0.01
SQU-US	2026-06-27 01:15:00	9.80	26.86	471.55	7.20	11.26	69.03	0.01
SQU-US	2026-06-27 01:30:00	9.75	27.08	472.75	7.19	11.26	73.44	0.01
SQU-US	2026-06-27 01:45:00	9.72	26.52	472.01	7.22	11.27	70.07	0.01
SQU-US	2026-06-27 02:00:00	9.67	26.79	475.87	7.22	11.28	360.78	0.01
SQU-US	2026-06-27 02:15:00	9.64	25.95	471.82	7.25	11.30	392.90	0.01
SQU-US	2026-06-27 02:30:00	9.59	26.68	473.62	7.24	11.30	400.32	0.01
SQU-US	2026-06-27 02:45:00	9.54	26.12	475.35	7.21	11.31	466.67	0.01
SQU-US	2026-06-27 03:00:00	9.53	26.21	478.74	7.17	11.31	71.58	0.01
SQU-US	2026-06-27 03:15:00	9.48	25.73	475.22	7.23	11.34	72.30	0.01
SQU-US	2026-06-27 03:30:00	9.44	25.86	476.74	7.21	11.34	70.85	0.01
SQU-US	2026-06-27 03:45:00	9.41	25.68	476.97	7.20	11.34	75.47	0.01
SQU-US	2026-06-27 04:00:00	9.36	25.30	480.23	7.20	11.36	81.09	0.01
SQU-US	2026-06-27 04:15:00	9.35	24.78	478.27	7.20	11.37	77.77	0.01
SQU-US	2026-06-27 04:30:00	9.32	25.15	479.54	7.19	11.37	75.29	0.01
SQU-US	2026-06-27 04:45:00	9.29	24.92	479.36	7.20	11.38	77.99	0.01
SQU-US	2026-06-27 05:00:00	9.25	25.25	481.08	7.20	11.39	73.47	0.01
SQU-US	2026-06-27 05:15:00	9.22	25.36	480.86	7.17	11.39	78.60	0.01
SQU-US	2026-06-27 05:30:00	9.19	25.20	480.06	7.18	11.42	72.91	0.01
SQU-US	2026-06-27 05:45:00	9.17	25.05	479.55	7.18	11.42	74.10	0.01
SQU-US	2026-06-27 06:00:00	9.14	24.74	478.22	7.19	11.42	363.22	0.01
SQU-US	2026-06-27 06:15:00	9.14	24.90	477.30	7.18	11.42	456.42	0.01
SQU-US	2026-06-27 06:30:00	9.12	24.82	475.42	7.20	11.43	487.01	0.01
SQU-US	2026-06-27 06:45:00	9.10	24.26	473.73	7.20	11.45	496.25	0.01
SQU-US	2026-06-27 07:00:00	9.09	24.87	475.09	7.14	11.46	77.20	0.01
SQU-US	2026-06-27 07:15:00	9.06	24.89	471.84	7.14	11.47	76.12	0.01
SQU-US	2026-06-27 07:30:00	9.07	25.07	468.60	7.14	11.48	75.64	0.01
SQU-US	2026-06-27 07:45:00	9.09	24.92	465.03	7.14	11.48	77.32	0.01
SQU-US	2026-06-27 08:00:00	9.11	24.20	463.98	7.15	11.48	82.38	0.01
SQU-US	2026-06-27 08:15:00	9.16	24.06	460.10	7.15	11.50	77.15	0.01
SQU-US	2026-06-27 08:30:00	9.24	23.24	457.99	7.15	11.49	79.68	0.01
SQU-US	2026-06-27 08:45:00	9.27	23.59	455.61	7.16	11.50	81.52	0.01
SQU-US	2026-06-27 09:00:00	9.26	25.15	454.53	7.14	11.53	84.12	0.01
SQU-US	2026-06-27 09:15:00	9.34	25.32	449.27	7.14	11.54	80.97	0.01
SQU-US	2026-06-27 09:30:00	9.40	25.29	445.17	7.16	11.54	83.20	0.01
SQU-US	2026-06-27 09:45:00	9.46	25.05	442.15	7.16	11.54	82.79	0.01
SQU-US	2026-06-27 10:00:00	9.54	24.77	442.07	7.16	11.54	84.08	0.01
SQU-US	2026-06-27 10:15:00	9.61	24.62	439.99	7.16	11.54	79.36	0.01
SQU-US	2026-06-27 10:30:00	9.67	24.46	438.21	7.16	11.54	82.06	0.01
SQU-US	2026-06-27 10:45:00	9.73	24.54	436.58	7.15	11.53	79.62	0.01
SQU-US	2026-06-27 11:00:00	9.78	25.25	437.40	7.15	11.54	75.49	0.01
SQU-US	2026-06-27 11:15:00	9.81	25.54	436.28	7.15	11.53	70.26	0.01
SQU-US	2026-06-27 11:30:00	9.86	25.80	435.91	7.14	11.53	76.76	0.01
SQU-US	2026-06-27 11:45:00	9.95	25.11	433.61	7.16	11.54	75.44	0.01
SQU-US	2026-06-27 12:00:00	10.01	24.77	433.59	7.16	11.53	79.53	0.01
SQU-US	2026-06-27 12:15:00	10.12	24.94	431.49	7.17	11.52	74.66	0.01
SQU-US	2026-06-27 12:30:00	10.21	24.69	432.07	7.15	11.51	72.90	0.01
SQU-US	2026-06-27 12:45:00	10.29	24.79	431.44	7.16	11.51	74.82	0.01
SQU-US	2026-06-27 13:00:00	10.37	25.27	431.66	7.15	11.50	75.11	0.01
SQU-US	2026-06-27 13:15:00	10.46	26.00	428.74	7.16	11.48	72.66	0.01
SQU-US	2026-06-27 13:30:00	10.51	25.73	427.92	7.16	11.47	70.46	0.01
SQU-US	2026-06-27 13:45:00	10.54	25.37	427.65	7.16	11.47	74.05	0.01
SQU-US	2026-06-27 14:00:00	10.59	25.07	425.97	7.17	11.44	74.37	0.01
SQU-US	2026-06-27 14:15:00	10.64	25.29	428.14	7.17	11.44	69.47	0.01

Squamish River								
Station	Date/Time	Temperature (C)	Specific Conductivity (µS/cm)	ORP (V)	pH (pH units)	Dissolved Oxygen (mg/L)	Turbidity (NTU)	Salinity (PSU)
SQU-US	2026-06-27 14:30:00	10.71	24.81	429.51	7.16	11.43	69.04	0.01
SQU-US	2026-06-27 14:45:00	10.77	25.65	429.11	7.18	11.41	68.30	0.01
SQU-US	2026-06-27 15:00:00	10.76	26.17	431.06	7.16	11.40	69.92	0.01
SQU-US	2026-06-27 15:15:00	10.79	25.71	431.16	7.16	11.39	66.16	0.01
SQU-US	2026-06-27 15:30:00	10.81	25.53	431.00	7.18	11.38	66.21	0.01
SQU-US	2026-06-27 15:45:00	10.87	25.76	431.60	7.17	11.38	65.55	0.01
SQU-US	2026-06-27 16:00:00	11.00	25.18	431.24	7.22	11.36	73.08	0.01
SQU-US	2026-06-27 16:15:00	11.07	25.21	429.67	7.24	11.35	65.96	0.01
SQU-US	2026-06-27 16:30:00	11.10	25.34	429.24	7.24	11.35	70.69	0.01
SQU-US	2026-06-27 16:45:00	11.16	25.22	428.54	7.25	11.35	67.38	0.01
SQU-US	2026-06-27 17:00:00	11.18	25.60	430.54	7.25	11.33	64.50	0.01
SQU-US	2026-06-27 17:15:00	11.25	26.15	428.25	7.25	11.31	67.16	0.01
SQU-US	2026-06-27 17:30:00	11.29	25.93	428.88	7.24	11.31	67.57	0.01
SQU-US	2026-06-27 17:45:00	11.37	26.03	428.10	7.26	11.28	69.74	0.01
SQU-US	2026-06-27 18:00:00	11.41	26.12	431.80	7.25	11.25	102.18	0.01
SQU-US	2026-06-27 18:15:00	11.40	25.72	430.27	7.28	11.25	115.77	0.01
SQU-US	2026-06-27 18:30:00	11.36	25.78	433.18	7.27	11.24	123.37	0.01
SQU-US	2026-06-27 18:45:00	11.35	25.93	435.87	7.27	11.22	130.31	0.01
SQU-US	2026-06-27 19:00:00	11.36	26.83	439.22	7.24	11.19	69.13	0.01
SQU-US	2026-06-27 19:15:00	11.34	26.66	442.01	7.24	11.18	62.06	0.01
SQU-US	2026-06-27 19:30:00	11.34	27.33	444.87	7.24	11.17	59.15	0.01
SQU-US	2026-06-27 19:45:00	11.31	27.14	446.65	7.25	11.14	59.46	0.01
SQU-US	2026-06-27 20:00:00	11.29	27.77	451.58	7.24	11.14	139.21	0.01
SQU-US	2026-06-27 20:15:00	11.25	27.35	450.13	7.25	11.12	145.21	0.01
SQU-US	2026-06-27 20:30:00	11.20	27.43	452.17	7.25	11.10	161.74	0.01
SQU-US	2026-06-27 20:45:00	11.16	27.62	454.88	7.23	11.08	171.72	0.01
SQU-US	2026-06-27 21:00:00	11.14	28.39	458.96	7.19	11.07	67.96	0.01
SQU-US	2026-06-27 21:15:00	11.10	28.03	459.37	7.17	11.04	69.26	0.01
SQU-US	2026-06-27 21:30:00	11.07	28.34	461.28	7.15	11.01	71.70	0.01
SQU-US	2026-06-27 21:45:00	11.05	28.48	461.95	7.15	11.00	66.48	0.01
SQU-US	2026-06-27 22:00:00	11.04	27.72	464.26	7.12	10.97	63.21	0.01
SQU-US	2026-06-27 22:15:00	11.02	27.26	464.26	7.10	10.97	59.64	0.01
SQU-US	2026-06-27 22:30:00	10.99	27.56	464.33	7.10	10.95	58.43	0.01
SQU-US	2026-06-27 22:45:00	10.96	27.88	465.03	7.09	10.94	57.64	0.01
SQU-US	2026-06-27 23:00:00	10.94	28.62	464.96	7.08	10.94	59.32	0.01
SQU-US	2026-06-27 23:15:00	10.91	28.30	465.43	7.08	10.94	54.04	0.01
SQU-US	2026-06-27 23:30:00	10.88	28.22	465.67	7.09	10.95	53.58	0.01
SQU-US	2026-06-27 23:45:00	10.85	28.11	465.87	7.10	10.95	52.99	0.01
SQU-US	2026-06-28 00:00:00	10.82	27.80	465.79	7.12	10.96	58.30	0.01
SQU-US	2026-06-28 00:15:00	10.79	27.53	465.37	7.14	10.97	55.85	0.01
SQU-US	2026-06-28 00:30:00	10.76	27.16	466.90	7.14	10.99	52.16	0.01
SQU-US	2026-06-28 00:45:00	10.72	27.19	468.48	7.13	10.99	57.13	0.01
SQU-US	2026-06-28 01:00:00	10.69	27.68	469.89	7.13	10.99	55.51	0.01
SQU-US	2026-06-28 01:15:00	10.65	27.95	470.34	7.13	11.00	57.16	0.01
SQU-US	2026-06-28 01:30:00	10.62	26.98	470.71	7.14	11.01	58.35	0.01
SQU-US	2026-06-28 01:45:00	10.58	26.88	471.72	7.14	11.03	57.28	0.01
SQU-US	2026-06-28 02:00:00	10.54	26.53	472.56	7.16	11.02	63.01	0.01
SQU-US	2026-06-28 02:15:00	10.49	26.58	472.76	7.18	11.04	58.49	0.01
SQU-US	2026-06-28 02:30:00	10.44	26.89	473.62	7.19	11.05	52.76	0.01
SQU-US	2026-06-28 02:45:00	10.40	26.75	474.76	7.18	11.06	57.86	0.01
SQU-US	2026-06-28 03:00:00	10.36	27.43	476.54	7.16	11.07	56.53	0.01
SQU-US	2026-06-28 03:15:00	10.33	27.04	478.05	7.15	11.07	55.21	0.01
SQU-US	2026-06-28 03:30:00	10.30	27.04	478.49	7.16	11.08	52.12	0.01
SQU-US	2026-06-28 03:45:00	10.25	27.34	478.36	7.17	11.09	54.58	0.01
SQU-US	2026-06-28 04:00:00	10.23	26.71	480.95	7.16	11.08	55.90	0.01

Squamish River								
Station	Date/Time	Temperature (C)	Specific Conductivity (µS/cm)	ORP (V)	pH (pH units)	Dissolved Oxygen (mg/L)	Turbidity (NTU)	Salinity (PSU)
SQU-US	2026-06-28 04:15:00	10.19	26.49	479.59	7.16	11.09	53.59	0.01
SQU-US	2026-06-28 04:30:00	10.16	27.02	479.52	7.17	11.10	53.05	0.01
SQU-US	2026-06-28 04:45:00	10.14	26.65	480.80	7.14	11.08	53.57	0.01
SQU-US	2026-06-28 05:00:00	10.12	27.73	482.03	7.12	11.09	57.79	0.01
SQU-US	2026-06-28 05:15:00	10.09	28.24	482.11	7.10	11.09	52.43	0.01
SQU-US	2026-06-28 05:30:00	10.05	28.34	481.46	7.09	11.08	52.67	0.01
SQU-US	2026-06-28 05:45:00	10.04	27.75	480.85	7.08	11.08	54.39	0.01
SQU-US	2026-06-28 06:00:00	10.02	26.94	482.07	7.08	11.10	61.60	0.01
SQU-US	2026-06-28 06:15:00	10.00	27.51	475.15	7.13	11.10	52.14	0.01
SQU-US	2026-06-28 06:30:00	9.97	27.10	475.50	7.10	11.12	53.26	0.01
SQU-US	2026-06-28 06:45:00	9.96	27.09	473.15	7.13	11.14	49.30	0.01
SQU-US	2026-06-28 07:00:00	9.96	27.38	473.85	7.11	11.16	50.27	0.01
SQU-US	2026-06-28 07:15:00	9.94	27.73	471.66	7.11	11.17	47.90	0.01
SQU-US	2026-06-28 07:30:00	9.93	27.53	469.94	7.11	11.18	53.79	0.01
SQU-US	2026-06-28 07:45:00	9.94	27.37	467.56	7.14	11.20	52.00	0.01
SQU-US	2026-06-28 08:00:00	9.94	27.41	465.22	7.18	11.22	84.28	0.01
SQU-US	2026-06-28 08:15:00	9.98	27.22	465.67	7.16	11.23	92.82	0.01
SQU-US	2026-06-28 08:30:00	10.00	27.59	464.65	7.18	11.24	99.56	0.01
SQU-US	2026-06-28 08:45:00	10.02	27.30	464.84	7.16	11.25	133.59	0.01
SQU-US	2026-06-28 09:00:00	10.06	27.32	463.82	7.17	11.27	52.68	0.01
SQU-US	2026-06-28 09:15:00	10.10	27.17	463.43	7.15	11.29	45.85	0.01
SQU-US	2026-06-28 09:30:00	10.15	27.44	462.33	7.16	11.29	48.39	0.01
SQU-US	2026-06-28 09:45:00	10.19	27.62	461.04	7.17	11.30	50.28	0.01
SQU-US	2026-06-28 10:00:00	10.23	26.69	461.05	7.19	11.29	50.54	0.01
SQU-US	2026-06-28 10:15:00	10.25	26.74	459.81	7.18	11.30	50.42	0.01
SQU-US	2026-06-28 10:30:00	10.28	27.20	457.24	7.22	11.30	52.74	0.01
SQU-US	2026-06-28 10:45:00	10.32	26.94	457.03	7.21	11.31	55.06	0.01
SQU-US	2026-06-28 11:00:00	10.35	27.76	459.76	7.15	11.30	51.91	0.01
SQU-US	2026-06-28 11:15:00	10.40	27.66	458.26	7.16	11.31	51.89	0.01
SQU-US	2026-06-28 11:30:00	10.47	28.42	457.38	7.16	11.31	48.11	0.01
SQU-US	2026-06-28 11:45:00	10.53	28.40	455.54	7.18	11.31	50.19	0.01
SQU-US	2026-06-28 12:00:00	10.62	27.25	455.11	7.19	11.32	49.98	0.01
SQU-US	2026-06-28 12:15:00	10.74	27.62	452.68	7.18	11.30	45.79	0.01
SQU-US	2026-06-28 12:30:00	10.81	27.55	449.94	7.21	11.31	43.45	0.01
SQU-US	2026-06-28 12:45:00	10.83	27.78	449.80	7.20	11.30	45.70	0.01
SQU-US	2026-06-28 13:00:00	10.83	28.37	452.59	7.17	11.29	48.84	0.01
SQU-US	2026-06-28 13:15:00	10.85	28.23	452.88	7.17	11.29	45.52	0.01
SQU-US	2026-06-28 13:30:00	10.89	28.54	454.17	7.16	11.28	51.65	0.01
SQU-US	2026-06-28 13:45:00	10.93	28.29	454.03	7.17	11.27	48.51	0.01
SQU-US	2026-06-28 14:00:00	10.97	27.38	455.12	7.20	11.27	49.58	0.01
SQU-US	2026-06-28 14:15:00	11.00	27.28	452.30	7.20	11.26	47.59	0.01
SQU-US	2026-06-28 14:30:00	11.02	27.05	453.36	7.18	11.25	45.61	0.01
SQU-US	2026-06-28 14:45:00	11.04	27.46	451.72	7.22	11.24	45.84	0.01
SQU-US	2026-06-28 15:00:00	11.07	28.23	454.81	7.17	11.25	45.96	0.01
SQU-US	2026-06-28 15:15:00	11.11	28.17	454.73	7.19	11.24	46.50	0.01
SQU-US	2026-06-28 15:30:00	11.15	28.26	455.41	7.17	11.24	47.65	0.01
SQU-US	2026-06-28 15:45:00	11.19	28.05	454.13	7.19	11.24	48.19	0.01
SQU-US	2026-06-28 16:00:00	11.25	27.92	454.82	7.22	11.22	105.06	0.01
SQU-US	2026-06-28 16:15:00	11.30	28.09	450.26	7.25	11.22	123.97	0.01
SQU-US	2026-06-28 16:30:00	11.40	27.70	449.51	7.25	11.23	142.07	0.01
SQU-US	2026-06-28 16:45:00	11.49	27.49	447.18	7.26	11.24	151.72	0.01
SQU-US	2026-06-28 17:00:00	11.60	27.73	444.01	7.29	11.23	46.72	0.01
SQU-US	2026-06-28 17:15:00	11.70	27.65	444.45	7.28	11.22	40.88	0.01
SQU-US	2026-06-28 17:30:00	11.79	27.55	445.15	7.28	11.20	41.67	0.01
SQU-US	2026-06-28 17:45:00	11.84	27.50	445.40	7.29	11.19	44.00	0.01

Squamish River								
Station	Date/Time	Temperature (C)	Specific Conductivity (µS/cm)	ORP (V)	pH (pH units)	Dissolved Oxygen (mg/L)	Turbidity (NTU)	Salinity (PSU)
SQU-US	2026-06-28 18:00:00	11.87	26.88	448.21	7.29	11.16	46.31	0.01
SQU-US	2026-06-28 18:15:00	11.88	26.91	446.63	7.30	11.15	44.89	0.01
SQU-US	2026-06-28 18:30:00	11.89	27.00	448.55	7.28	11.15	42.62	0.01
SQU-US	2026-06-28 18:45:00	11.89	27.41	449.78	7.28	11.12	42.53	0.01
SQU-US	2026-06-28 19:00:00	11.87	27.85	451.20	7.29	11.11	51.71	0.01
SQU-US	2026-06-28 19:15:00	11.86	28.12	450.85	7.29	11.10	43.79	0.01
SQU-US	2026-06-28 19:30:00	11.85	28.20	450.98	7.31	11.08	43.43	0.01
SQU-US	2026-06-28 19:45:00	11.87	29.28	454.73	7.26	11.04	43.00	0.01
SQU-US	2026-06-28 20:00:00	11.85	30.03	455.44	7.27	11.03	137.07	0.01
SQU-US	2026-06-28 20:15:00	11.87	29.87	454.80	7.30	10.99	139.99	0.01
SQU-US	2026-06-28 20:30:00	11.87	29.73	458.15	7.26	10.98	149.91	0.01
SQU-US	2026-06-28 20:45:00	11.88	29.95	459.23	7.26	10.94	158.28	0.01
SQU-US	2026-06-28 21:00:00	11.87	29.68	461.59	7.25	10.92	50.06	0.01
SQU-US	2026-06-28 21:15:00	11.84	30.53	463.48	7.23	10.91	44.48	0.01
SQU-US	2026-06-28 21:30:00	11.83	30.65	464.84	7.21	10.88	45.72	0.01
SQU-US	2026-06-28 21:45:00	11.81	30.71	465.88	7.21	10.86	43.80	0.01
SQU-US	2026-06-28 22:00:00	11.78	30.30	468.35	7.18	10.84	50.28	0.01
SQU-US	2026-06-28 22:15:00	11.76	30.85	467.84	7.16	10.81	45.89	0.01
SQU-US	2026-06-28 22:30:00	11.75	30.89	468.95	7.12	10.78	50.36	0.01
SQU-US	2026-06-28 22:45:00	11.72	30.45	468.04	7.12	10.76	47.55	0.01
SQU-US	2026-06-28 23:00:00	11.70	31.19	466.84	7.13	10.76	49.11	0.01
SQU-US	2026-06-28 23:15:00	11.68	30.63	465.60	7.11	10.75	48.35	0.01
SQU-US	2026-06-28 23:30:00	11.65	30.53	463.90	7.13	10.76	47.31	0.01
SQU-US	2026-06-28 23:45:00	11.59	30.37	464.34	7.13	10.77	91.61	0.01



Guideline — BC FWAL - Acute Monitoring location — SQU-DS — SQU-US

 Eagle Mountain – Woodfibre Gas Pipeline Project Waste Discharge Permit PE-110163 Report	Reporting Week	June 22 to June 28, 2026
	Report #	118
	Appendix C	C-1

Appendix C: Woodfibre Site Point of Discharge from Water Treatment Plant Documentation

 Eagle Mountain – Woodfibre Gas Pipeline Project Waste Discharge Permit PE-110163 Report	Reporting Week	June 22 to June 28, 2026
	Report #	118
	Appendix C	C-2

Woodfibre Site Sample Analysis



Analyte	Unit	Permit PE-110163 Discharge Limit	BC Approved Water Quality Guideline - Freshwater Aquatic Life - Long Term Average	BC Approved Water Quality Guideline - Freshwater Aquatic Life - Short Term Max	BC Working Water Quality Guideline - Freshwater Aquatic Life - Long Term Average	BC Approved Water Quality Guideline - Marine Aquatic Life - Long Term Average	BC Approved Water Quality Guideline - Marine Aquatic Life - Short Term Max	BC Working Water Quality Guideline - Marine Aquatic Life - Long Term Average	WLNG EOP 2026-06-23 11:11:00
In situ Parameters									
Field pH	pH Units			6.5 - 9			7 - 8.7		7.4
Field Temperature	°C		18	19					14.8
General Parameters									
pH	pH Units								7.59
Alkalinity (Total as CaCO ₃)	mg/L								49
Alkalinity (PP as CaCO ₃)	mg/L								<1
Hardness (CaCO ₃)-Total	mg/L								60.8
Hardness (CaCO ₃)-Dissolved	mg/L								58.5
Sulphide-Total	mg/L								<0.0018
Sulphide (as H ₂ S)	mg/L				0.002				<0.002
Un-ionized Hydrogen Sulfide as H ₂ S-Total	mg/L								<0.0019
Un-ionized Hydrogen Sulfide as S-Total	mg/L								<0.0018
Anions and Nutrients									
Ammonia (N)-Total	mg/L		1.78	13.9		7.8	52		<0.015
Bicarbonate (HCO ₃)	mg/L								60
Carbonate (CO ₃)	mg/L								<1
Hydroxide (OH)	mg/L								<1
Nitrate (N)	mg/L		3	32.8		3.7			0.063
Nitrite (N)	mg/L		0.1	0.3					<0.005
Nitrate plus Nitrite (N)	mg/L								0.063
Nitrogen (N)-Total	mg/L								0.276
Phosphorus (P)-Total (4500-P)	mg/L								0.0039
Bromide (Br)	mg/L								<0.01
Chloride (Cl)	mg/L		150	600					9.5
Fluoride (F)	mg/L			1.13406			1.5		0.32
Sulphate (SO ₄)-Dissolved	mg/L		218						15
Total Metals									
Aluminum (Al)-Total	mg/L		0.0719743						0.268
Antimony (Sb)-Total	mg/L		0.074	0.25					0.000756
Arsenic (As)-Total	mg/L		0.005			0.0125			0.000891
Barium (Ba)-Total	mg/L				1				0.00543
Beryllium (Be)-Total	mg/L				0.00013			0.1	<0.00001
Bismuth (Bi)-Total	mg/L								<0.000005
Boron (B)-Total	mg/L		1.2			1.2			0.012
Cadmium (Cd)-Total	mg/L							0.00012	<0.000005
Calcium (Ca)-Total	mg/L								22.4
Cesium (Cs)-Total	mg/L								<0.00005
Chromium (Cr)-Total	mg/L								0.00016

¹ Guideline calculated using the in-situ measurements (pH (field),Temperature (field), Turbidity (field), Hardness (as CaCO₃) – total, Dissolved Organic Carbon (DOC), Total Alkalinity (CaCO₃), and Chloride).

² Guideline values presented represent the lower of the co-factor dependent guidelines for the upstream and downstream stations when they differ, but exceedance bolding is dependent on guidelines calculated using in situ co-factor considerations.

³ **Bold text** denotes value exceeding guidelines, except in cases where they are below a station-specific guideline that isn't displayed as per ¹ and ² above. Given that application of chronic BC water quality guidelines for protection of aquatic life in the receiving environment downstream of the discharge does not represent a regulatory requirement and instead data are intended to be assessed relative to monthly average concentrations, exceedances of these guidelines are highlighted for information purposes, but detailed interpretation of guideline exceedances are not provided given that an interpretation of monthly trends and consideration of background influences and discharge chemistry is required.

⁴ **Bold and shaded text** outlines a reportable exceedance given that it exceeds the applicable BC water quality guideline (i.e., the short-term acute freshwater aquatic life guideline), or discharge concentration limit, consistent with recommendations outlined in Hatfield (2024).



Analyte	Unit	Permit PE-110163 Discharge Limit	BC Approved Water Quality Guideline - Freshwater Aquatic Life - Long Term Average	BC Approved Water Quality Guideline - Freshwater Aquatic Life - Short Term Max	BC Working Water Quality Guideline - Freshwater Aquatic Life - Long Term Average	BC Approved Water Quality Guideline - Marine Aquatic Life - Long Term Average	BC Approved Water Quality Guideline - Marine Aquatic Life - Short Term Max	BC Working Water Quality Guideline - Marine Aquatic Life - Long Term Average	WLNG EOP 2026-06-23 11:11:00
Total Metals (cont'd.)									
Chromium (Cr III)-Total	mg/L				0.0089			0.056	<0.00099
Chromium (Cr VI)-Total	mg/L				0.0025			0.0015	<0.00099
Cobalt (Co)-Total	mg/L								0.0000468
Copper (Cu)-Total	mg/L					0.002	0.003		0.000179
Iron (Fe)-Total	mg/L		0.055	1					0.0573
Lead (Pb)-Total	mg/L					0.002	0.14		0.0000277
Lithium (Li)-Total	mg/L								0.00787
Magnesium (Mg)-Total	mg/L								1.18
Manganese (Mn)-Total	mg/L							0.1	0.0252
Mercury (Hg)-Total	mg/L		0.00002			0.0001			<0.0000019
Molybdenum (Mo)-Total	mg/L		7.6	46					0.0341
Nickel (Ni)-Total	mg/L							0.0083	0.000133
Phosphorus (P)-Total (ICPMS)	mg/L								0.0058
Potassium (K)-Total	mg/L								2.15
Rubidium (Rb)-Total	mg/L								0.00432
Selenium (Se)-Total	mg/L		0.002			0.002			0.000049
Silicon (Si)-Total	mg/L								7.05
Silver (Ag)-Total	mg/L		0.00012			0.0005	0.0037	0.0005	<0.000005
Sodium (Na)-Total	mg/L								7.35
Strontium (Sr)-Total	mg/L								0.0486
Sulphur (S)-Total	mg/L								5
Tellurium (Te)-Total	mg/L								<0.00002
Thallium (Tl)-Total	mg/L				0.00003				0.0000113
Thorium (Th)-Total	mg/L								<0.00005
Tin (Sn)-Total	mg/L								<0.0002
Titanium (Ti)-Total	mg/L								0.0023
Uranium (U)-Total	mg/L			0.0165	0.0075				0.000553
Vanadium (V)-Total	mg/L				0.06			0.005	0.00025
Zinc (Zn)-Total	mg/L					0.01	0.055		0.00197
Zirconium (Zr)-Total	mg/L								<0.0001
Dissolved Metals									
Aluminum (Al)-Dissolved	mg/L								0.0505
Antimony (Sb)-Dissolved	mg/L								0.00063
Arsenic (As)-Dissolved	mg/L								0.000796
Barium (Ba)-Dissolved	mg/L								0.00437
Beryllium (Be)-Dissolved	mg/L								<0.00001
Bismuth (Bi)-Dissolved	mg/L								<0.000005
Boron (B)-Dissolved	mg/L								0.011

¹ Guideline calculated using the in-situ measurements (pH (field),Temperature (field), Turbidity (field), Hardness (as CaCO₃) – total, Dissolved Organic Carbon (DOC), Total Alkalinity (CaCO₃), and Chloride).

² Guideline values presented represent the lower of the co-factor dependent guidelines for the upstream and downstream stations when they differ, but exceedance bolding is dependent on guidelines calculated using in situ co-factor considerations.

³ **Bold text** denotes value exceeding guidelines, except in cases where they are below a station-specific guideline that isn't displayed as per ¹ and ² above. Given that application of chronic BC water quality guidelines for protection of aquatic life in the receiving environment downstream of the discharge does not represent a regulatory requirement and instead data are intended to be assessed relative to monthly average concentrations, exceedances of these guidelines are highlighted for information purposes, but detailed interpretation of guideline exceedances are not provided given that an interpretation of monthly trends and consideration of background influences and discharge chemistry is required.

⁴ **Bold and shaded text** outlines a reportable exceedance given that it exceeds the applicable BC water quality guideline (i.e., the short-term acute freshwater aquatic life guideline), or discharge concentration limit, consistent with recommendations outlined in Hatfield (2024).



Analyte	Unit	Permit PE-110163 Discharge Limit	BC Approved Water Quality Guideline - Freshwater Aquatic Life - Long Term Average	BC Approved Water Quality Guideline - Freshwater Aquatic Life - Short Term Max	BC Working Water Quality Guideline - Freshwater Aquatic Life - Long Term Average	BC Approved Water Quality Guideline - Marine Aquatic Life - Long Term Average	BC Approved Water Quality Guideline - Marine Aquatic Life - Short Term Max	BC Working Water Quality Guideline - Marine Aquatic Life - Long Term Average	WLNG EOP 2026-06-23 11:11:00
Dissolved Metals (cont'd.)									
Cadmium (Cd)-Dissolved	mg/L		0.0001466	0.0003523					<0.000005
Calcium (Ca)-Dissolved	mg/L								21.6
Cesium (Cs)-Dissolved	mg/L								<0.00005
Chromium (Cr)-Dissolved	mg/L								0.00012
Cobalt (Co)-Dissolved	mg/L		0.0004149						0.0000317
Copper (Cu)-Dissolved	mg/L	0.00366							0.000085
Iron (Fe)-Dissolved	mg/L								<0.001
Lead (Pb)-Dissolved	mg/L		0.0016913						<0.000005
Lithium (Li)-Dissolved	mg/L								0.00766
Manganese (Mn)-Dissolved	mg/L		0.215	2.150201					0.023
Magnesium (Mg)-Dissolved	mg/L								1.09
Mercury (Hg)-Dissolved	mg/L								<0.0000019
Molybdenum (Mo)-Dissolved	mg/L								0.0322
Nickel (Ni)-Dissolved	mg/L		0.0012	0.0211					0.000106
Phosphorus (P)-Dissolved	mg/L								<0.002
Potassium (K)-Dissolved	mg/L								2.03
Rubidium (Rb)-Dissolved	mg/L								0.00389
Selenium (Se)-Dissolved	mg/L								0.000042
Silicon (Si)-Dissolved	mg/L								6.6
Silver (Ag)-Dissolved	mg/L								<0.000005
Sodium (Na)-Dissolved	mg/L								6.7
Strontium (Sr)-Dissolved	mg/L				1.25				0.0449
Sulphur (S)-Dissolved	mg/L								4.3
Tellurium (Te)-Dissolved	mg/L								<0.00002
Thallium (Tl)-Dissolved	mg/L								0.0000107
Thorium (Th)-Dissolved	mg/L								0.0000061
Tin (Sn)-Dissolved	mg/L								<0.0002
Titanium (Ti)-Dissolved	mg/L								<0.0005
Uranium (U)-Dissolved	mg/L								0.000475
Vanadium (V)-Dissolved	mg/L								<0.0002
Zinc (Zn)-Dissolved	mg/L		0.0055655	0.024773					0.00131
Zirconium (Zr)-Dissolved	mg/L								<0.0001
Inorganics									
Organic Carbon (C)-Total	mg/L								1.1
Organic Carbon (C)-Dissolved	mg/L								0.83
Solids-Total Dissolved	mg/L								100
Solids-Total Suspended	mg/L		6	26					3.6

¹ Guideline calculated using the in-situ measurements (pH (field), Temperature (field), Turbidity (field), Hardness (as CaCO₃) – total, Dissolved Organic Carbon (DOC), Total Alkalinity (CaCO₃), and Chloride).

² Guideline values presented represent the lower of the co-factor dependent guidelines for the upstream and downstream stations when they differ, but exceedance bolding is dependent on guidelines calculated using in situ co-factor considerations.

³ **Bold text** denotes value exceeding guidelines, except in cases where they are below a station-specific guideline that isn't displayed as per ¹ and ² above. Given that application of chronic BC water quality guidelines for protection of aquatic life in the receiving environment downstream of the discharge does not represent a regulatory requirement and instead data are intended to be assessed relative to monthly average concentrations, exceedances of these guidelines are highlighted for information purposes, but detailed interpretation of guideline exceedances are not provided given that an interpretation of monthly trends and consideration of background influences and discharge chemistry is required.

⁴ **Bold and shaded text** outlines a reportable exceedance given that it exceeds the applicable BC water quality guideline (i.e., the short-term acute freshwater aquatic life guideline), or discharge concentration limit, consistent with recommendations outlined in Hatfield (2024).

Analyte	Unit	Permit PE-110163 Discharge Limit	BC Approved Water Quality Guideline - Freshwater Aquatic Life - Long Term Average	BC Approved Water Quality Guideline - Freshwater Aquatic Life - Short Term Max	BC Working Water Quality Guideline - Freshwater Aquatic Life - Long Term Average	BC Approved Water Quality Guideline - Marine Aquatic Life - Long Term Average	BC Approved Water Quality Guideline - Marine Aquatic Life - Short Term Max	BC Working Water Quality Guideline - Marine Aquatic Life - Long Term Average	WLNG EOP 2026-06-23 11:11:00
Organics									
HEPH (C19-C32 less PAH)	mg/L								<0.2
LEPH (C10-C19 less PAH)	mg/L								<0.2
EPH (C10-C19)	mg/L								<0.2
EPH (C19-C32)	mg/L								<0.2
Ethylene Glycol	mg/L								<3
Diethylene Glycol	mg/L								<5
Triethylene Glycol	mg/L								<5
Propylene Glycol	mg/L								<5
Acenaphthene	mg/L		0.006			0.006			<0.00005
Acenaphthylene	mg/L								<0.00005
Acridine	mg/L		0.003						<0.00005
Anthracene	mg/L		0.004						<0.00001
Benzo(a)anthracene	mg/L		0.0001						<0.00001
Benzo(a)pyrene	mg/L		0.00001			0.00001			<0.000005
Benzo(b&j)fluoranthene	mg/L								<0.00003
Benzo(g,h,i)perylene	mg/L								<0.00005
Benzo(k)fluoranthene	mg/L								<0.00005
Chrysene	mg/L					0.0001			<0.00002
Dibenz(a,h)anthracene	mg/L								<0.000003
Fluoranthene	mg/L		0.004						<0.00002
Fluorene	mg/L		0.012			0.012			<0.00005
Indeno(1,2,3-cd)pyrene	mg/L								<0.00005
1-Methylnaphthalene	mg/L					0.001			<0.00005
2-Methylnaphthalene	mg/L					0.001			<0.0001
Naphthalene	mg/L		0.001	0.001		0.001			<0.0001
Phenanthrene	mg/L		0.0003						<0.00005
Pyrene	mg/L								<0.00002
Quinoline	mg/L								<0.00002
Low Molecular Weight PAH's	mg/L								<0.0001
High Molecular Weight PAH's	mg/L								<0.00005
Total PAH	mg/L								<0.0001
VH C6-C10	mg/L								<0.3
1,1,1,2-Tetrachloroethane	mg/L								<0.0005
1,1,1-Trichloroethane	mg/L								<0.0005
1,1,2,2-Tetrachloroethane	mg/L								<0.0005
1,1,2Trichloro-1,2,2Trifluoroethane	mg/L								<0.002
1,1,2-Trichloroethane	mg/L								<0.0005
1,1-Dichloroethane	mg/L								<0.0005

¹ Guideline calculated using the in-situ measurements (pH (field),Temperature (field), Turbidity (field), Hardness (as CaCO₃) – total, Dissolved Organic Carbon (DOC), Total Alkalinity (CaCO₃), and Chloride).

² Guideline values presented represent the lower of the co-factor dependent guidelines for the upstream and downstream stations when they differ, but exceedance bolding is dependent on guidelines calculated using in situ co-factor considerations.

³ **Bold text** denotes value exceeding guidelines, except in cases where they are below a station-specific guideline that isn't displayed as per ¹ and ² above. Given that application of chronic BC water quality guidelines for protection of aquatic life in the receiving environment downstream of the discharge does not represent a regulatory requirement and instead data are intended to be assessed relative to monthly average concentrations, exceedances of these guidelines are highlighted for information purposes, but detailed interpretation of guideline exceedances are not provided given that an interpretation of monthly trends and consideration of background influences and discharge chemistry is required.

⁴ **Bold and shaded text** outlines a reportable exceedance given that it exceeds the applicable BC water quality guideline (i.e., the short-term acute freshwater aquatic life guideline), or discharge concentration limit, consistent with recommendations outlined in Hatfield (2024).

Analyte	Unit	Permit PE-110163 Discharge Limit	BC Approved Water Quality Guideline - Freshwater Aquatic Life - Long Term Average	BC Approved Water Quality Guideline - Freshwater Aquatic Life - Short Term Max	BC Working Water Quality Guideline - Freshwater Aquatic Life - Long Term Average	BC Approved Water Quality Guideline - Marine Aquatic Life - Long Term Average	BC Approved Water Quality Guideline - Marine Aquatic Life - Short Term Max	BC Working Water Quality Guideline - Marine Aquatic Life - Long Term Average	WLNG EOP 2026-06-23 11:11:00
Organics (cont'd.)									
1,1-Dichloroethene	mg/L								<0.0005
1,2,3-trichlorobenzene	mg/L				0.008				<0.002
1,2,4-trichlorobenzene	mg/L				0.024			0.0054	<0.002
1,2-dibromoethane	mg/L								<0.0002
1,2-Dichlorobenzene	mg/L				0.0007			0.042	<0.0005
1,2-Dichloroethane	mg/L				0.1				<0.0005
1,2-Dichloropropane	mg/L								<0.0005
1,3,5-trimethylbenzene	mg/L								<0.002
1,3-Butadiene	mg/L								<0.0005
1,3-Dichlorobenzene	mg/L				0.15				<0.0005
1,3-dichloropropane	mg/L								<0.001
1,4-Dichlorobenzene	mg/L				0.026				<0.0005
Benzene	mg/L		0.04			0.11			<0.0004
Bromobenzene	mg/L								<0.002
Bromodichloromethane	mg/L								<0.001
Bromoform	mg/L								<0.001
Bromomethane	mg/L								<0.001
Carbon tetrachloride	mg/L								<0.0005
Chlorobenzene	mg/L				0.0013			0.025	<0.0005
Chloroethane	mg/L								<0.001
Chloroform	mg/L								<0.001
Chloromethane	mg/L								<0.001
cis-1,2-Dichloroethene	mg/L								<0.001
cis-1,3-Dichloropropene	mg/L								<0.001
Dibromochloromethane	mg/L								<0.001
Dichlorodifluoromethane	mg/L								<0.002
Dichloromethane	mg/L				0.0981				<0.002
Ethylbenzene	mg/L		0.2			0.25			<0.0004
Hexachlorobutadiene	mg/L								<0.0005
Isopropylbenzene	mg/L								<0.002
Methyl-tert-butylether (MTBE)	mg/L			3.4			0.44		<0.004
Styrene	mg/L				0.072				<0.0005
Tetrachloroethene	mg/L								<0.0005
Toluene	mg/L		0.0005						<0.0004
trans-1,2-dichloroethene	mg/L								<0.001
trans-1,3-dichloropropene	mg/L								<0.001
Trichloroethene	mg/L								<0.0005
Trichlorofluoromethane	mg/L								<0.004

¹ Guideline calculated using the in-situ measurements (pH (field),Temperature (field), Turbidity (field), Hardness (as CaCO₃) – total, Dissolved Organic Carbon (DOC), Total Alkalinity (CaCO₃), and Chloride).

² Guideline values presented represent the lower of the co-factor dependent guidelines for the upstream and downstream stations when they differ, but exceedance bolding is dependent on guidelines calculated using in situ co-factor considerations.

³ **Bold text** denotes value exceeding guidelines, except in cases where they are below a station-specific guideline that isn't displayed as per ¹ and ² above. Given that application of chronic BC water quality guidelines for protection of aquatic life in the receiving environment downstream of the discharge does not represent a regulatory requirement and instead data are intended to be assessed relative to monthly average concentrations, exceedances of these guidelines are highlighted for information purposes, but detailed interpretation of guideline exceedances are not provided given that an interpretation of monthly trends and consideration of background influences and discharge chemistry is required.

⁴ **Bold and shaded text** outlines a reportable exceedance given that it exceeds the applicable BC water quality guideline (i.e., the short-term acute freshwater aquatic life guideline), or discharge concentration limit, consistent with recommendations outlined in Hatfield (2024).

Analyte	Unit	Permit PE-110163 Discharge Limit	BC Approved Water Quality Guideline - Freshwater Aquatic Life - Long Term Average	BC Approved Water Quality Guideline - Freshwater Aquatic Life - Short Term Max	BC Working Water Quality Guideline - Freshwater Aquatic Life - Long Term Average	BC Approved Water Quality Guideline - Marine Aquatic Life - Long Term Average	BC Approved Water Quality Guideline - Marine Aquatic Life - Short Term Max	BC Working Water Quality Guideline - Marine Aquatic Life - Long Term Average	WLNG EOP 2026-06-23 11:11:00
Organics (cont'd.)									
Vinyl chloride	mg/L								<0.0005
VPH (VH6 to 10 - BTEX)	mg/L								<0.3
Xylenes (Total)	mg/L		0.03						<0.0004
m & p-Xylene	mg/L								<0.0004
o-Xylene	mg/L								<0.0004
Phenols	mg/L			0.05					<0.0015

¹ Guideline calculated using the in-situ measurements (pH (field), Temperature (field), Turbidity (field), Hardness (as CaCO₃) – total, Dissolved Organic Carbon (DOC), Total Alkalinity (CaCO₃), and Chloride).

² Guideline values presented represent the lower of the co-factor dependent guidelines for the upstream and downstream stations when they differ, but exceedance bolding is dependent on guidelines calculated using in situ co-factor considerations.

³ **Bold text** denotes value exceeding guidelines, except in cases where they are below a station-specific guideline that isn't displayed as per ¹ and ² above. Given that application of chronic BC water quality guidelines for protection of aquatic life in the receiving environment downstream of the discharge does not represent a regulatory requirement and instead data are intended to be assessed relative to monthly average concentrations, exceedances of these guidelines are highlighted for information purposes, but detailed interpretation of guideline exceedances are not provided given that an interpretation of monthly trends and consideration of background influences and discharge chemistry is required.

⁴ **Bold and shaded text** outlines a reportable exceedance given that it exceeds the applicable BC water quality guideline (i.e., the short-term acute freshwater aquatic life guideline), or discharge concentration limit, consistent with recommendations outlined in Hatfield (2024).

 Eagle Mountain – Woodfibre Gas Pipeline Project Waste Discharge Permit PE-110163 Report	Reporting Week	June 22 to June 28, 2026
	Report #	118
	Appendix C	C-3

Woodfibre Site WTP Discharge
Field Notes and Logs

		Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope	
Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Table of Contents:

1. Executive Summary and Field Notes
2. Daily Volume Summary
3. Portal Discharge Parameter Summary
4. CP2 Discharge Parameter Summary
5. In-situ Readings
6. WTP Calibration Log

Appendices:

Appendix A- Portal WTP Data Log

Appendix B- CP2 WTP Data Log

Appendix C- Photos

1. Executive Summary and Field Notes:

Parameters, including temperature, NTU, pH, DO, salinity, conductivity, and oxidation-reduction potential (ORP), were monitored throughout the discharge process.

On June 26th a value of 67 NTU was recorded at 16:45 on the CP2 WTP data log while the probe was being cleaned prior to calibration. Readings of 725 NTU and 0 uS/cm conductivity were recorded at 17:00 while the NTU and conductivity probes were being calibrated. The discharge water at the time was ~1 NTU.

A reading of 55.4 NTU was recorded on the Portal WTP (PWTP) data log on June 28th at 17:30 while the slip stream and probe were being cleaned. The discharge water at the time was ~2 NTU.

Temperature readings >19°C were recorded on the PWTP data logs on June 22nd and 24th due to the plant being idle and no water flowing through the slip stream or past the probe which resulted in the ambient temperature in the control room influencing the readings. Once the system discharged and water passed through the slip stream the discharge temperature was ~16°C. YSI readings were taken of the discharge:

- June 22/ 2026 @ 10:48: 14.5°C
- June 22/ 2026 @ 20:42: 15.7°C
- June 24/ 2026 @ 08:10: 13.9°C
- June 24/ 2026 @ 21:57: 15.6°C

		Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope	
Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Temperature readings >19°C were recorded on the CP2 WTP data log on June 23rd, 24th, 26th and 28th. These readings occurred when water was stagnant within the conductivity/temperature probe slip stream and the water was heated by the probe. The discharge water was ~16°C at the time of the elevated readings. Refer to FKM 2026-05-31 Weekly Report WF Rev 1 for details regarding findings and changes made to rectify the issue. YSI readings were taken during routine inspections:

- June 23/ 2026 @ 03:01: 15.2°C
- June 23/ 2026 @ 18:33: 16.8°C
- June 23/ 2026 @ 20:13: 16.0°C
- June 24/ 2026 @ 23:08: 15.1°C
- June 26/ 2026 @ 03:58: 14.6°C
- June 26/ 2026 @ 09:44: 13.9°C
- June 28/ 2026 @ 19:42: 15.0°C

No visible sheen was observed on the surface of the WTP tanks or in the discharged water. All relevant parameters were measured using YSI instruments, Hanna NTU meter and WTP's NTU, pH, conductivity and temperature probes.

The CP2 WTP received ~340 GPM (1.29 m3/min) and the PWTP received ~204 GPM (0.77 m3/min) from the tunnel.

The total discharge volume up to June 28th was 1,562,934 m3.

		Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope	
Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: BC1 Approved by: BC2 Date: July 16, 2026	

2. Daily Volume Summary:

Table 1: Discharge Volumes Daily Summary

Date	Location	Volume (m3)	Comments
June 22	Woodfibre (WF)	2,963	Exceeded discharge volume limit
June 23	WF	3,008	Exceeded discharge volume limit
June 24	WF	2,926	Exceeded discharge volume limit
June 25	WF	2,993	Exceeded discharge volume limit
June 26	WF	3,115	Exceeded discharge volume limit
June 27	WF	2,969	Exceeded discharge volume limit
June 28	WF	2,795	Exceeded discharge volume limit
Total		20,769	None

		Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope	
Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

3. Discharge Parameter Summary:

Table 2: Portal Discharge Parameter Summary

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/22/2026	0:45:00	7.7	1.2833	1.9	1,380,755	15.1	291
6/22/2026	1:30:00	7.6	1.2908	0	1,380,787	15.7	289
6/22/2026	2:00:00	7.6	1.2833	0	1,380,788	19.3	292
6/22/2026	2:30:00	7.6	1.2681	0	1,380,817	16.1	290
6/22/2026	2:45:00	7.6	1.2795	0	1,380,821	16.8	287
6/22/2026	3:00:00	7.6	1.4309	0.5	1,380,835	15.9	290
6/22/2026	3:15:00	7.5	0.1893	1	1,380,836	16.6	289
6/22/2026	3:30:00	7.6	1.4498	1	1,380,854	15.4	291
6/22/2026	4:00:00	7.6	1.4309	1.2	1,380,885	15.1	291
6/22/2026	4:30:00	7.6	1.4385	1.2	1,380,916	14.8	286
6/22/2026	4:45:00	7.6	1.4498	1.2	1,380,925	15	284
6/22/2026	5:30:00	7.6	1.4157	0.7	1,380,954	14.6	279
6/22/2026	6:00:00	7.6	1.3930	1.4	1,380,972	14.5	278
6/22/2026	6:30:00	7.6	1.3590	2.1	1,380,993	14.3	278
6/22/2026	7:15:00	7.5	1.3400	1.7	1,381,015	14.6	279
6/22/2026	7:30:00	7.5	1.3098	2.1	1,381,035	14.1	279
6/22/2026	8:15:00	7.5	1.3211	2.2	1,381,055	14.3	279
6/22/2026	8:30:00	7.5	1.2681	2.3	1,381,074	14.1	279
6/22/2026	8:45:00	7.5	1.2870	2.4	1,381,077	14.5	279
6/22/2026	9:15:00	7.5	1.0069	3.1	1,381,097	14.4	279
6/22/2026	10:15:00	7.5	0.5830	15.6	1,381,123	14.8	278
6/22/2026	10:45:00	7.5	1.0221	3.7	1,381,139	14.8	278
6/22/2026	11:00:00	7.5	1.3665	2.9	1,381,143	15.1	278
6/22/2026	11:30:00	7.5	1.4460	1.4	1,381,165	15.2	278
6/22/2026	12:45:00	7.5	1.4233	0	1,381,212	15.8	278
6/22/2026	13:15:00	7.5	1.4385	0	1,381,226	16	276
6/22/2026	13:45:00	7.6	0.8593	4.9	1,381,237	16	276
6/22/2026	14:00:00	7.6	0.6473	3.1	1,381,241	16.1	277
6/22/2026	14:45:00	7.5	1.5142	0	1,381,269	16.3	276



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/22/2026	15:15:00	7.5	1.5104	0	1,381,286	16.3	274
6/22/2026	15:45:00	7.5	1.4650	0	1,381,297	16.5	273
6/22/2026	16:15:00	7.5	1.4460	0	1,381,310	16.4	270
6/22/2026	17:30:00	7.5	1.4498	0	1,381,343	17.1	270
6/22/2026	18:45:00	7.6	1.9911	2.8	1,381,381	15.9	267
6/22/2026	19:15:00	7.5	1.4650	0.3	1,381,410	16	265
6/22/2026	20:30:00	7.5	1.3817	0.5	1,381,451	16.4	268
6/22/2026	21:45:00	7.5	1.1962	0	1,381,488	16.3	270
6/22/2026	22:15:00	7.5	1.1886	0.1	1,381,506	16.4	273
6/23/2026	0:00:00	7.6	1.4271	0.1	1,381,545	16.8	290
6/23/2026	0:45:00	7.6	1.4385	0.6	1,381,572	16.5	297
6/23/2026	1:45:00	7.6	1.4422	0.5	1,381,605	16.5	305
6/23/2026	2:15:00	7.7	1.4574	0.1	1,381,627	16.4	307
6/23/2026	2:30:00	7.7	1.4915	1.2	1,381,635	16.7	309
6/23/2026	2:45:00	7.7	1.4309	0	1,381,657	16	302
6/23/2026	3:30:00	7.6	1.4044	1.5	1,381,683	15.4	286
6/23/2026	3:45:00	7.6	1.3968	1.2	1,381,704	15.2	286
6/23/2026	4:15:00	7.6	1.3779	3.7	1,381,731	15.1	284
6/23/2026	4:45:00	7.5	1.3665	6	1,381,756	15	286
6/23/2026	5:00:00	7.5	0.8706	8.1	1,381,761	15.3	286
6/23/2026	5:15:00	7.5	1.3476	13.5	1,381,780	14.8	281
6/23/2026	5:45:00	7.4	1.3135	5.4	1,381,802	14.7	281
6/23/2026	6:15:00	7.4	1.3249	6	1,381,826	14.6	278
6/23/2026	7:15:00	7.4	0.7760	3.2	1,381,861	14.6	272
6/23/2026	7:30:00	7.5	1.2757	1.1	1,381,879	14.4	270
6/23/2026	8:00:00	7.5	1.2681	1.8	1,381,899	14.6	272
6/23/2026	8:30:00	7.5	1.2757	0.8	1,381,924	14.6	268
6/23/2026	9:00:00	7.5	1.1016	5.7	1,381,936	15.2	265
6/23/2026	9:30:00	7.5	1.3703	0.6	1,381,960	14.6	267
6/23/2026	10:00:00	7.5	1.3552	0.2	1,381,987	14.9	267
6/23/2026	10:30:00	7.5	1.2946	1.9	1,382,012	15	268
6/23/2026	11:30:00	7.4	1.2416	3.6	1,382,045	15.5	275



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/23/2026	12:00:00	7.4	1.2265	2.7	1,382,070	15.7	278
6/23/2026	12:30:00	7.4	1.2189	0.6	1,382,092	16	276
6/23/2026	13:15:00	7.5	0.3823	0	1,382,112	16.3	279
6/23/2026	13:30:00	7.4	1.1962	0	1,382,116	16.6	281
6/23/2026	13:45:00	7.4	0.4845	0	1,382,127	16.7	281
6/23/2026	14:00:00	7.5	1.2378	0	1,382,137	16.7	283
6/23/2026	14:15:00	7.4	0.7495	0	1,382,153	16.9	283
6/23/2026	14:30:00	7.4	1.2416	0.6	1,382,160	17.4	283
6/23/2026	15:00:00	7.5	0.4013	2.1	1,382,181	16.5	281
6/23/2026	15:30:00	7.5	1.3779	0.4	1,382,205	16.6	283
6/23/2026	16:00:00	7.5	1.3476	0.4	1,382,235	16.5	279
6/23/2026	16:30:00	7.4	1.3135	0.5	1,382,249	16.6	280
6/23/2026	17:00:00	7.5	1.3060	1	1,382,275	16.6	280
6/23/2026	17:30:00	7.5	1.2681	1.9	1,382,299	16.6	282
6/23/2026	18:00:00	7.4	1.3400	0.6	1,382,319	16.8	282
6/23/2026	18:30:00	7.4	1.3287	0	1,382,343	16.6	282
6/23/2026	19:00:00	7.4	1.3211	0	1,382,366	16.3	280
6/23/2026	19:15:00	7.4	1.3627	1.6	1,382,368	17	278
6/23/2026	19:30:00	7.4	0.8328	12.6	1,382,371	15.9	272
6/23/2026	20:15:00	7.4	1.5444	4	1,382,399	15.6	286
6/23/2026	20:45:00	7.4	1.5104	2.5	1,382,426	15.7	284
6/23/2026	21:00:00	7.4	1.4801	2.6	1,382,449	15.8	284
6/23/2026	21:30:00	7.5	1.4612	3.7	1,382,470	15.9	286
6/23/2026	21:45:00	7.5	1.5028	0.7	1,382,479	16	291
6/23/2026	22:00:00	7.5	0.9388	1.2	1,382,501	16.1	293
6/23/2026	22:15:00	7.5	1.4650	2	1,382,510	16.1	294
6/23/2026	23:15:00	7.5	1.5217	4.7	1,382,546	16.4	304
6/23/2026	23:30:00	7.4	1.4044	2.3	1,382,568	16.8	304
6/24/2026	0:00:00	7.4	0.8441	1.7	1,382,582	17.6	304
6/24/2026	0:15:00	7.4	1.4120	2	1,382,590	17.9	304
6/24/2026	0:30:00	7.4	1.6164	1.9	1,382,614	18.3	304
6/24/2026	1:15:00	7.3	1.4574	1.4	1,382,655	19	304



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/24/2026	2:30:00	7.3	1.5672	0.8	1,382,696	20.1	302
6/24/2026	3:00:00	7.3	0.9009	0.4	1,382,722	21.2	303
6/24/2026	3:30:00	7.4	1.4157	0	1,382,740	16.4	282
6/24/2026	3:45:00	7.4	1.1659	0	1,382,758	15.8	281
6/24/2026	4:00:00	7.4	0.8706	0	1,382,762	16.4	283
6/24/2026	4:15:00	7.4	1.0864	0	1,382,776	15.7	279
6/24/2026	4:30:00	7.4	1.0296	0	1,382,792	16.2	281
6/24/2026	4:45:00	7.4	0.9312	0	1,382,807	17.1	281
6/24/2026	5:00:00	7.4	0.5413	0	1,382,820	17.7	279
6/24/2026	5:15:00	7.3	0.8101	0	1,382,830	18.1	279
6/24/2026	5:30:00	7.3	0.7457	0	1,382,842	18.5	279
6/24/2026	5:45:00	7.4	1.4309	3.1	1,382,863	15.3	271
6/24/2026	6:15:00	7.4	1.1924	4.5	1,382,886	14.9	273
6/24/2026	6:45:00	7.4	1.4385	4.4	1,382,905	15	273
6/24/2026	7:15:00	7.4	1.3855	3.8	1,382,928	14.6	273
6/24/2026	7:45:00	7.4	1.3211	8.5	1,382,947	14.3	268
6/24/2026	8:00:00	7.4	1.3627	2.3	1,382,951	14.6	268
6/24/2026	8:15:00	7.4	1.3438	0.2	1,382,971	14.1	268
6/24/2026	8:30:00	7.4	1.3476	0.5	1,382,976	14.3	268
6/24/2026	9:15:00	7.4	1.3400	0	1,382,998	14.2	266
6/24/2026	9:45:00	7.4	1.3665	0	1,383,024	14.3	265
6/24/2026	10:30:00	7.4	1.3476	0.4	1,383,049	15	266
6/24/2026	11:00:00	7.4	1.3400	0.5	1,383,078	15.2	265
6/24/2026	11:30:00	7.5	1.3476	1.9	1,383,103	14.8	265
6/24/2026	12:00:00	7.5	1.3627	1.9	1,383,131	15.1	266
6/24/2026	12:15:00	7.5	0.6852	1.6	1,383,151	15.2	268
6/24/2026	12:30:00	7.5	1.3665	3.1	1,383,158	15.5	269
6/24/2026	12:45:00	7.5	1.3779	2.5	1,383,169	15.7	270
6/24/2026	13:15:00	7.5	1.3552	2.8	1,383,196	15.8	270
6/24/2026	14:00:00	7.5	1.3476	5.6	1,383,220	16.4	271
6/24/2026	14:30:00	7.5	1.3665	6.3	1,383,247	16.3	277
6/24/2026	14:45:00	7.5	1.3325	2.2	1,383,268	16.3	281



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/24/2026	15:00:00	7.5	1.3665	4.2	1,383,273	16.8	281
6/24/2026	15:15:00	7.5	1.3249	0.8	1,383,294	16.5	281
6/24/2026	15:30:00	7.5	1.3552	4.7	1,383,299	16.7	283
6/24/2026	16:00:00	7.5	1.3249	3.1	1,383,324	16.7	283
6/24/2026	16:15:00	7.5	1.3022	1.5	1,383,343	16.6	281
6/24/2026	16:30:00	7.5	1.3249	0.7	1,383,351	16.8	283
6/24/2026	17:00:00	7.5	1.3173	1.3	1,383,366	16.9	282
6/24/2026	17:15:00	7.5	1.2908	1	1,383,377	16.8	281
6/24/2026	17:30:00	7.5	1.3135	1.9	1,383,394	16.8	281
6/24/2026	17:45:00	7.5	1.3287	1.3	1,383,405	16.8	283
6/24/2026	18:15:00	7.5	1.3173	0.6	1,383,430	16.8	283
6/24/2026	18:45:00	7.5	1.2719	1.3	1,383,458	16.6	282
6/24/2026	19:15:00	7.5	1.7867	10.4	1,383,466	16.2	282
6/24/2026	19:45:00	7.5	0.3293	15.5	1,383,484	16.1	277
6/24/2026	20:00:00	7.5	1.4347	4.5	1,383,493	16.1	279
6/24/2026	20:15:00	7.4	1.4839	2.1	1,383,516	16	278
6/24/2026	20:30:00	7.4	1.4271	2	1,383,538	16	277
6/24/2026	21:00:00	7.4	1.1886	0.5	1,383,557	16	278
6/24/2026	21:45:00	7.5	1.4006	5.7	1,383,568	15.7	285
6/24/2026	22:00:00	7.5	1.0258	5.6	1,383,591	15.7	285
6/24/2026	22:30:00	7.5	1.3627	0	1,383,622	17.1	109
6/24/2026	22:45:00	7.5	1.5369	0	1,383,645	15.6	287
6/24/2026	23:15:00	7.5	1.4839	0.4	1,383,659	15.5	289
6/25/2026	0:00:00	7.5	0.9350	1.3	1,383,692	15.3	291
6/25/2026	0:30:00	7.5	1.4271	1.6	1,383,719	15.2	291
6/25/2026	1:00:00	7.5	0.9009	1.7	1,383,747	15.3	294
6/25/2026	1:45:00	7.6	1.7640	8.4	1,383,765	15.3	294
6/25/2026	2:00:00	7.5	0.9918	3.2	1,383,788	15.3	294
6/25/2026	2:15:00	7.5	1.4536	0.4	1,383,808	15.3	294
6/25/2026	2:30:00	7.5	0.7154	5.9	1,383,830	15.2	294
6/25/2026	2:45:00	7.6	1.3590	1.9	1,383,831	15.2	296
6/25/2026	3:00:00	7.5	0.8063	0.6	1,383,851	15.2	298



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/25/2026	3:15:00	7.5	1.3552	0.8	1,383,869	15.1	299
6/25/2026	3:45:00	7.6	1.2075	8.2	1,383,887	15.1	299
6/25/2026	4:00:00	7.5	0.8328	1.4	1,383,893	15.1	298
6/25/2026	4:15:00	7.5	1.3476	2.3	1,383,911	15	298
6/25/2026	4:30:00	7.5	1.3703	3.5	1,383,932	15	298
6/25/2026	5:00:00	7.6	0.9199	11.8	1,383,937	15.1	297
6/25/2026	5:15:00	7.5	1.6239	7.2	1,383,949	14.9	299
6/25/2026	5:30:00	7.5	1.6694	5.9	1,383,962	15.3	303
6/25/2026	6:00:00	7.5	1.0221	4.1	1,383,996	15.1	294
6/25/2026	6:30:00	7.5	1.5823	3.8	1,384,026	15.2	298
6/25/2026	7:15:00	7.5	1.5747	0.8	1,384,055	15.5	294
6/25/2026	8:00:00	7.4	0.6435	8.1	1,384,086	15.4	291
6/25/2026	8:15:00	7.4	1.6126	1.6	1,384,092	15.3	286
6/25/2026	8:45:00	7.4	1.5482	1.7	1,384,124	14.7	283
6/25/2026	9:15:00	7.4	1.4120	3.9	1,384,150	14.5	279
6/25/2026	9:45:00	7.4	1.4044	5.9	1,384,178	14.5	279
6/25/2026	10:30:00	7.4	1.3855	6.1	1,384,217	14.6	278
6/25/2026	10:45:00	7.4	1.3438	5.4	1,384,238	14.6	275
6/25/2026	11:00:00	7.4	0.7760	14	1,384,242	15.3	275
6/25/2026	11:15:00	7.4	1.3249	4	1,384,259	14.6	275
6/25/2026	11:30:00	7.4	1.3173	4.2	1,384,269	14.7	274
6/25/2026	11:45:00	7.5	1.3400	4.5	1,384,288	14.6	274
6/25/2026	12:00:00	7.5	0.8252	13.6	1,384,295	14.7	273
6/25/2026	12:30:00	7.5	1.3514	4.7	1,384,310	14.7	273
6/25/2026	12:45:00	7.5	1.3173	4.8	1,384,330	14.6	273
6/25/2026	13:00:00	7.5	0.7457	20.6	1,384,335	14.7	273
6/25/2026	13:15:00	7.5	1.3098	2.8	1,384,353	14.6	273
6/25/2026	13:30:00	7.5	1.3400	3.1	1,384,361	15.1	277
6/25/2026	13:45:00	7.5	1.3249	1.7	1,384,381	14.6	273
6/25/2026	14:15:00	7.4	1.3098	3.4	1,384,405	14.6	274
6/25/2026	14:45:00	7.4	1.3173	1.5	1,384,435	14.6	275
6/25/2026	15:00:00	7.4	0.8025	11.8	1,384,454	14.6	275



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/25/2026	15:30:00	7.5	1.2908	2.4	1,384,481	14.5	273
6/25/2026	16:15:00	7.5	1.4157	6.7	1,384,505	14.6	275
6/25/2026	16:30:00	7.5	1.3817	5.9	1,384,526	14.5	275
6/25/2026	16:45:00	7.5	1.4044	3.2	1,384,537	14.6	275
6/25/2026	17:30:00	7.5	1.3703	1.4	1,384,572	14.6	275
6/25/2026	17:45:00	7.5	1.3703	1.5	1,384,593	14.6	275
6/25/2026	18:00:00	7.5	0.8555	7.2	1,384,613	14.6	275
6/25/2026	18:15:00	7.5	1.4120	2.5	1,384,619	14.7	273
6/25/2026	18:45:00	7.5	1.4120	2.1	1,384,643	14.6	272
6/25/2026	19:15:00	7.5	1.3892	0.7	1,384,668	14.5	270
6/25/2026	20:00:00	7.5	1.3476	2.1	1,384,689	14.2	270
6/25/2026	20:15:00	7.5	1.3400	1.8	1,384,709	14.2	270
6/25/2026	20:45:00	7.5	0.4164	6.2	1,384,735	14.2	269
6/25/2026	21:30:00	7.6	0.9047	2.9	1,384,752	14.4	272
6/25/2026	22:00:00	7.6	1.4612	20.1	1,384,782	14.3	273
6/25/2026	22:15:00	7.6	1.4612	0.8	1,384,803	14.5	273
6/25/2026	22:30:00	7.5	0.9729	0.4	1,384,821	14.4	273
6/25/2026	22:45:00	7.5	1.5709	0.6	1,384,826	14.4	273
6/25/2026	23:30:00	7.6	0.9842	0.6	1,384,834	15	276
6/25/2026	23:45:00	7.5	1.5482	0.2	1,384,857	14.5	273
6/26/2026	0:00:00	7.5	1.5331	0.2	1,384,880	14.5	273
6/26/2026	0:15:00	7.5	1.5482	0.1	1,384,897	14.5	273
6/26/2026	0:30:00	7.5	0.9388	0.4	1,384,918	14.7	275
6/26/2026	1:00:00	7.5	1.5028	0.1	1,384,956	14.5	273
6/26/2026	2:15:00	7.5	1.5066	1.6	1,384,991	14.7	272
6/26/2026	2:30:00	7.5	0.9993	2.1	1,385,013	14.9	271
6/26/2026	2:45:00	7.5	1.5558	1.8	1,385,035	14.7	271
6/26/2026	3:00:00	7.5	1.5558	1.5	1,385,059	14.6	271
6/26/2026	3:30:00	7.5	0.9918	1.7	1,385,086	15	269
6/26/2026	3:45:00	7.5	1.5520	1.9	1,385,109	14.9	271
6/26/2026	4:15:00	7.5	1.5179	1.4	1,385,133	14.7	271
6/26/2026	4:45:00	7.5	1.4952	0.3	1,385,148	14.4	269



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/26/2026	5:15:00	7.5	1.4498	1.3	1,385,165	14.1	271
6/26/2026	5:45:00	7.5	1.5369	2.6	1,385,189	14	269
6/26/2026	6:00:00	7.5	1.4687	2.3	1,385,212	13.8	271
6/26/2026	6:30:00	7.5	0.9123	1.6	1,385,231	13.8	268
6/26/2026	6:45:00	7.5	1.5066	1	1,385,253	13.6	268
6/26/2026	7:15:00	7.5	1.4839	1	1,385,275	13.6	268
6/26/2026	7:45:00	7.5	1.4536	1.5	1,385,295	13.9	268
6/26/2026	8:00:00	7.5	1.4650	1.4	1,385,317	13.5	269
6/26/2026	8:15:00	7.5	0.8858	1.6	1,385,320	13.7	268
6/26/2026	8:30:00	7.5	1.4347	1.5	1,385,341	13.5	267
6/26/2026	9:15:00	7.5	1.3627	2.3	1,385,374	13.6	266
6/26/2026	9:45:00	7.5	1.6959	1.6	1,385,397	13.6	268
6/26/2026	10:15:00	7.5	1.6164	2.9	1,385,438	13.7	268
6/26/2026	10:30:00	7.5	1.5785	2.4	1,385,462	13.8	272
6/26/2026	11:00:00	7.5	1.6088	1.7	1,385,489	13.9	272
6/26/2026	11:30:00	7.5	1.5142	1.2	1,385,506	14.3	272
6/26/2026	11:45:00	7.5	1.5672	0.7	1,385,511	13.9	273
6/26/2026	12:00:00	7.5	1.4309	1.3	1,385,533	13.9	273
6/26/2026	12:30:00	7.5	1.4915	1.6	1,385,558	14.1	274
6/26/2026	12:45:00	7.5	1.5028	2.1	1,385,581	14.1	273
6/26/2026	13:00:00	7.5	1.4536	2	1,385,599	14.1	274
6/26/2026	13:30:00	7.5	1.4915	3.7	1,385,606	14.2	277
6/26/2026	14:00:00	7.5	1.5028	3.6	1,385,627	14.8	278
6/26/2026	14:15:00	7.5	1.4877	4.9	1,385,645	14.2	277
6/26/2026	14:30:00	7.5	1.4650	6.1	1,385,667	14.2	278
6/26/2026	14:45:00	7.5	1.4952	1.8	1,385,674	14.3	277
6/26/2026	15:00:00	7.5	1.4460	1.9	1,385,690	14.4	277
6/26/2026	15:15:00	7.5	1.4612	4.4	1,385,700	14.4	277
6/26/2026	15:30:00	7.5	1.4574	1.6	1,385,713	14.3	276
6/26/2026	15:45:00	7.5	1.3627	5	1,385,735	14.2	276
6/26/2026	16:00:00	7.5	1.4460	0.6	1,385,757	14.2	275
6/26/2026	17:00:00	7.5	1.5104	0.4	1,385,789	14	273



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/26/2026	17:15:00	7.5	1.4498	0.4	1,385,808	14	273
6/26/2026	17:30:00	7.5	1.4460	0.5	1,385,819	14	273
6/26/2026	17:45:00	7.5	1.4574	0.4	1,385,837	14	273
6/26/2026	18:15:00	7.5	1.4195	0.9	1,385,859	14.1	275
6/26/2026	18:30:00	7.5	1.3627	1.4	1,385,880	14.1	275
6/26/2026	18:45:00	7.5	1.3930	1.9	1,385,898	14.1	275
6/26/2026	19:30:00	7.5	1.4271	4.2	1,385,905	14.1	270
6/26/2026	19:45:00	7.5	1.4725	3.1	1,385,927	14.2	270
6/26/2026	20:00:00	7.5	1.3438	2	1,385,945	14.2	270
6/26/2026	20:30:00	7.5	1.3022	1.6	1,385,963	14.2	268
6/26/2026	20:45:00	7.5	1.3552	1	1,385,977	14.1	268
6/26/2026	21:00:00	7.5	1.3930	1.4	1,385,986	14.1	268
6/26/2026	21:30:00	7.5	1.0523	1.1	1,386,003	13.7	272
6/26/2026	21:45:00	7.5	1.1432	0.8	1,386,018	13.8	270
6/26/2026	22:15:00	7.5	0.6776	1.9	1,386,032	13.9	270
6/26/2026	22:30:00	7.5	1.1318	1.9	1,386,047	14	270
6/26/2026	22:45:00	7.5	1.1053	5.1	1,386,053	13.9	270
6/26/2026	23:00:00	7.5	1.7034	6.6	1,386,068	14	273
6/26/2026	23:45:00	7.5	1.5407	2.3	1,386,101	13.8	273
6/27/2026	0:00:00	7.5	1.5293	2.1	1,386,113	14.2	271
6/27/2026	0:15:00	7.4	1.0410	6.3	1,386,130	14.1	271
6/27/2026	1:30:00	7.4	1.5179	3.1	1,386,178	13.7	269
6/27/2026	1:45:00	7.4	1.4915	2.9	1,386,194	13.6	271
6/27/2026	2:15:00	7.4	0.9956	3.2	1,386,214	13.8	269
6/27/2026	3:00:00	7.4	1.5444	6.4	1,386,237	13.7	271
6/27/2026	3:45:00	7.4	1.4839	4.2	1,386,271	13.8	268
6/27/2026	4:15:00	7.4	0.8063	2.9	1,386,305	13.6	271
6/27/2026	4:30:00	7.4	1.2719	9.2	1,386,323	13.5	271
6/27/2026	5:00:00	7.5	1.2757	1.7	1,386,350	13.5	268
6/27/2026	5:30:00	7.5	1.2265	0.7	1,386,372	13.4	271
6/27/2026	6:00:00	7.4	1.2492	0.1	1,386,381	15	269
6/27/2026	6:15:00	7.4	0.8517	0	1,386,398	14.3	271



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/27/2026	6:30:00	7.4	1.3135	0	1,386,406	14.3	269
6/27/2026	6:45:00	7.4	1.2605	0	1,386,425	14.1	269
6/27/2026	7:15:00	7.4	0.9880	0.2	1,386,456	14.3	269
6/27/2026	7:30:00	7.4	1.2568	0.4	1,386,461	14.2	271
6/27/2026	8:15:00	7.4	0.5224	0	1,386,494	14.3	269
6/27/2026	8:30:00	7.4	0.7419	0.2	1,386,502	14.2	268
6/27/2026	8:45:00	7.4	1.3022	0.5	1,386,519	14	269
6/27/2026	9:00:00	7.4	1.2757	0.5	1,386,539	13.8	273
6/27/2026	9:30:00	7.4	0.7874	0.8	1,386,559	13.9	269
6/27/2026	9:45:00	7.4	0.4240	1.3	1,386,573	13.7	270
6/27/2026	10:00:00	7.4	1.3438	1	1,386,576	14.1	268
6/27/2026	10:15:00	7.4	1.2795	1	1,386,595	13.9	270
6/27/2026	10:30:00	7.4	1.2643	1	1,386,614	14	269
6/27/2026	10:45:00	7.4	0.2574	5.8	1,386,629	13.8	272
6/27/2026	11:30:00	7.4	1.5369	1.7	1,386,655	13.9	270
6/27/2026	12:00:00	7.4	0.9274	1.4	1,386,691	13.9	270
6/27/2026	12:30:00	7.4	1.5747	1.9	1,386,725	14.1	268
6/27/2026	12:45:00	7.4	1.5823	2.1	1,386,738	14.2	268
6/27/2026	13:30:00	7.4	1.6126	4.6	1,386,756	14.3	268
6/27/2026	14:00:00	7.5	1.5785	4.5	1,386,766	14.6	265
6/27/2026	14:30:00	7.5	1.6429	4.9	1,386,795	14.6	268
6/27/2026	15:00:00	7.4	1.5104	7.2	1,386,812	14.7	265
6/27/2026	15:15:00	7.5	1.9419	1.1	1,386,817	15.1	267
6/27/2026	15:30:00	7.5	1.8056	3.1	1,386,844	14.6	267
6/27/2026	15:45:00	7.5	1.7981	3.3	1,386,852	15	267
6/27/2026	16:45:00	7.5	1.5369	0.8	1,386,885	14.7	265
6/27/2026	17:30:00	7.5	1.4574	0.7	1,386,921	14.4	265
6/27/2026	17:45:00	7.5	1.4990	0.8	1,386,931	14.5	263
6/27/2026	18:00:00	7.5	1.4952	1.3	1,386,953	14.5	263
6/27/2026	18:15:00	7.4	1.4877	1.8	1,386,959	14.9	268
6/27/2026	18:30:00	7.5	1.4574	1.2	1,386,980	14.6	267
6/27/2026	19:45:00	7.5	1.5142	2.6	1,387,009	14.6	272



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/27/2026	20:00:00	7.5	1.5823	2.2	1,387,032	14.6	272
6/27/2026	20:30:00	7.5	1.6012	1.4	1,387,040	14.7	273
6/27/2026	21:45:00	7.5	1.3590	1.4	1,387,069	14.4	273
6/27/2026	22:00:00	7.4	0.9880	1.8	1,387,091	14.5	275
6/27/2026	22:15:00	7.4	1.4990	3	1,387,111	14.5	275
6/27/2026	22:30:00	7.4	1.4574	2.9	1,387,133	14.5	275
6/27/2026	22:45:00	7.4	1.4309	3.6	1,387,154	14.5	275
6/27/2026	23:45:00	7.4	1.3552	9.5	1,387,186	14.5	274
6/28/2026	0:15:00	7.5	1.6769	10.5	1,387,200	14.6	274
6/28/2026	0:30:00	7.5	0.9047	10.2	1,387,220	14.6	274
6/28/2026	1:15:00	7.5	1.4422	3.7	1,387,246	14.5	277
6/28/2026	2:15:00	7.4	1.4952	0.1	1,387,286	15	275
6/28/2026	2:45:00	7.4	1.5028	1.3	1,387,307	14.5	276
6/28/2026	3:15:00	7.4	1.4763	1.5	1,387,323	14.4	281
6/28/2026	3:30:00	7.4	0.9426	13.2	1,387,344	14.5	284
6/28/2026	4:30:00	7.4	0.9577	10.6	1,387,368	15.4	282
6/28/2026	5:15:00	7.4	1.4385	12.3	1,387,410	15.5	281
6/28/2026	6:00:00	7.4	1.3779	11.4	1,387,431	15.3	282
6/28/2026	6:15:00	7.4	1.3703	12.9	1,387,452	15.2	282
6/28/2026	7:00:00	7.4	1.4195	0.3	1,387,480	14.9	280
6/28/2026	7:15:00	7.4	1.4157	0.5	1,387,501	14.9	279
6/28/2026	7:30:00	7.4	1.3968	0.8	1,387,522	14.9	279
6/28/2026	8:15:00	7.4	0.7306	7	1,387,540	14.2	274
6/28/2026	8:30:00	7.4	0.3028	1.2	1,387,547	14.2	276
6/28/2026	8:45:00	7.4	1.1659	0.5	1,387,552	14	273
6/28/2026	9:00:00	7.4	1.2265	0.5	1,387,571	14.1	274
6/28/2026	9:15:00	7.4	1.4233	1.7	1,387,586	14.1	274
6/28/2026	10:15:00	7.4	1.3325	2.6	1,387,602	14.4	274
6/28/2026	10:30:00	7.4	1.3665	2.9	1,387,615	14.1	276
6/28/2026	10:45:00	7.4	0.7836	3.8	1,387,634	14.3	276
6/28/2026	11:00:00	7.4	1.3703	3.1	1,387,653	14.3	281
6/28/2026	11:15:00	7.4	1.3552	3.7	1,387,660	14.6	281



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/28/2026	11:30:00	7.5	1.3855	5.5	1,387,676	14.5	282
6/28/2026	11:45:00	7.5	1.3590	4	1,387,697	14.4	284
6/28/2026	12:15:00	7.5	1.5293	4.3	1,387,729	14.6	286
6/28/2026	12:30:00	7.5	0.8025	7.7	1,387,740	14.7	288
6/28/2026	13:15:00	7.5	1.6845	12.7	1,387,764	14.8	289
6/28/2026	13:30:00	7.5	1.3173	2.6	1,387,774	14.9	288
6/28/2026	14:00:00	7.5	1.5028	1.5	1,387,810	15.1	288
6/28/2026	14:30:00	7.5	1.6391	0.7	1,387,816	15.3	288
6/28/2026	15:00:00	7.5	0.9047	2.2	1,387,839	15.1	286
6/28/2026	15:15:00	7.5	0.4467	0	1,387,850	15.1	286
6/28/2026	15:30:00	7.5	1.3211	0	1,387,868	15.2	286
6/28/2026	15:45:00	7.4	1.3060	0	1,387,881	15.5	286
6/28/2026	16:00:00	7.4	1.2946	0	1,387,901	15.6	288
6/28/2026	16:15:00	7.4	1.2492	0.1	1,387,920	15.7	286
6/28/2026	17:00:00	7.4	1.5369	4.8	1,387,939	15.3	286
6/28/2026	17:15:00	7.4	1.6429	2.1	1,387,960	15.5	288
6/28/2026	17:30:00	7.5	1.6504	55.4	1,387,979	15.5	289
6/28/2026	17:45:00	7.4	1.2530	1.1	1,387,993	15.6	289
6/28/2026	18:00:00	7.4	1.1773	1.1	1,388,011	15.6	291
6/28/2026	18:15:00	7.4	1.1962	1.4	1,388,029	15.7	291
6/28/2026	18:30:00	7.4	1.2038	1.3	1,388,046	15.7	291
6/28/2026	18:45:00	7.4	1.1735	1.5	1,388,060	15.7	291
6/28/2026	19:00:00	7.4	1.2000	0.5	1,388,078	15.7	291
6/28/2026	19:30:00	7.4	1.4233	6.6	1,388,091	15.6	289
6/28/2026	19:45:00	7.4	1.3627	7.3	1,388,108	15.5	288
6/28/2026	20:00:00	7.4	1.3817	4.4	1,388,129	15.4	287
6/28/2026	20:30:00	7.4	1.4082	4	1,388,150	15.3	283
6/28/2026	21:00:00	7.4	1.4195	4.2	1,388,165	15.2	281
6/28/2026	22:00:00	7.5	0.3937	8.1	1,388,198	14.8	282
6/28/2026	22:15:00	7.5	1.8473	13.4	1,388,199	14.8	286
6/28/2026	22:30:00	7.5	1.4801	1.4	1,388,219	14.8	286
6/28/2026	22:45:00	7.5	1.4460	1.6	1,388,240	14.8	288



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/28/2026	23:00:00	7.5	1.5028	2	1,388,263	14.8	288

		Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope	
Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

4. CP2 Discharge Parameter Summary:

Table 3: CP2 Discharge Parameter Summary

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/22/2026	0:00:00	7.41	2.1880	0	161677.4	14.3	161
6/22/2026	0:15:00	7.41	2.1653	0	161711.4	14.2	161
6/22/2026	0:30:00	7.4	1.6239	0	161741.5	14.7	161
6/22/2026	0:45:00	7.38	2.1388	0	161771.5	14.2	163
6/22/2026	1:00:00	7.38	1.5861	0	161801.8	14.4	164
6/22/2026	1:15:00	7.33	0.8063	0	161809.6	15.1	164
6/22/2026	1:30:00	7.35	2.0441	0	161839.5	14.2	164
6/22/2026	1:45:00	7.34	1.5293	0	161866.1	14.8	164
6/22/2026	2:00:00	7.31	0.2839	0	161874.2	15.4	163
6/22/2026	2:15:00	7.33	1.5672	0	161890.4	15	162
6/22/2026	2:30:00	7.33	1.9230	0	161919.3	14.2	162
6/22/2026	2:45:00	7.33	1.6012	0	161944.9	14.6	163
6/22/2026	3:00:00	7.3	1.7678	0	161968.9	15.1	164
6/22/2026	3:15:00	7.29	1.6088	0	161995.3	15.6	164
6/22/2026	3:30:00	7.27	1.4309	0	162017.7	15.9	164
6/22/2026	3:45:00	7.31	2.0479	0	162045.2	14.2	161
6/22/2026	4:00:00	7.3	1.4801	0	162072.7	14.4	161
6/22/2026	4:15:00	7.3	1.8927	0	162100.3	13.9	162
6/22/2026	4:30:00	7.31	1.0561	0	162126.0	14.2	162
6/22/2026	4:45:00	7.28	0.3142	0	162130.8	14.6	163
6/22/2026	5:00:00	7.27	0.4050	0	162137.2	15	161
6/22/2026	5:15:00	7.25	1.5142	0	162151.8	15.4	164
6/22/2026	5:30:00	7.24	1.4195	0	162165.1	15.6	164
6/22/2026	5:45:00	7.27	2.0214	0	162184.5	13.8	161
6/22/2026	6:00:00	7.25	1.5444	0	162212.6	13.6	163
6/22/2026	6:15:00	7.24	2.3507	0	162243.4	13.3	165
6/22/2026	6:30:00	7.24	1.5104	0	162269.3	13.4	165
6/22/2026	6:45:00	7.24	0.9918	0	162300.3	13.7	164



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/22/2026	7:00:00	7.23	0.4959	0	162310.7	15.7	163
6/22/2026	7:15:00	7.23	2.2258	0	162319.4	15.3	159
6/22/2026	7:30:00	7.28	2.3167	0	162353.4	14.1	163
6/22/2026	7:45:00	7.29	2.3091	0	162383.7	14	161
6/22/2026	8:00:00	7.29	2.0138	0	162416.0	14.1	164
6/22/2026	8:15:00	7.27	0.7949	0	162441.3	14.8	163
6/22/2026	8:30:00	7.26	2.2258	1	162450.4	15.8	163
6/22/2026	8:45:00	7.25	0.6965	0	162470.9	15.9	164
6/22/2026	9:00:00	7.27	0.3710	0	162480.3	16.5	161
6/22/2026	9:15:00	7.25	0.8934	0	162496.8	15.9	161
6/22/2026	9:30:00	7.25	0.2990	0	162505.3	17.4	164
6/22/2026	9:45:00	7.27	2.0025	0	162523.9	15.6	161
6/22/2026	10:00:00	7.27	0.7647	0	162546.1	15.9	162
6/22/2026	10:15:00	7.25	0.9123	0	162554.0	17.2	163
6/22/2026	10:30:00	7.28	2.1766	0	162582.4	15.4	162
6/22/2026	10:45:00	7.28	2.1842	0	162614.4	15.3	164
6/22/2026	11:00:00	7.28	1.8473	0	162645.9	15.4	164
6/22/2026	11:15:00	7.27	0.5754	0	162665.5	16.3	165
6/22/2026	11:30:00	7.28	1.9760	0	162682.2	15.9	164
6/22/2026	11:45:00	7.28	2.3280	0	162711.6	15.8	164
6/22/2026	12:00:00	7.27	0.4694	0	162723.7	17.5	165
6/22/2026	12:15:00	7.28	2.3091	0	162738.2	16.7	163
6/22/2026	12:30:00	7.29	2.3318	0	162770.8	16.1	164
6/22/2026	12:45:00	7.29	1.8397	0	162802.1	16	164
6/22/2026	13:00:00	7.29	1.9722	0	162834.0	15.8	163
6/22/2026	13:15:00	7.27	0.4429	0	162847.4	17.1	164
6/22/2026	13:30:00	7.28	2.0025	0	162868.4	16.2	164
6/22/2026	13:45:00	7.29	2.3053	0	162900.7	16.1	164
6/22/2026	14:00:00	7.28	2.1350	0	162929.9	16.2	164
6/22/2026	14:15:00	7.29	1.5785	0	162962.6	16	164
6/22/2026	14:30:00	7.26	0.6284	0	162974.0	17.2	167
6/22/2026	14:45:00	7.28	0.8366	0	162999.7	16.5	163



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/22/2026	15:00:00	7.27	2.2599	0	163013.3	16.5	164
6/22/2026	15:15:00	7.28	2.3129	0	163047.3	15.9	163
6/22/2026	15:30:00	7.26	0.5489	0	163059.3	17.4	164
6/22/2026	15:45:00	7.28	2.2107	0	163077.5	16.5	162
6/22/2026	16:00:00	7.3	1.5861	0	163109.7	16.3	164
6/22/2026	16:15:00	7.31	2.3167	0	163139.6	16.1	164
6/22/2026	16:30:00	7.3	2.3015	0	163173.7	16.1	164
6/22/2026	16:45:00	7.28	0.7192	0	163196.6	16.9	164
6/22/2026	17:00:00	7.28	2.2750	0	163213.8	16.5	163
6/22/2026	17:15:00	7.28	1.7754	0	163245.6	16.4	162
6/22/2026	17:30:00	7.27	0.8744	0	163266.5	16.8	164
6/22/2026	17:45:00	7.27	2.2864	0	163290.8	16.1	160
6/22/2026	18:00:00	7.28	0.8934	0	163323.5	16	161
6/22/2026	18:15:00	7.26	0.4391	0	163333.2	17.5	163
6/22/2026	18:30:00	7.24	2.1236	0	163341.3	18.1	161
6/22/2026	18:45:00	7.28	2.1653	0	163370.5	16.1	160
6/22/2026	19:00:00	7.29	2.2296	0	163404.0	15.5	161
6/22/2026	19:30:00	7.3	1.8700	0	163462.5	15.1	161
6/22/2026	19:45:00	7.29	0.2498	0	163474.5	16.4	161
6/22/2026	20:00:00	7.29	2.1463	0	163494.2	15.2	160
6/22/2026	20:15:00	7.29	2.1312	0	163523.1	14.8	159
6/22/2026	20:30:00	7.29	1.7564	0	163548.1	15	160
6/22/2026	20:45:00	7.3	2.0366	0	163577.5	14.8	159
6/22/2026	21:00:00	7.3	1.3817	0	163603.4	15.1	160
6/22/2026	21:15:00	7.3	1.9495	0	163629.4	14.9	160
6/22/2026	21:30:00	7.29	1.2151	0	163655.4	14.9	159
6/22/2026	21:45:00	7.29	0.6776	0	163671.0	15.8	161
6/22/2026	22:00:00	7.26	0.7003	0	163675.7	17.2	163
6/22/2026	22:15:00	7.28	1.7224	0	163694.2	15.7	160
6/22/2026	22:30:00	7.29	0.6738	0	163714.6	15.5	161
6/22/2026	22:45:00	7.27	0.8441	0	163723.1	16.4	163
6/22/2026	23:00:00	7.28	0.4542	0	163733.2	16.3	161



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/22/2026	23:15:00	7.25	0.0341	0	163734.6	17.4	162
6/22/2026	23:30:00	7.28	1.6807	0	163754.6	15.3	163
6/22/2026	23:45:00	7.27	1.6164	0	163776.4	15	162
6/23/2026	0:00:00	7.27	1.7867	0	163799.2	15.1	163
6/23/2026	0:15:00	7.26	1.1356	0	163821.6	15	163
6/23/2026	0:30:00	7.26	2.0895	0	163850.0	14.6	163
6/23/2026	0:45:00	7.25	1.7375	0	163884.8	14.4	162
6/23/2026	1:00:00	7.26	2.6649	0	163921.5	14.4	162
6/23/2026	1:15:00	7.29	2.5249	0	163956.1	14.5	163
6/23/2026	1:30:00	7.28	0.1590	0	163974.6	15.4	163
6/23/2026	1:45:00	7.25	0.3293	0	163978.5	16.3	163
6/23/2026	2:00:00	7.29	2.2750	0	164008.7	14.8	163
6/23/2026	2:15:00	7.3	1.5142	0	164043.9	14.6	162
6/23/2026	2:30:00	7.29	2.1880	0	164060.4	14.8	164
6/23/2026	2:45:00	7.29	2.5059	0	164096.6	14.3	164
6/23/2026	3:00:00	7.3	2.2069	0	164130.1	14.5	164
6/23/2026	3:15:00	7.31	2.1993	0	164164.7	14.6	165
6/23/2026	3:30:00	7.31	1.4120	0	164196.1	15	164
6/23/2026	3:45:00	7.29	0.2309	0	164202.8	15.8	165
6/23/2026	4:00:00	7.27	1.9381	1	164208.1	16.3	167
6/23/2026	4:15:00	7.3	2.2712	0	164241.9	14.6	165
6/23/2026	4:30:00	7.3	2.3886	0	164272.5	14.7	165
6/23/2026	4:45:00	7.3	0.1060	0	164294.6	15.1	165
6/23/2026	5:00:00	7.27	0.1401	0	164295.8	15.8	165
6/23/2026	5:15:00	7.25	0.2839	0	164299.2	16.3	168
6/23/2026	5:30:00	7.28	0.9691	0	164313.3	15.1	165
6/23/2026	5:45:00	7.3	2.2750	0	164331.5	14.4	165
6/23/2026	6:00:00	7.29	1.6656	0	164363.8	14.1	165
6/23/2026	6:15:00	7.3	0.7003	0	164384.5	14.4	165
6/23/2026	6:30:00	7.27	0.3861	0	164392.1	15.3	166
6/23/2026	6:45:00	7.28	2.1728	0	164409.4	14.3	165
6/23/2026	7:00:00	7.26	0.8214	0	164437.0	14.3	165



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/23/2026	7:15:00	7.25	0.3861	0	164445.3	15	165
6/23/2026	7:30:00	7.27	2.0441	0	164469.0	14.3	165
6/23/2026	7:45:00	7.27	1.2605	0	164497.7	14.3	166
6/23/2026	8:00:00	7.27	1.8965	0	164524.3	14.3	165
6/23/2026	8:15:00	7.28	1.7754	0	164547.6	14.5	165
6/23/2026	8:30:00	7.27	0.9047	0	164565.6	14.8	165
6/23/2026	8:45:00	7.27	0.9009	0	164584.0	15	164
6/23/2026	9:00:00	7.25	0.1741	0	164591.7	16.1	166
6/23/2026	9:15:00	7.23	0.0227	0	164593.1	17.6	166
6/23/2026	9:30:00	7.21	0.0227	0	164594.4	18.9	168
6/23/2026	9:45:00	7.25	1.3438	1	164605.1	17.4	163
6/23/2026	10:00:00	7.26	1.0448	0	164625.5	16.4	162
6/23/2026	10:15:00	7.27	1.8321	0	164647.0	16	161
6/23/2026	10:30:00	7.28	2.3810	0	164679.2	15.5	161
6/23/2026	10:45:00	7.28	2.3545	0	164710.3	15.6	162
6/23/2026	11:00:00	7.29	2.0933	0	164739.3	16.1	163
6/23/2026	11:15:00	7.3	2.3735	0	164772.1	16.1	161
6/23/2026	11:30:00	7.28	0.1211	0	164788.6	17.6	162
6/23/2026	11:45:00	7.29	2.2637	0	164811.9	16.5	159
6/23/2026	12:00:00	7.28	1.3514	0	164835.1	16.5	159
6/23/2026	12:15:00	7.26	1.1924	0	164856.1	18.3	162
6/23/2026	12:30:00	7.22	0.3558	1	164861.1	19.8	164
6/23/2026	12:45:00	7.2	0.3710	1	164867.7	21.2	165
6/23/2026	13:00:00	7.25	2.0668	1	164876.5	17.2	158
6/23/2026	13:15:00	7.26	0.3104	0	164899.1	17.8	161
6/23/2026	13:30:00	7.3	2.2031	1	164919.9	15.7	163
6/23/2026	13:45:00	7.3	1.9154	0	164952.3	16.1	162
6/23/2026	14:00:00	7.31	1.0713	0	164980.3	16.9	161
6/23/2026	14:15:00	7.29	2.1804	8	164986.7	17.4	158
6/23/2026	14:30:00	7.31	2.3735	0	165020.2	15.5	163
6/23/2026	14:45:00	7.33	1.5407	0	165052.4	16.1	162
6/23/2026	15:00:00	7.29	0.2877	0	165060.3	18.3	163



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/23/2026	15:15:00	7.27	0.3180	1	165064.5	20.1	164
6/23/2026	15:30:00	7.21	0.3710	1	165070.0	21.6	165
6/23/2026	15:45:00	7.29	2.0517	0	165086.6	16.8	162
6/23/2026	16:00:00	7.3	0.1438	1	165105.8	18.2	162
6/23/2026	16:15:00	7.3	0.7571	3	165114.9	18.4	162
6/23/2026	16:30:00	7.31	2.0706	0	165134.9	17.5	160
6/23/2026	16:45:00	7.32	2.0517	0	165165.6	17	160
6/23/2026	17:00:00	7.31	0.1401	0	165186.4	18.3	161
6/23/2026	17:15:00	7.27	0.1703	0	165189.5	20.3	164
6/23/2026	17:30:00	7.29	2.3697	0	165217.5	16.9	160
6/23/2026	17:45:00	7.29	0.1173	0	165237.9	18.4	161
6/23/2026	18:00:00	7.3	2.3697	0	165251.5	17.3	160
6/23/2026	18:15:00	7.33	2.3621	0	165285.6	16.5	161
6/23/2026	18:30:00	7.33	2.3470	0	165319.7	16.4	162
6/23/2026	18:45:00	7.32	0.8896	0	165348.3	17.3	163
6/23/2026	19:00:00	7.31	2.3318	1	165357.0	16.8	161
6/23/2026	19:15:00	7.32	1.3022	0	165388.0	16.9	161
6/23/2026	19:30:00	7.29	0.1514	0	165392.5	18.9	164
6/23/2026	19:45:00	7.28	2.3053	1	165401.1	17.2	160
6/23/2026	20:00:00	7.3	2.0063	0	165434.6	15.9	161
6/23/2026	20:15:00	7.29	1.9873	0	165467.7	16.1	160
6/23/2026	20:30:00	7.27	0.2612	0	165481.7	17.6	161
6/23/2026	20:45:00	7.24	0.2801	1	165485.1	19.1	163
6/23/2026	21:00:00	7.21	0.2461	1	165488.5	20.3	163
6/23/2026	21:15:00	7.19	0.2082	1	165491.9	21.1	163
6/23/2026	21:30:00	7.26	1.7602	0	165514.5	16.7	158
6/23/2026	21:45:00	7.24	0.4694	1	165525.7	18.1	161
6/23/2026	22:00:00	7.22	1.2605	1	165533.4	19.2	165
6/23/2026	22:15:00	7.27	2.1047	0	165562.6	15.7	157
6/23/2026	22:30:00	7.27	2.0782	0	165593.3	15.2	160
6/23/2026	22:45:00	7.29	2.0820	0	165624.0	15.1	160
6/23/2026	23:00:00	7.3	2.0366	0	165654.6	15.1	162



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/23/2026	23:15:00	7.29	0.1893	0	165670.2	16.4	163
6/23/2026	23:30:00	7.29	1.9949	1	165679.1	15.5	162
6/23/2026	23:45:00	7.3	1.9949	0	165709.8	15.2	161
6/24/2026	0:00:00	7.29	0.1741	0	165726.0	16.4	162
6/24/2026	0:15:00	7.3	0.5527	2	165730.6	17.3	165
6/24/2026	0:30:00	7.28	0.2612	2	165742.1	17.7	165
6/24/2026	0:45:00	7.3	2.0403	1	165755.6	15.6	161
6/24/2026	1:00:00	7.28	1.9533	1	165784.3	15.6	164
6/24/2026	1:15:00	7.28	1.8549	1	165810.0	16.1	163
6/24/2026	1:30:00	7.3	2.3091	0	165839.5	14.7	161
6/24/2026	1:45:00	7.31	1.6694	1	165870.3	14.9	163
6/24/2026	2:00:00	7.3	0.0265	1	165897.5	15.2	161
6/24/2026	2:15:00	7.27	0.5413	1	165901.0	16.1	165
6/24/2026	2:30:00	7.31	0.6359	5	165910.5	15.2	161
6/24/2026	2:45:00	7.29	0.3823	2	165925.8	15.6	161
6/24/2026	3:00:00	7.3	2.3507	0	165956.8	14.2	161
6/24/2026	3:15:00	7.29	0.1438	1	165972.7	15.3	161
6/24/2026	3:30:00	7.27	0.3180	1	165976.1	16.1	162
6/24/2026	3:45:00	7.29	2.3924	1	166003.7	14.2	161
6/24/2026	4:00:00	7.3	1.9533	0	166039.1	14.1	162
6/24/2026	4:15:00	7.31	2.3659	0	166072.0	13.9	162
6/24/2026	4:30:00	7.3	0.2158	0	166085.0	15.1	161
6/24/2026	4:45:00	7.3	2.3583	0	166109.0	14	163
6/24/2026	5:00:00	7.3	0.1022	0	166127.8	14.9	161
6/24/2026	5:15:00	7.28	0.2120	0	166131.1	15.6	163
6/24/2026	5:30:00	7.26	0.2196	0	166134.5	16.3	164
6/24/2026	5:45:00	7.28	2.3621	0	166150.0	14.3	161
6/24/2026	6:00:00	7.3	2.2334	0	166184.8	13.9	161
6/24/2026	6:15:00	7.3	2.3545	0	166216.3	13.8	161
6/24/2026	6:30:00	7.31	1.1508	0	166246.0	14.3	161
6/24/2026	6:45:00	7.29	0.1703	0	166249.5	15.1	161
6/24/2026	7:00:00	7.31	0.4580	1	166254.7	14.8	163



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/24/2026	7:15:00	7.31	2.3583	0	166284.4	13.9	161
6/24/2026	7:30:00	7.33	1.6126	0	166315.0	14.2	158
6/24/2026	7:45:00	7.3	0.1968	0	166324.3	15.2	161
6/24/2026	8:00:00	7.3	2.3583	0	166339.9	14.3	160
6/24/2026	8:15:00	7.29	2.3167	0	166373.6	14	160
6/24/2026	8:30:00	7.29	1.6618	0	166405.4	14.6	159
6/24/2026	8:45:00	7.28	2.1993	0	166435.7	14.4	159
6/24/2026	9:00:00	7.28	2.1918	0	166468.4	14.4	160
6/24/2026	9:15:00	7.28	2.1312	0	166496.6	14.6	158
6/24/2026	9:30:00	7.27	0.0946	0	166510.1	16.1	159
6/24/2026	9:45:00	7.25	0.1363	0	166511.3	17.5	160
6/24/2026	10:00:00	7.23	0.1590	0	166514.7	18.7	161
6/24/2026	10:15:00	7.27	1.6656	1	166520.7	18.7	158
6/24/2026	10:30:00	7.24	0.2271	1	166536.1	19.6	164
6/24/2026	10:45:00	7.26	0.2990	0	166552.1	17.6	159
6/24/2026	11:00:00	7.24	0.2574	1	166555.7	18.8	161
6/24/2026	11:15:00	7.25	1.4915	0	166579.4	17.3	159
6/24/2026	11:30:00	7.25	1.8700	0	166595.9	15.6	159
6/24/2026	11:45:00	7.25	2.1123	0	166622.8	15.4	160
6/24/2026	12:00:00	7.24	2.0820	1	166651.6	16.5	161
6/24/2026	12:15:00	7.22	1.1470	0	166675.9	17.5	159
6/24/2026	12:30:00	7.2	0.0189	1	166693.3	19.1	163
6/24/2026	12:45:00	7.18	0.1249	1	166694.8	20.4	163
6/24/2026	13:00:00	7.24	1.9268	0	166712.7	16.5	158
6/24/2026	13:15:00	7.28	0.0379	0	166733.5	16.5	159
6/24/2026	13:30:00	7.26	1.5861	1	166735.5	18.1	163
6/24/2026	13:45:00	7.29	1.9760	1	166763.4	16.8	159
6/24/2026	14:00:00	7.29	1.9684	1	166794.1	16.4	161
6/24/2026	14:15:00	7.29	1.8586	1	166819.6	16	160
6/24/2026	14:30:00	7.29	0.4732	1	166839.3	16.9	161
6/24/2026	14:45:00	7.27	0.9918	1	166847.5	17.5	161
6/24/2026	15:00:00	7.29	0.7722	1	166874.4	16.8	161



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/24/2026	15:15:00	7.28	0.4997	0	166888.1	17.2	162
6/24/2026	15:30:00	7.3	0.9993	1	166914.6	16.6	162
6/24/2026	15:45:00	7.27	0.3634	1	166922.7	18.4	163
6/24/2026	16:00:00	7.31	2.0479	1	166941.8	16.8	161
6/24/2026	16:15:00	7.29	1.6769	1	166958.8	16.7	161
6/24/2026	16:30:00	7.28	0.4391	1	166969.2	17.7	164
6/24/2026	16:45:00	7.25	0.2612	1	166974.9	19.5	165
6/24/2026	17:00:00	7.29	0.5640	3	166978.9	20.1	164
6/24/2026	17:15:00	7.26	2.2183	1	166999.6	16.7	161
6/24/2026	17:30:00	7.27	2.1993	0	167033.1	16.1	162
6/24/2026	17:45:00	7.26	0.4807	1	167045.7	17.2	164
6/24/2026	18:00:00	7.25	0.4164	1	167052.5	18.3	164
6/24/2026	18:15:00	7.24	0.4240	1	167059.2	18.6	165
6/24/2026	18:30:00	7.27	1.2568	1	167075.3	17	160
6/24/2026	18:45:00	7.27	1.2643	1	167096.7	16.4	162
6/24/2026	19:00:00	7.29	2.1160	1	167125.6	15.7	162
6/24/2026	19:15:00	7.3	2.0744	0	167156.2	15.5	163
6/24/2026	19:30:00	7.3	2.0328	0	167182.5	15.4	163
6/24/2026	19:45:00	7.3	1.9722	0	167213.2	15.3	163
6/24/2026	20:00:00	7.29	1.7791	0	167238.2	15.5	161
6/24/2026	20:15:00	7.28	0.3748	0	167249.8	16.5	163
6/24/2026	20:30:00	7.29	1.1243	0	167268.9	15.6	160
6/24/2026	20:45:00	7.29	1.7224	0	167289.9	15.3	161
6/24/2026	21:00:00	7.28	0.1552	1	167301.2	16.3	161
6/24/2026	21:15:00	7.24	0.6852	0	167304.4	17.6	164
6/24/2026	21:30:00	7.28	0.4278	0	167312.4	16.8	160
6/24/2026	21:45:00	7.28	0.4883	1	167318.4	17	160
6/24/2026	22:00:00	7.29	0.9009	1	167325.7	16.1	159
6/24/2026	22:15:00	7.3	1.4990	1	167343.5	15.1	160
6/24/2026	22:30:00	7.29	1.3362	0	167361.4	15	160
6/24/2026	22:45:00	7.28	0.5602	0	167374.6	15.4	162
6/24/2026	23:00:00	7.29	2.2069	1	167385.7	14.9	161



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/24/2026	23:15:00	7.3	1.8208	1	167418.3	14.9	161
6/24/2026	23:30:00	7.3	2.2826	1	167450.6	14.5	162
6/24/2026	23:45:00	7.29	0.1211	1	167466.1	15.8	161
6/25/2026	0:00:00	7.29	1.5520	1	167472.1	16.8	165
6/25/2026	0:15:00	7.25	0.0341	1	167478.1	17.6	163
6/25/2026	0:30:00	7.3	2.2599	1	167490.9	15.1	161
6/25/2026	0:45:00	7.32	2.2599	1	167524.3	14.6	163
6/25/2026	1:00:00	7.32	2.2712	1	167554.5	14.6	162
6/25/2026	1:15:00	7.33	1.0448	1	167584.1	15.2	163
6/25/2026	1:30:00	7.31	0.1060	1	167586.0	16.3	164
6/25/2026	1:45:00	7.31	2.2826	1	167596.2	15	163
6/25/2026	2:00:00	7.34	1.8019	0	167629.5	14.6	163
6/25/2026	2:15:00	7.31	0.1476	1	167642.3	15.6	163
6/25/2026	2:30:00	7.29	0.0454	1	167644.7	16.4	165
6/25/2026	2:45:00	7.3	0.4050	1	167648.0	17	166
6/25/2026	3:00:00	7.33	1.8586	1	167659.0	15.2	163
6/25/2026	3:15:00	7.31	0.2158	1	167670.1	16.1	165
6/25/2026	3:30:00	7.33	2.3091	1	167691.9	14.4	164
6/25/2026	3:45:00	7.33	2.3167	1	167725.6	14.1	164
6/25/2026	4:00:00	7.34	2.2410	1	167758.7	14.1	168
6/25/2026	4:15:00	7.35	2.2334	1	167791.9	14	166
6/25/2026	4:30:00	7.34	0.4845	1	167812.1	14.6	165
6/25/2026	4:45:00	7.33	2.2258	1	167828.0	14.1	165
6/25/2026	5:00:00	7.33	0.7382	1	167855.5	14.3	165
6/25/2026	5:15:00	7.32	0.5262	1	167865.4	14.6	165
6/25/2026	5:30:00	7.31	0.4656	1	167872.1	15.1	166
6/25/2026	5:45:00	7.29	0.8252	1	167879.1	15.6	167
6/25/2026	6:00:00	7.33	1.5709	1	167907.8	14.2	166
6/25/2026	6:15:00	7.33	2.0858	1	167936.4	13.9	165
6/25/2026	6:30:00	7.33	2.0858	1	167966.6	13.9	165
6/25/2026	6:45:00	7.33	2.0441	1	167993.5	13.9	166
6/25/2026	7:00:00	7.33	0.6624	1	168014.9	14.4	165



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/25/2026	7:15:00	7.32	1.0561	1	168024.4	14.6	166
6/25/2026	7:30:00	7.33	1.9571	1	168054.9	14.2	166
6/25/2026	7:45:00	7.33	1.2265	1	168081.0	14.3	163
6/25/2026	8:00:00	7.32	0.6852	1	168099.6	14.5	164
6/25/2026	8:15:00	7.3	0.3180	1	168106.3	15.4	164
6/25/2026	8:30:00	7.28	0.2612	1	168109.8	16.3	165
6/25/2026	8:45:00	7.3	0.7949	1	168118.2	15.5	163
6/25/2026	9:00:00	7.3	0.0265	1	168125.2	15.8	164
6/25/2026	9:15:00	7.27	1.8700	1	168126.2	16.4	166
6/25/2026	9:30:00	7.3	1.0940	1	168149.5	14.9	161
6/25/2026	9:45:00	7.29	1.6959	0	168168.5	14.8	162
6/25/2026	10:00:00	7.27	1.1318	0	168187.1	14.9	162
6/25/2026	10:15:00	7.27	1.4574	0	168204.8	14.9	164
6/25/2026	10:30:00	7.27	1.4725	1	168224.4	14.7	163
6/25/2026	10:45:00	7.27	1.9495	1	168252.9	14.5	163
6/25/2026	11:00:00	7.27	1.5709	1	168281.4	15.5	162
6/25/2026	11:15:00	7.24	1.6542	1	168304.3	16.6	165
6/25/2026	11:30:00	7.27	1.5823	0	168333.0	15.5	162
6/25/2026	11:45:00	7.24	0.1211	0	168348.8	16.6	163
6/25/2026	12:00:00	7.25	0.2461	1	168352.2	17.4	164
6/25/2026	12:15:00	7.27	1.9306	1	168373.9	14.8	163
6/25/2026	12:30:00	7.27	0.5602	1	168394.4	15.1	161
6/25/2026	12:45:00	7.25	0.3028	1	168399.3	16.3	164
6/25/2026	13:00:00	7.27	1.0523	1	168406.7	15.9	161
6/25/2026	13:15:00	7.27	2.0063	0	168437.6	14.6	161
6/25/2026	13:30:00	7.27	0.3255	0	168455.0	15.4	162
6/25/2026	13:45:00	7.25	0.1211	1	168457.3	16.5	164
6/25/2026	14:00:00	7.28	0.4656	1	168465.4	15.8	162
6/25/2026	14:15:00	7.31	1.7261	1	168478.3	15.2	165
6/25/2026	14:30:00	7.3	0.7457	1	168494.4	15.6	164
6/25/2026	14:45:00	7.31	0.7079	1	168511.8	14.9	166
6/25/2026	15:00:00	7.33	0.9085	1	168530.7	15	168



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/25/2026	15:15:00	7.33	0.7344	1	168542.8	15.1	168
6/25/2026	15:30:00	7.33	2.1236	1	168558.4	14.7	167
6/25/2026	15:45:00	7.32	1.6202	1	168585.6	14.8	168
6/25/2026	16:00:00	7.31	0.5981	1	168599.8	15.2	165
6/25/2026	16:15:00	7.31	0.8820	8	168608.1	15.4	167
6/25/2026	16:30:00	7.3	1.4650	1	168622.7	14.8	165
6/25/2026	16:45:00	7.29	0.2461	1	168633.1	15.6	165
6/25/2026	17:00:00	7.3	2.3924	1	168643.3	14.9	164
6/25/2026	17:15:00	7.31	2.5665	1	168678.6	14.6	164
6/25/2026	17:30:00	7.31	2.1955	1	168709.7	14.5	164
6/25/2026	17:45:00	7.31	2.2069	1	168744.9	14.4	162
6/25/2026	18:00:00	7.3	0.2650	1	168761.5	15.5	163
6/25/2026	18:15:00	7.31	0.9464	1	168772.4	15	161
6/25/2026	18:30:00	7.32	0.9199	1	168793.3	15	161
6/25/2026	18:45:00	7.33	2.4529	1	168824.1	14.3	162
6/25/2026	19:00:00	7.34	1.5747	0	168857.1	14.7	161
6/25/2026	19:15:00	7.34	2.0895	0	168887.2	14.4	159
6/25/2026	19:30:00	7.34	1.3514	0	168917.2	14.8	160
6/25/2026	19:45:00	7.32	0.1855	0	168923.1	15.8	161
6/25/2026	20:00:00	7.29	1.2000	1	168926.8	16.5	164
6/25/2026	20:15:00	7.31	1.4801	0	168953.1	15.4	161
6/25/2026	20:30:00	7.31	1.3249	0	168978.6	15.1	159
6/25/2026	20:45:00	7.28	0.2120	1	168984.6	15.8	161
6/25/2026	21:00:00	7.26	0.2271	1	168988.0	16.5	161
6/25/2026	21:15:00	7.3	2.2334	1	169012.8	14.3	159
6/25/2026	21:30:00	7.31	1.2605	0	169043.4	14.4	159
6/25/2026	21:45:00	7.3	0.5527	1	169050.7	15	161
6/25/2026	22:00:00	7.31	2.2410	1	169069.3	14	159
6/25/2026	22:15:00	7.3	0.1817	0	169094.2	14.8	158
6/25/2026	22:30:00	7.28	0.2650	1	169097.6	15.4	161
6/25/2026	22:45:00	7.32	1.6542	0	169119.5	14.5	160
6/25/2026	23:00:00	7.29	0.3369	1	169129.2	15.2	161



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/25/2026	23:15:00	7.27	0.1855	1	169132.8	15.8	161
6/25/2026	23:30:00	7.31	1.9760	1	169159.2	13.8	161
6/25/2026	23:45:00	7.31	1.9684	1	169189.8	13.6	161
6/26/2026	0:00:00	7.3	1.9381	0	169216.3	13.7	161
6/26/2026	0:15:00	7.3	1.2227	0	169244.3	13.7	163
6/26/2026	0:30:00	7.29	0.1552	0	169251.7	14.6	163
6/26/2026	0:45:00	7.29	1.8586	0	169273.5	13.7	161
6/26/2026	1:00:00	7.29	0.4959	1	169291.9	14.1	163
6/26/2026	1:15:00	7.27	0.2158	0	169296.8	14.8	163
6/26/2026	1:30:00	7.25	0.2044	1	169301.3	15.3	163
6/26/2026	1:45:00	7.3	1.6504	1	169313.5	13.9	163
6/26/2026	2:00:00	7.31	1.5558	0	169335.3	13.7	162
6/26/2026	2:15:00	7.31	1.4801	0	169360.6	13.6	163
6/26/2026	2:30:00	7.31	1.1697	0	169379.4	13.8	162
6/26/2026	2:45:00	7.32	1.9419	0	169401.5	13.8	161
6/26/2026	3:00:00	7.31	1.4082	1	169429.8	13.5	162
6/26/2026	3:15:00	7.3	2.1955	1	169458.1	13.3	164
6/26/2026	3:30:00	7.3	0.2725	0	169469.8	14	162
6/26/2026	3:45:00	7.28	0.1931	0	169473.8	14.6	162
6/26/2026	4:00:00	7.29	1.8624	0	169490.4	13.5	163
6/26/2026	4:15:00	7.29	0.9615	0	169515.3	13.5	162
6/26/2026	4:30:00	7.28	0.1968	1	169522.2	14.1	162
6/26/2026	4:45:00	7.3	1.3627	1	169534.2	13.5	161
6/26/2026	5:00:00	7.3	1.8700	0	169561.9	13.3	161
6/26/2026	5:15:00	7.3	2.1918	1	169591.6	13.3	163
6/26/2026	5:30:00	7.3	1.8624	0	169618.6	13.3	161
6/26/2026	5:45:00	7.3	0.3975	0	169634.9	13.7	161
6/26/2026	6:00:00	7.29	2.1955	1	169647.3	13.4	161
6/26/2026	6:15:00	7.27	1.8700	0	169677.6	13.2	162
6/26/2026	6:30:00	7.27	1.5937	0	169706.3	13.3	162
6/26/2026	6:45:00	7.27	0.1287	1	169715.9	13.9	161
6/26/2026	7:00:00	7.29	0.4694	1	169726.1	13.7	161



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/26/2026	7:15:00	7.27	0.2688	1	169730.1	14.5	161
6/26/2026	7:30:00	7.31	2.1804	1	169741.7	13.7	161
6/26/2026	7:45:00	7.32	2.1388	1	169771.3	13.5	161
6/26/2026	8:00:00	7.31	0.7798	1	169793.1	14.1	162
6/26/2026	8:15:00	7.31	1.8776	1	169808.5	14.6	159
6/26/2026	8:30:00	7.3	1.3249	1	169831.7	14.5	159
6/26/2026	8:45:00	7.29	0.9918	1	169847.6	14.5	160
6/26/2026	9:00:00	7.28	0.8782	1	169862.1	15.4	159
6/26/2026	9:15:00	7.29	1.5331	1	169887.9	15.7	158
6/26/2026	9:30:00	7.29	1.5861	1	169910.6	16.3	157
6/26/2026	9:45:00	7.29	1.5596	1	169938.9	17	156
6/26/2026	10:00:00	7.3	0.5110	1	169946.9	18.2	161
6/26/2026	10:15:00	7.28	1.4839	2	169958.0	19.8	156
6/26/2026	10:30:00	7.25	0.4921	2	169965.9	20.2	157
6/26/2026	10:45:00	7.28	1.1697	2	169980.2	21.5	157
6/26/2026	11:00:00	7.29	0.3861	2	169993.8	24.1	162
6/26/2026	11:15:00	7.3	2.2637	1	170023.7	16	156
6/26/2026	11:30:00	7.29	0.2347	1	170041.2	18.8	158
6/26/2026	11:45:00	7.29	2.2675	1	170051.2	16.5	154
6/26/2026	12:00:00	7.3	2.2485	1	170085.2	15.7	158
6/26/2026	12:15:00	7.31	1.6845	1	170116.7	16.7	158
6/26/2026	12:30:00	7.33	2.2183	1	170149.8	15.5	157
6/26/2026	12:45:00	7.3	0.1325	1	170160.8	19.1	159
6/26/2026	13:00:00	7.32	2.1918	1	170175.5	16.1	155
6/26/2026	13:15:00	7.34	2.1955	1	170199.1	15.3	158
6/26/2026	13:30:00	7.36	1.6012	1	170231.0	15.5	159
6/26/2026	13:45:00	7.32	0.5262	1	170242.0	18.4	161
6/26/2026	14:00:00	7.32	0.1552	2	170252.5	20.5	164
6/26/2026	14:15:00	7.3	0.2461	3	170256.0	24.1	164
6/26/2026	14:30:00	7.27	0.3596	2	170260.0	24.9	165
6/26/2026	14:45:00	7.34	1.9873	1	170287.3	15.9	159
6/26/2026	15:00:00	7.33	1.5520	1	170313.2	17	159



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/26/2026	15:15:00	7.31	1.5634	1	170338.0	18.4	162
6/26/2026	15:30:00	7.28	0.1438	1	170346.7	19.5	163
6/26/2026	15:45:00	7.33	1.7375	1	170371.5	14.7	158
6/26/2026	16:00:00	7.33	1.6467	1	170393.3	14.6	160
6/26/2026	16:15:00	7.33	2.2675	1	170426.0	14.3	160
6/26/2026	16:30:00	7.32	2.3659	1	170458.2	14.3	161
6/26/2026	16:45:00	7.35	0.0114	67	170484.0	14.2	161
6/26/2026	17:00:00	7.43	0.1968	725	170503.1	17.6	0
6/26/2026	17:15:00	7.67	0.1855	1	170506.5	19	370
6/26/2026	17:30:00	7.68	0.1401	1	170509.9	19.6	366
6/26/2026	17:45:00	7.32	1.9116	1	170524.1	15.9	162
6/26/2026	18:00:00	7.32	2.2447	1	170555.4	14.5	163
6/26/2026	18:15:00	7.32	2.2372	1	170589.5	14.2	163
6/26/2026	18:30:00	7.31	2.2675	2	170620.6	14.1	165
6/26/2026	18:45:00	7.31	1.3173	1	170651.7	14.5	165
6/26/2026	19:00:00	7.3	0.2461	1	170656.3	15.1	165
6/26/2026	19:15:00	7.29	2.2258	1	170686.7	13.8	166
6/26/2026	19:30:00	7.3	1.8397	0	170720.3	13.8	166
6/26/2026	19:45:00	7.29	0.1022	1	170738.8	14.7	164
6/26/2026	20:00:00	7.28	0.2725	1	170742.1	15.2	166
6/26/2026	20:15:00	7.28	2.2750	1	170768.3	13.7	165
6/26/2026	20:30:00	7.28	2.2523	0	170802.4	13.5	165
6/26/2026	20:45:00	7.28	1.9722	0	170833.7	14	164
6/26/2026	21:00:00	7.29	0.1136	0	170848.2	14.3	162
6/26/2026	21:15:00	7.28	0.2385	1	170851.6	14.8	163
6/26/2026	21:30:00	7.27	0.2461	1	170855.0	15.3	164
6/26/2026	21:45:00	7.28	2.1955	1	170873.2	13.5	162
6/26/2026	22:00:00	7.29	2.2107	1	170904.3	13.3	162
6/26/2026	22:15:00	7.3	2.1918	0	170938.4	13.1	162
6/26/2026	22:30:00	7.29	1.9495	0	170968.8	13.7	160
6/26/2026	22:45:00	7.31	2.1728	0	171002.6	13.1	161
6/26/2026	23:00:00	7.31	0.3558	0	171015.5	14.1	161



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/26/2026	23:15:00	7.3	0.2120	1	171019.5	14.5	161
6/26/2026	23:30:00	7.3	1.5331	2	171038.1	14.8	161
6/26/2026	23:45:00	7.28	1.5066	1	171060.7	15.1	161
6/27/2026	0:00:00	7.29	2.0782	0	171089.5	13.2	158
6/27/2026	0:15:00	7.31	1.5369	1	171118.7	13.7	158
6/27/2026	0:30:00	7.3	1.8813	0	171142.8	13.6	159
6/27/2026	0:45:00	7.32	1.7791	0	171168.9	13.9	159
6/27/2026	1:00:00	7.3	1.5066	0	171191.7	14.2	159
6/27/2026	1:15:00	7.3	0.1741	0	171203.9	14.4	160
6/27/2026	1:30:00	7.3	1.1735	1	171208.3	14.2	158
6/27/2026	1:45:00	7.33	1.5937	1	171232.3	13.8	160
6/27/2026	2:00:00	7.32	0.2915	1	171248.0	14.1	161
6/27/2026	2:15:00	7.31	0.9880	1	171265.0	14	160
6/27/2026	2:30:00	7.34	1.5785	1	171272.0	13.5	160
6/27/2026	2:45:00	7.31	0.7609	1	171286.0	13.7	161
6/27/2026	3:00:00	7.35	0.9615	2	171292.3	13.4	161
6/27/2026	3:30:00	7.31	0.0341	3	171306.5	12.8	161
6/27/2026	3:45:00	7.3	2.3318	1	171320.1	12.5	165
6/27/2026	4:00:00	7.28	2.1955	1	171351.3	12.4	165
6/27/2026	4:15:00	7.29	1.9306	0	171381.8	12.4	164
6/27/2026	4:30:00	7.29	1.8889	1	171406.8	12.4	163
6/27/2026	4:45:00	7.29	0.3558	0	171425.1	12.8	161
6/27/2026	5:00:00	7.28	0.0908	1	171426.7	13.4	160
6/27/2026	5:15:00	7.27	0.2915	0	171428.4	13.7	161
6/27/2026	5:30:00	7.29	1.9533	0	171454.4	12.6	163
6/27/2026	5:45:00	7.29	2.2485	1	171482.0	12.6	163
6/27/2026	6:00:00	7.29	2.2523	1	171514.1	12.5	163
6/27/2026	6:15:00	7.3	0.8934	0	171541.7	12.6	163
6/27/2026	6:30:00	7.3	0.3975	1	171549.8	13.1	161
6/27/2026	6:45:00	7.3	1.5293	0	171570.1	12.5	162
6/27/2026	7:00:00	7.29	2.2523	1	171600.2	12.5	162
6/27/2026	7:15:00	7.29	0.8820	0	171614.5	12.8	161



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/27/2026	7:30:00	7.28	2.1047	1	171643.4	12.6	163
6/27/2026	7:45:00	7.28	0.5640	1	171666.5	13.1	159
6/27/2026	8:00:00	7.27	0.1287	0	171669.9	14	160
6/27/2026	8:15:00	7.28	0.7987	4	171676.6	14.2	161
6/27/2026	8:30:00	7.27	1.7678	1	171688.9	14.1	161
6/27/2026	8:45:00	7.28	1.6694	1	171712.1	14	160
6/27/2026	9:00:00	7.29	1.4157	1	171734.1	14.2	161
6/27/2026	9:15:00	7.28	1.3930	1	171757.8	15.5	161
6/27/2026	9:30:00	7.25	2.1577	2	171771.7	17.5	167
6/27/2026	9:45:00	7.23	0.7306	1	171782.2	18.9	170
6/27/2026	10:00:00	7.24	1.9836	1	171806.6	15.9	181
6/27/2026	10:15:00	7.23	1.7754	1	171836.0	15.4	185
6/27/2026	10:30:00	7.22	1.5179	1	171860.7	16.8	186
6/27/2026	10:45:00	7.2	1.4915	1	171884.2	18.8	188
6/27/2026	11:00:00	7.22	1.5293	1	171903.6	18.2	182
6/27/2026	11:15:00	7.25	2.1993	1	171932.1	14.8	175
6/27/2026	11:30:00	7.25	0.1098	1	171955.5	16.2	176
6/27/2026	11:45:00	7.23	1.0826	1	171966.4	17.2	177
6/27/2026	12:00:00	7.27	1.8132	1	171983.9	16.4	172
6/27/2026	12:15:00	7.27	0.0114	1	172001.9	16.9	172
6/27/2026	12:30:00	7.27	2.1804	2	172015.0	15.2	170
6/27/2026	12:45:00	7.27	2.2183	1	172049.1	14.9	166
6/27/2026	13:00:00	7.27	2.1236	1	172083.0	14.9	167
6/27/2026	13:15:00	7.27	2.1615	1	172115.8	14.9	165
6/27/2026	13:30:00	7.26	0.2990	1	172131.3	16.8	165
6/27/2026	13:45:00	7.26	1.8435	1	172145.0	15.2	165
6/27/2026	14:00:00	7.28	1.2113	4	172163.6	15.2	163
6/27/2026	14:15:00	7.26	1.9457	1	172187.0	15.1	164
6/27/2026	14:30:00	7.28	1.1243	2	172204.2	15.2	162
6/27/2026	14:45:00	7.28	1.7526	1	172226.7	15.1	161
6/27/2026	15:00:00	7.31	1.3135	6	172249.0	15.4	160
6/27/2026	15:15:00	7.31	1.2795	5	172258.3	15.3	161



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/27/2026	15:30:00	7.28	1.1697	2	172277.9	15.9	160
6/27/2026	15:45:00	7.28	1.3287	4	172293.8	15.9	160
6/27/2026	16:00:00	7.3	1.8321	2	172318.0	15.5	160
6/27/2026	16:15:00	7.28	0.2385	1	172336.1	16.7	160
6/27/2026	16:30:00	7.31	0.8176	3	172346.4	17.4	162
6/27/2026	16:45:00	7.27	0.9501	4	172358.8	17	161
6/27/2026	17:00:00	7.26	0.0189	4	172374.2	17.3	161
6/27/2026	17:15:00	7.27	2.1388	1	172397.3	15.4	157
6/27/2026	17:30:00	7.27	2.3886	1	172429.4	15	158
6/27/2026	17:45:00	7.29	1.5709	1	172462.7	15.5	160
6/27/2026	18:00:00	7.27	0.2233	2	172470.5	16.7	160
6/27/2026	18:15:00	7.27	2.4492	2	172496.2	15.4	159
6/27/2026	18:30:00	7.28	2.4037	2	172533.6	15	159
6/27/2026	18:45:00	7.28	0.0189	1	172559.1	15.8	160
6/27/2026	19:00:00	7.25	0.2763	2	172559.8	17	162
6/27/2026	19:15:00	7.28	2.1123	2	172576.5	17	161
6/27/2026	19:30:00	7.27	2.1236	1	172609.5	15.1	159
6/27/2026	19:45:00	7.27	2.1047	1	172640.2	14.8	160
6/27/2026	20:00:00	7.25	0.0000	1	172664.5	15.5	161
6/27/2026	20:15:00	7.24	0.1703	1	172666.7	16.3	161
6/27/2026	20:30:00	7.23	1.3968	1	172676.9	16.9	162
6/27/2026	20:45:00	7.21	0.9993	2	172696.9	17.3	162
6/27/2026	21:00:00	7.25	2.3697	1	172719.4	14.7	158
6/27/2026	21:15:00	7.25	1.3098	1	172748.9	14.7	160
6/27/2026	21:30:00	7.23	0.2196	1	172751.3	15.3	161
6/27/2026	21:45:00	7.24	2.2069	2	172759.1	15.2	163
6/27/2026	22:00:00	7.26	2.0517	1	172790.3	14.2	165
6/27/2026	22:15:00	7.27	1.5407	1	172820.1	14.4	166
6/27/2026	22:30:00	7.26	1.8700	2	172846.2	14.5	166
6/27/2026	22:45:00	7.25	1.7261	2	172873.4	14.9	166
6/27/2026	23:00:00	7.23	0.0871	2	172886.8	15.4	167
6/27/2026	23:15:00	7.26	1.8397	1	172899.6	14.8	168



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/27/2026	23:30:00	7.23	2.3129	2	172927.8	14.5	167
6/27/2026	23:45:00	7.21	2.1804	2	172960.6	14	168
6/28/2026	0:00:00	7.21	1.3476	2	172985.5	14.5	169
6/28/2026	0:15:00	7.2	0.0833	2	172992.8	15	170
6/28/2026	0:30:00	7.18	0.2801	2	172995.5	15.4	170
6/28/2026	0:45:00	7.18	0.3672	2	172999.7	15.6	171
6/28/2026	1:00:00	7.21	1.9571	2	173013.0	14.4	169
6/28/2026	1:15:00	7.22	2.1463	2	173044.1	13.9	167
6/28/2026	1:30:00	7.21	1.1432	2	173065.9	14.3	167
6/28/2026	1:45:00	7.19	1.2454	1	173081.4	14.6	168
6/28/2026	2:00:00	7.22	2.0366	2	173093.9	13.8	167
6/28/2026	2:15:00	7.22	0.1401	2	173117.1	14.1	167
6/28/2026	2:30:00	7.21	0.1022	2	173120.1	14.4	168
6/28/2026	2:45:00	7.24	1.6656	2	173131.0	14	169
6/28/2026	3:00:00	7.23	2.1425	2	173159.7	13.6	166
6/28/2026	3:15:00	7.22	1.9873	2	173190.4	13.6	167
6/28/2026	3:30:00	7.21	1.4990	1	173216.2	13.9	167
6/28/2026	3:45:00	7.21	1.5293	2	173240.0	14.3	167
6/28/2026	4:00:00	7.2	0.1552	2	173258.0	14.6	168
6/28/2026	4:15:00	7.19	0.2082	1	173261.4	14.8	167
6/28/2026	4:30:00	7.16	1.5293	1	173269.4	15	168
6/28/2026	4:45:00	7.21	2.3242	2	173289.5	14.5	165
6/28/2026	5:00:00	7.21	2.2069	2	173322.0	13.5	166
6/28/2026	5:15:00	7.21	0.8858	2	173349.0	13.6	166
6/28/2026	5:30:00	7.2	0.1931	2	173351.8	13.9	167
6/28/2026	5:45:00	7.21	2.1577	2	173366.6	13.3	168
6/28/2026	6:00:00	7.21	2.5362	2	173404.0	13.2	168
6/28/2026	6:15:00	7.21	2.1577	2	173441.4	13.2	168
6/28/2026	6:30:00	7.22	1.4915	2	173473.6	13.5	167
6/28/2026	6:45:00	7.2	1.5407	2	173487.1	13.8	167
6/28/2026	7:00:00	7.19	0.0189	2	173503.7	14.3	168
6/28/2026	7:15:00	7.18	0.2233	2	173506.3	14.9	170



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/28/2026	7:30:00	7.22	0.7495	4	173516.6	15.2	170
6/28/2026	7:45:00	7.22	0.7609	2	173526.8	15.8	171
6/28/2026	8:00:00	7.22	1.9495	2	173552.2	14.7	166
6/28/2026	8:15:00	7.23	1.3211	2	173578.8	14.4	168
6/28/2026	8:30:00	7.22	1.6202	2	173600.1	14.8	167
6/28/2026	8:45:00	7.22	0.0341	2	173614.5	16.8	170
6/28/2026	9:00:00	7.24	1.7413	3	173620.9	17.4	168
6/28/2026	9:15:00	7.21	0.8025	2	173637.9	16	168
6/28/2026	9:30:00	7.19	2.4340	2	173657.3	15.1	168
6/28/2026	9:45:00	7.18	2.4113	2	173693.3	14.8	167
6/28/2026	10:00:00	7.18	0.2158	2	173708.6	16.5	169
6/28/2026	10:15:00	7.21	2.5173	2	173734.6	15.2	168
6/28/2026	10:30:00	7.2	0.6095	2	173745.1	17.2	168
6/28/2026	10:45:00	7.19	2.4946	3	173758.8	17	165
6/28/2026	11:00:00	7.21	1.4233	2	173790.4	16.2	169
6/28/2026	11:15:00	7.21	2.4454	2	173804.5	15.9	169
6/28/2026	11:30:00	7.23	2.3318	2	173840.5	15.2	169
6/28/2026	11:45:00	7.22	2.1918	2	173870.4	15.6	168
6/28/2026	12:00:00	7.21	0.1060	2	173889.9	17.7	169
6/28/2026	12:15:00	7.19	0.1741	2	173892.5	19.2	171
6/28/2026	12:30:00	7.18	1.5293	2	173904.4	19.3	171
6/28/2026	12:45:00	7.17	0.1173	2	173915.2	20	173
6/28/2026	13:00:00	7.16	0.1287	2	173918.3	20.5	172
6/28/2026	13:15:00	7.15	1.6050	2	173927.1	20.7	172
6/28/2026	13:30:00	7.2	2.3886	2	173956.7	16.4	165
6/28/2026	13:45:00	7.19	2.2220	2	173991.0	15.4	168
6/28/2026	14:00:00	7.18	0.1060	2	174009.1	16.3	168
6/28/2026	14:15:00	7.17	0.0265	2	174010.9	17.4	169
6/28/2026	14:30:00	7.21	0.5110	5	174017.0	17.5	173
6/28/2026	14:45:00	7.19	2.1690	2	174041.5	15.5	167
6/28/2026	15:00:00	7.2	2.1539	2	174075.0	15.1	168
6/28/2026	15:15:00	7.2	0.8063	2	174097.7	15.5	168



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/28/2026	15:30:00	7.21	2.1198	2	174116.2	15.3	168
6/28/2026	15:45:00	7.21	0.2725	2	174130.3	16.1	167
6/28/2026	16:00:00	7.19	0.1968	2	174133.7	17.2	167
6/28/2026	16:15:00	7.18	0.1855	2	174136.0	18.2	170
6/28/2026	16:30:00	7.16	0.0303	2	174136.5	19	171
6/28/2026	16:45:00	7.2	1.8094	2	174146.6	16.7	165
6/28/2026	17:00:00	7.21	2.1653	2	174178.0	15.6	168
6/28/2026	17:15:00	7.21	2.1274	2	174209.5	15.5	170
6/28/2026	17:30:00	7.21	0.1325	2	174221.6	16.5	170
6/28/2026	17:45:00	7.19	0.1855	2	174224.2	17.6	170
6/28/2026	18:00:00	7.2	1.9608	2	174232.8	17.3	168
6/28/2026	18:15:00	7.21	2.1312	2	174266.6	15.7	168
6/28/2026	18:30:00	7.21	0.9653	2	174287.3	15.9	169
6/28/2026	18:45:00	7.21	2.3167	2	174314.6	15.4	169
6/28/2026	19:00:00	7.21	0.6852	2	174340.0	15.6	170
6/28/2026	19:15:00	7.2	0.6587	2	174343.6	16.5	169
6/28/2026	19:30:00	7.2	1.9533	2	174371.2	15.3	168
6/28/2026	19:45:00	7.19	1.8700	2	174395.8	15.1	168
6/28/2026	20:00:00	7.19	1.7451	2	174421.5	14.9	166
6/28/2026	20:15:00	7.19	2.1160	2	174442.4	14.8	168
6/28/2026	20:30:00	7.21	0.6700	2	174464.1	15	167
6/28/2026	20:45:00	7.19	0.4883	2	174466.9	15.8	168
6/28/2026	21:00:00	7.18	0.3407	2	174473.2	16.6	167
6/28/2026	21:15:00	7.17	0.4807	2	174479.9	17.2	168
6/28/2026	21:30:00	7.13	0.4694	2	174486.7	17.5	168
6/28/2026	21:45:00	7.19	1.3400	8	174493.9	15.4	164
6/28/2026	22:00:00	7.21	1.0675	4	174510.6	15.6	168
6/28/2026	22:15:00	7.23	1.6353	3	174526.7	15.4	168
6/28/2026	22:30:00	7.21	1.9608	3	174546.3	15.7	168
6/28/2026	22:45:00	7.18	2.2220	2	174580.4	14.4	168
6/28/2026	23:00:00	7.17	2.1425	2	174612.1	14.3	169
6/28/2026	23:15:00	7.19	1.3930	2	174641.5	14.6	168

		Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope	
Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/28/2026	23:30:00	7.17	0.2233	2	174646.5	15.2	169
6/28/2026	23:45:00	7.19	0.5110	7	174651.2	15.5	172

5. In-Situ Readings

Table 4. In-Situ Readings

Date	Temperature (C°)	DO mg/L	SAL-ppt	pH	ORP (mV)	NTU
06/22/2026	14.5	9.72	0.09	7.12	166.8	3.07
06/23/2026	15.2	9.78	0.09	7.21	161.3	0.75
06/24/2026	13.9	10.11	0.09	7.18	159.9	0.99
06/25/2026	15.7	10.05	0.10	7.23	163.7	1.03
06/26/2026	13.4	9.90	0.09	7.30	168.1	1.11
06/27/2026	16.4	9.81	0.09	7.18	171.1	0.74
06/28/2026	15.0	9.97	0.09	7.38	160.3	1.70

6. Calibration Log:

Table 5. Calibration Log

Date	Unit	pH	Conductivity/ Salinity	NTU
06/26/2026	YSI	✓	✓	✓
06/26/2026	Portal WTP	✓	N/A	✓
06/26/2026	CP2 WTP	✓	✓	✓

		Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope	
Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: BC1 Approved by: BC2 Date: July 16, 2026	

APPENDIX A: Portal WTP Data Log



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Valve Status	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/22/2026	0:00:00	7.7	0.0000	3.1	1,380,745	Closed	15.2	288
6/22/2026	0:15:00	7.7	0.0000	1.8	1,380,747	Closed	15.2	288
6/22/2026	0:30:00	7.6	0.0000	2.1	1,380,747	Closed	15.6	289
6/22/2026	0:45:00	7.7	1.2833	1.9	1,380,755	Open	15.1	291
6/22/2026	1:00:00	7.7	0.0000	1	1,380,766	Closed	15.5	291
6/22/2026	1:15:00	7.7	0.0000	0.5	1,380,770	Closed	15.5	288
6/22/2026	1:30:00	7.6	1.2908	0	1,380,787	Open	15.7	289
6/22/2026	1:45:00	7.6	0.0000	0	1,380,788	Closed	17.1	291
6/22/2026	2:00:00	7.6	1.2833	0	1,380,788	Open	19.3	292
6/22/2026	2:15:00	7.6	0.0000	0	1,380,799	Closed	16.8	291
6/22/2026	2:30:00	7.6	1.2681	0	1,380,817	Open	16.1	290
6/22/2026	2:45:00	7.6	1.2795	0	1,380,821	Open	16.8	287
6/22/2026	3:00:00	7.6	1.4309	0.5	1,380,835	Open	15.9	290
6/22/2026	3:15:00	7.5	0.1893	1	1,380,836	Open	16.6	289
6/22/2026	3:30:00	7.6	1.4498	1	1,380,854	Open	15.4	291
6/22/2026	3:45:00	7.6	0.0000	1	1,380,871	Closed	15.3	291
6/22/2026	4:00:00	7.6	1.4309	1.2	1,380,885	Open	15.1	291
6/22/2026	4:15:00	7.6	0.0000	1.5	1,380,896	Closed	15.1	291
6/22/2026	4:30:00	7.6	1.4385	1.2	1,380,916	Open	14.8	286
6/22/2026	4:45:00	7.6	1.4498	1.2	1,380,925	Open	15	284
6/22/2026	5:00:00	7.6	0.0000	0.5	1,380,945	Closed	14.6	281
6/22/2026	5:15:00	7.5	0.0000	0.6	1,380,945	Closed	15.1	281
6/22/2026	5:30:00	7.6	1.4157	0.7	1,380,954	Open	14.6	279
6/22/2026	5:45:00	7.5	0.0000	0.9	1,380,963	Closed	14.7	278
6/22/2026	6:00:00	7.6	1.3930	1.4	1,380,972	Open	14.5	278
6/22/2026	6:15:00	7.5	0.0000	1.5	1,380,981	Closed	14.6	278
6/22/2026	6:30:00	7.6	1.3590	2.1	1,380,993	Open	14.3	278
6/22/2026	6:45:00	7.5	0.0000	2.2	1,380,997	Closed	14.6	278
6/22/2026	7:00:00	7.5	0.0000	2.6	1,381,014	Closed	14.2	278
6/22/2026	7:15:00	7.5	1.3400	1.7	1,381,015	Open	14.6	279
6/22/2026	7:30:00	7.5	1.3098	2.1	1,381,035	Open	14.1	279
6/22/2026	7:45:00	7.5	1.2151	2	1,381,036	Closed	14.4	279



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Valve Status	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/22/2026	8:00:00	7.5	0.0000	2.5	1,381,052	Closed	14.1	279
6/22/2026	8:15:00	7.5	1.3211	2.2	1,381,055	Open	14.3	279
6/22/2026	8:30:00	7.5	1.2681	2.3	1,381,074	Open	14.1	279
6/22/2026	8:45:00	7.5	1.2870	2.4	1,381,077	Open	14.5	279
6/22/2026	9:00:00	7.5	0.0000	2.4	1,381,093	Closed	14.3	279
6/22/2026	9:15:00	7.5	1.0069	3.1	1,381,097	Open	14.4	279
6/22/2026	9:30:00	7.5	0.0000	3.5	1,381,107	Closed	14.5	279
6/22/2026	9:45:00	7.4	0.0000	3.4	1,381,107	Closed	15.1	280
6/22/2026	10:00:00	7.5	0.0000	4.5	1,381,121	Closed	14.5	279
6/22/2026	10:15:00	7.5	0.5830	15.6	1,381,123	Open	14.8	278
6/22/2026	10:30:00	7.5	0.0000	8.9	1,381,127	Closed	14.8	278
6/22/2026	10:45:00	7.5	1.0221	3.7	1,381,139	Open	14.8	278
6/22/2026	11:00:00	7.5	1.3665	2.9	1,381,143	Open	15.1	278
6/22/2026	11:15:00	7.5	0.0000	2.4	1,381,154	Closed	15.2	279
6/22/2026	11:30:00	7.5	1.4460	1.4	1,381,165	Open	15.2	278
6/22/2026	11:45:00	7.5	0.0000	1.1	1,381,173	Closed	15.6	279
6/22/2026	12:00:00	7.5	0.0000	0.2	1,381,189	Closed	15.6	279
6/22/2026	12:15:00	7.5	0.0000	0.2	1,381,189	Closed	16.2	278
6/22/2026	12:30:00	7.5	0.0000	0	1,381,196	Closed	16.1	278
6/22/2026	12:45:00	7.5	1.4233	0	1,381,212	Open	15.8	278
6/22/2026	13:00:00	7.5	0.0000	0	1,381,212	Closed	16.3	278
6/22/2026	13:15:00	7.5	1.4385	0	1,381,226	Open	16	276
6/22/2026	13:30:00	7.5	0.0000	0	1,381,229	Closed	16.4	276
6/22/2026	13:45:00	7.6	0.8593	4.9	1,381,237	Open	16	276
6/22/2026	14:00:00	7.6	0.6473	3.1	1,381,241	Open	16.1	277
6/22/2026	14:15:00	7.5	0.0000	0	1,381,250	Closed	16.4	277
6/22/2026	14:30:00	7.5	0.0000	0	1,381,255	Closed	16.8	278
6/22/2026	14:45:00	7.5	1.5142	0	1,381,269	Open	16.3	276
6/22/2026	15:00:00	7.5	0.0000	0	1,381,272	Closed	16.6	276
6/22/2026	15:15:00	7.5	1.5104	0	1,381,286	Open	16.3	274
6/22/2026	15:30:00	7.5	0.0000	0	1,381,287	Closed	16.7	274
6/22/2026	15:45:00	7.5	1.4650	0	1,381,297	Open	16.5	273



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Valve Status	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/22/2026	16:00:00	7.5	0.0000	2.1	1,381,303	Closed	16.6	272
6/22/2026	16:15:00	7.5	1.4460	0	1,381,310	Open	16.4	270
6/22/2026	16:30:00	7.5	0.0000	0	1,381,315	Closed	16.7	273
6/22/2026	16:45:00	7.5	0.0000	0	1,381,330	Closed	16.4	270
6/22/2026	17:00:00	7.5	0.0000	0	1,381,330	Closed	17.1	270
6/22/2026	17:15:00	7.5	0.0000	0	1,381,343	Closed	16.4	268
6/22/2026	17:30:00	7.5	1.4498	0	1,381,343	Open	17.1	270
6/22/2026	17:45:00	7.5	0.0000	0	1,381,359	Closed	16.3	267
6/22/2026	18:00:00	7.5	0.0000	0	1,381,359	Closed	16.9	270
6/22/2026	18:15:00	7.5	0.0000	1.5	1,381,366	Closed	16.1	265
6/22/2026	18:30:00	7.6	0.0000	1.9	1,381,370	Closed	16	265
6/22/2026	18:45:00	7.6	1.9911	2.8	1,381,381	Open	15.9	267
6/22/2026	19:00:00	7.5	0.0000	0	1,381,391	Closed	16.3	268
6/22/2026	19:15:00	7.5	1.4650	0.3	1,381,410	Open	16	265
6/22/2026	19:30:00	7.5	0.0000	0.2	1,381,417	Closed	16.4	268
6/22/2026	19:45:00	7.5	0.0000	0.3	1,381,432	Closed	16.2	265
6/22/2026	20:00:00	7.5	0.0000	0.2	1,381,432	Closed	16.7	268
6/22/2026	20:15:00	7.5	0.0000	0.2	1,381,447	Closed	16.2	268
6/22/2026	20:30:00	7.5	1.3817	0.5	1,381,451	Open	16.4	268
6/22/2026	20:45:00	7.5	0.0000	4.6	1,381,466	Closed	16.3	268
6/22/2026	21:00:00	7.5	0.0000	0.4	1,381,466	Closed	16.6	268
6/22/2026	21:15:00	7.5	0.0000	0	1,381,479	Closed	16.2	268
6/22/2026	21:30:00	7.5	0.0000	0.1	1,381,479	Closed	16.8	267
6/22/2026	21:45:00	7.5	1.1962	0	1,381,488	Open	16.3	270
6/22/2026	22:00:00	7.5	0.0000	0.1	1,381,497	Closed	16.8	270
6/22/2026	22:15:00	7.5	1.1886	0.1	1,381,506	Open	16.4	273
6/22/2026	22:30:00	7.5	0.0000	1.7	1,381,516	Closed	16.1	278
6/22/2026	22:45:00	7.5	0.0000	1.7	1,381,516	Closed	16.8	279
6/22/2026	23:00:00	7.6	0.0000	0.3	1,381,531	Closed	16.3	284
6/22/2026	23:15:00	7.5	0.0000	0	1,381,531	Closed	17	284
6/22/2026	23:30:00	7.5	0.0000	0.7	1,381,538	Closed	17.2	282
6/22/2026	23:45:00	7.7	0.0000	6.3	1,381,538	Open	16.8	291



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Valve Status	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/23/2026	0:00:00	7.6	1.4271	0.1	1,381,545	Open	16.8	290
6/23/2026	0:15:00	7.6	0.0000	0.2	1,381,555	Closed	16.9	291
6/23/2026	0:30:00	7.6	0.0000	0.5	1,381,567	Closed	16.6	294
6/23/2026	0:45:00	7.6	1.4385	0.6	1,381,572	Open	16.5	297
6/23/2026	1:00:00	7.6	0.0000	0.1	1,381,585	Closed	16.5	299
6/23/2026	1:15:00	7.6	0.0000	0	1,381,585	Closed	17.2	302
6/23/2026	1:30:00	7.6	0.0000	1.6	1,381,593	Closed	16.9	304
6/23/2026	1:45:00	7.6	1.4422	0.5	1,381,605	Open	16.5	305
6/23/2026	2:00:00	7.6	0.0000	0	1,381,614	Closed	16.7	307
6/23/2026	2:15:00	7.7	1.4574	0.1	1,381,627	Open	16.4	307
6/23/2026	2:30:00	7.7	1.4915	1.2	1,381,635	Open	16.7	309
6/23/2026	2:45:00	7.7	1.4309	0	1,381,657	Open	16	302
6/23/2026	3:00:00	7.8	0.0000	0.9	1,381,661	Open	15.8	299
6/23/2026	3:15:00	7.7	1.2000	0.1	1,381,663	Closed	16	293
6/23/2026	3:30:00	7.6	1.4044	1.5	1,381,683	Open	15.4	286
6/23/2026	3:45:00	7.6	1.3968	1.2	1,381,704	Open	15.2	286
6/23/2026	4:00:00	7.6	0.0000	1.5	1,381,722	Closed	15.2	286
6/23/2026	4:15:00	7.6	1.3779	3.7	1,381,731	Open	15.1	284
6/23/2026	4:30:00	7.5	0.0000	3.2	1,381,741	Closed	15.3	286
6/23/2026	4:45:00	7.5	1.3665	6	1,381,756	Open	15	286
6/23/2026	5:00:00	7.5	0.8706	8.1	1,381,761	Open	15.3	286
6/23/2026	5:15:00	7.5	1.3476	13.5	1,381,780	Open	14.8	281
6/23/2026	5:30:00	7.5	0.0000	5.3	1,381,796	Closed	14.7	279
6/23/2026	5:45:00	7.4	1.3135	5.4	1,381,802	Open	14.7	281
6/23/2026	6:00:00	7.4	0.0000	3.6	1,381,815	Closed	14.7	279
6/23/2026	6:15:00	7.4	1.3249	6	1,381,826	Open	14.6	278
6/23/2026	6:30:00	7.4	0.0000	3.1	1,381,834	Closed	14.8	277
6/23/2026	6:45:00	7.4	0.0000	2	1,381,851	Closed	14.4	274
6/23/2026	7:00:00	7.4	0.0000	68.6	1,381,855	Closed	14.4	272
6/23/2026	7:15:00	7.4	0.7760	3.2	1,381,861	Open	14.6	272
6/23/2026	7:30:00	7.5	1.2757	1.1	1,381,879	Open	14.4	270
6/23/2026	7:45:00	7.5	0.0000	0.8	1,381,896	Closed	14.4	269



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Valve Status	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/23/2026	8:00:00	7.5	1.2681	1.8	1,381,899	Open	14.6	272
6/23/2026	8:15:00	7.5	0.0000	1	1,381,916	Closed	14.7	268
6/23/2026	8:30:00	7.5	1.2757	0.8	1,381,924	Open	14.6	268
6/23/2026	8:45:00	7.5	0.0000	4.9	1,381,936	Closed	14.5	265
6/23/2026	9:00:00	7.5	1.1016	5.7	1,381,936	Open	15.2	265
6/23/2026	9:15:00	7.5	0.0000	4	1,381,951	Closed	14.5	267
6/23/2026	9:30:00	7.5	1.3703	0.6	1,381,960	Open	14.6	267
6/23/2026	9:45:00	7.5	0.0000	0	1,381,975	Closed	14.9	267
6/23/2026	10:00:00	7.5	1.3552	0.2	1,381,987	Open	14.9	267
6/23/2026	10:15:00	7.4	0.0000	0.5	1,382,002	Closed	15.1	268
6/23/2026	10:30:00	7.5	1.2946	1.9	1,382,012	Open	15	268
6/23/2026	10:45:00	7.4	0.0000	2.2	1,382,026	Closed	15.2	270
6/23/2026	11:00:00	7.4	0.0000	2	1,382,026	Closed	15.8	272
6/23/2026	11:15:00	7.4	0.0000	3.8	1,382,037	Closed	15.6	275
6/23/2026	11:30:00	7.4	1.2416	3.6	1,382,045	Open	15.5	275
6/23/2026	11:45:00	7.4	0.0000	6	1,382,060	Closed	15.8	276
6/23/2026	12:00:00	7.4	1.2265	2.7	1,382,070	Open	15.7	278
6/23/2026	12:15:00	7.4	0.0000	2.5	1,382,086	Closed	16.1	278
6/23/2026	12:30:00	7.4	1.2189	0.6	1,382,092	Open	16	276
6/23/2026	12:45:00	7.4	0.0000	0	1,382,106	Closed	16.2	276
6/23/2026	13:00:00	7.4	0.0000	0	1,382,106	Closed	16.8	276
6/23/2026	13:15:00	7.5	0.3823	0	1,382,112	Open	16.3	279
6/23/2026	13:30:00	7.4	1.1962	0	1,382,116	Open	16.6	281
6/23/2026	13:45:00	7.4	0.4845	0	1,382,127	Open	16.7	281
6/23/2026	14:00:00	7.5	1.2378	0	1,382,137	Open	16.7	283
6/23/2026	14:15:00	7.4	0.7495	0	1,382,153	Open	16.9	283
6/23/2026	14:30:00	7.4	1.2416	0.6	1,382,160	Open	17.4	283
6/23/2026	14:45:00	7.5	0.0000	0	1,382,175	Closed	17	281
6/23/2026	15:00:00	7.5	0.4013	2.1	1,382,181	Open	16.5	281
6/23/2026	15:15:00	7.5	0.0000	0	1,382,188	Closed	16.8	282
6/23/2026	15:30:00	7.5	1.3779	0.4	1,382,205	Open	16.6	283
6/23/2026	15:45:00	7.5	0.0000	0.7	1,382,219	Closed	16.8	280



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Valve Status	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/23/2026	16:00:00	7.5	1.3476	0.4	1,382,235	Open	16.5	279
6/23/2026	16:15:00	7.4	0.0000	0	1,382,241	Closed	16.8	280
6/23/2026	16:30:00	7.4	1.3135	0.5	1,382,249	Open	16.6	280
6/23/2026	16:45:00	7.4	0.0000	0.6	1,382,258	Closed	16.8	280
6/23/2026	17:00:00	7.5	1.3060	1	1,382,275	Open	16.6	280
6/23/2026	17:15:00	7.4	0.0000	1.4	1,382,286	Closed	16.8	279
6/23/2026	17:30:00	7.5	1.2681	1.9	1,382,299	Open	16.6	282
6/23/2026	17:45:00	7.4	0.0000	2.6	1,382,313	Closed	16.9	282
6/23/2026	18:00:00	7.4	1.3400	0.6	1,382,319	Open	16.8	282
6/23/2026	18:15:00	7.4	0.0000	0	1,382,331	Closed	16.8	282
6/23/2026	18:30:00	7.4	1.3287	0	1,382,343	Open	16.6	282
6/23/2026	18:45:00	7.4	0.0000	0	1,382,349	Closed	16.8	280
6/23/2026	19:00:00	7.4	1.3211	0	1,382,366	Open	16.3	280
6/23/2026	19:15:00	7.4	1.3627	1.6	1,382,368	Open	17	278
6/23/2026	19:30:00	7.4	0.8328	12.6	1,382,371	Open	15.9	272
6/23/2026	19:45:00	7.4	0.0606	0	1,382,386	Closed	15.9	281
6/23/2026	20:00:00	7.4	0.0000	11.9	1,382,395	Open	15.6	283
6/23/2026	20:15:00	7.4	1.5444	4	1,382,399	Open	15.6	286
6/23/2026	20:30:00	7.4	0.0000	2.6	1,382,419	Closed	15.7	286
6/23/2026	20:45:00	7.4	1.5104	2.5	1,382,426	Open	15.7	284
6/23/2026	21:00:00	7.4	1.4801	2.6	1,382,449	Open	15.8	284
6/23/2026	21:15:00	7.4	0.0000	3.1	1,382,459	Closed	16.1	286
6/23/2026	21:30:00	7.5	1.4612	3.7	1,382,470	Open	15.9	286
6/23/2026	21:45:00	7.5	1.5028	0.7	1,382,479	Open	16	291
6/23/2026	22:00:00	7.5	0.9388	1.2	1,382,501	Open	16.1	293
6/23/2026	22:15:00	7.5	1.4650	2	1,382,510	Open	16.1	294
6/23/2026	22:30:00	7.6	0.0000	7.7	1,382,520	Open	16.1	298
6/23/2026	22:45:00	7.5	1.3287	4.4	1,382,521	Closed	16.4	301
6/23/2026	23:00:00	7.5	0.0000	2.6	1,382,534	Closed	16.2	303
6/23/2026	23:15:00	7.5	1.5217	4.7	1,382,546	Open	16.4	304
6/23/2026	23:30:00	7.4	1.4044	2.3	1,382,568	Open	16.8	304
6/23/2026	23:45:00	7.4	0.0000	1.8	1,382,576	Closed	17.2	303



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Valve Status	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/24/2026	0:00:00	7.4	0.8441	1.7	1,382,582	Open	17.6	304
6/24/2026	0:15:00	7.4	1.4120	2	1,382,590	Open	17.9	304
6/24/2026	0:30:00	7.4	1.6164	1.9	1,382,614	Open	18.3	304
6/24/2026	0:45:00	7.4	0.0000	1.7	1,382,629	Closed	18.5	304
6/24/2026	1:00:00	7.4	0.0000	1.6	1,382,637	Closed	18.8	304
6/24/2026	1:15:00	7.3	1.4574	1.4	1,382,655	Open	19	304
6/24/2026	1:30:00	7.3	0.0000	1.5	1,382,656	Closed	19.2	304
6/24/2026	1:45:00	7.3	0.0000	1.4	1,382,661	Open	19.3	303
6/24/2026	2:00:00	7.3	0.1514	1.5	1,382,670	Closed	19.5	303
6/24/2026	2:15:00	7.3	0.0000	1.2	1,382,686	Closed	19.6	302
6/24/2026	2:30:00	7.3	1.5672	0.8	1,382,696	Open	20.1	302
6/24/2026	2:45:00	7.3	0.0000	0.5	1,382,708	Closed	20.7	304
6/24/2026	3:00:00	7.3	0.9009	0.4	1,382,722	Open	21.2	303
6/24/2026	3:15:00	7.2	0.0000	0.6	1,382,726	Open	21.6	302
6/24/2026	3:30:00	7.4	1.4157	0	1,382,740	Open	16.4	282
6/24/2026	3:45:00	7.4	1.1659	0	1,382,758	Open	15.8	281
6/24/2026	4:00:00	7.4	0.8706	0	1,382,762	Open	16.4	283
6/24/2026	4:15:00	7.4	1.0864	0	1,382,776	Open	15.7	279
6/24/2026	4:30:00	7.4	1.0296	0	1,382,792	Open	16.2	281
6/24/2026	4:45:00	7.4	0.9312	0	1,382,807	Open	17.1	281
6/24/2026	5:00:00	7.4	0.5413	0	1,382,820	Open	17.7	279
6/24/2026	5:15:00	7.3	0.8101	0	1,382,830	Open	18.1	279
6/24/2026	5:30:00	7.3	0.7457	0	1,382,842	Open	18.5	279
6/24/2026	5:45:00	7.4	1.4309	3.1	1,382,863	Open	15.3	271
6/24/2026	6:00:00	7.4	0.9161	3.5	1,382,869	Closed	15.5	274
6/24/2026	6:15:00	7.4	1.1924	4.5	1,382,886	Open	14.9	273
6/24/2026	6:30:00	7.4	0.0000	7.7	1,382,901	Closed	14.9	273
6/24/2026	6:45:00	7.4	1.4385	4.4	1,382,905	Open	15	273
6/24/2026	7:00:00	7.4	0.0000	5.1	1,382,919	Closed	14.9	273
6/24/2026	7:15:00	7.4	1.3855	3.8	1,382,928	Open	14.6	273
6/24/2026	7:30:00	7.4	0.0000	3.4	1,382,936	Closed	14.7	269
6/24/2026	7:45:00	7.4	1.3211	8.5	1,382,947	Open	14.3	268



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Valve Status	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/24/2026	8:00:00	7.4	1.3627	2.3	1,382,951	Open	14.6	268
6/24/2026	8:15:00	7.4	1.3438	0.2	1,382,971	Open	14.1	268
6/24/2026	8:30:00	7.4	1.3476	0.5	1,382,976	Open	14.3	268
6/24/2026	8:45:00	7.4	0.0000	0	1,382,989	Closed	14.2	266
6/24/2026	9:00:00	7.4	0.0000	0	1,382,989	Closed	14.7	267
6/24/2026	9:15:00	7.4	1.3400	0	1,382,998	Open	14.2	266
6/24/2026	9:30:00	7.4	0.0000	0	1,383,011	Closed	14.3	266
6/24/2026	9:45:00	7.4	1.3665	0	1,383,024	Open	14.3	265
6/24/2026	10:00:00	7.4	0.0000	0	1,383,030	Closed	14.5	265
6/24/2026	10:15:00	7.4	0.0000	0	1,383,047	Open	14.3	265
6/24/2026	10:30:00	7.4	1.3476	0.4	1,383,049	Open	15	266
6/24/2026	10:45:00	7.4	0.0000	0.4	1,383,065	Closed	14.7	266
6/24/2026	11:00:00	7.4	1.3400	0.5	1,383,078	Open	15.2	265
6/24/2026	11:15:00	7.5	0.0000	0.2	1,383,092	Closed	14.7	265
6/24/2026	11:30:00	7.5	1.3476	1.9	1,383,103	Open	14.8	265
6/24/2026	11:45:00	7.5	0.0000	0.7	1,383,122	Closed	14.9	265
6/24/2026	12:00:00	7.5	1.3627	1.9	1,383,131	Open	15.1	266
6/24/2026	12:15:00	7.5	0.6852	1.6	1,383,151	Open	15.2	268
6/24/2026	12:30:00	7.5	1.3665	3.1	1,383,158	Open	15.5	269
6/24/2026	12:45:00	7.5	1.3779	2.5	1,383,169	Open	15.7	270
6/24/2026	13:00:00	7.5	0.0000	3.6	1,383,184	Closed	15.8	270
6/24/2026	13:15:00	7.5	1.3552	2.8	1,383,196	Open	15.8	270
6/24/2026	13:30:00	7.5	1.0561	2.1	1,383,199	Closed	16.3	273
6/24/2026	13:45:00	7.5	0.0644	3.1	1,383,218	Closed	16	273
6/24/2026	14:00:00	7.5	1.3476	5.6	1,383,220	Open	16.4	271
6/24/2026	14:15:00	7.5	0.0000	4.5	1,383,235	Closed	16.2	273
6/24/2026	14:30:00	7.5	1.3665	6.3	1,383,247	Open	16.3	277
6/24/2026	14:45:00	7.5	1.3325	2.2	1,383,268	Open	16.3	281
6/24/2026	15:00:00	7.5	1.3665	4.2	1,383,273	Open	16.8	281
6/24/2026	15:15:00	7.5	1.3249	0.8	1,383,294	Open	16.5	281
6/24/2026	15:30:00	7.5	1.3552	4.7	1,383,299	Open	16.7	283
6/24/2026	15:45:00	7.5	0.0000	2.6	1,383,315	Closed	16.7	281



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Valve Status	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/24/2026	16:00:00	7.5	1.3249	3.1	1,383,324	Open	16.7	283
6/24/2026	16:15:00	7.5	1.3022	1.5	1,383,343	Open	16.6	281
6/24/2026	16:30:00	7.5	1.3249	0.7	1,383,351	Open	16.8	283
6/24/2026	16:45:00	7.4	0.0000	1.3	1,383,354	Closed	17.2	283
6/24/2026	17:00:00	7.5	1.3173	1.3	1,383,366	Open	16.9	282
6/24/2026	17:15:00	7.5	1.2908	1	1,383,377	Open	16.8	281
6/24/2026	17:30:00	7.5	1.3135	1.9	1,383,394	Open	16.8	281
6/24/2026	17:45:00	7.5	1.3287	1.3	1,383,405	Open	16.8	283
6/24/2026	18:00:00	7.5	0.0000	4.2	1,383,419	Closed	16.9	283
6/24/2026	18:15:00	7.5	1.3173	0.6	1,383,430	Open	16.8	283
6/24/2026	18:30:00	7.5	0.0000	3	1,383,442	Closed	16.9	283
6/24/2026	18:45:00	7.5	1.2719	1.3	1,383,458	Open	16.6	282
6/24/2026	19:00:00	7.5	0.0000	4.5	1,383,461	Closed	16.7	281
6/24/2026	19:15:00	7.5	1.7867	10.4	1,383,466	Open	16.2	282
6/24/2026	19:30:00	7.5	0.0000	2.9	1,383,481	Closed	16.5	280
6/24/2026	19:45:00	7.5	0.3293	15.5	1,383,484	Open	16.1	277
6/24/2026	20:00:00	7.5	1.4347	4.5	1,383,493	Open	16.1	279
6/24/2026	20:15:00	7.4	1.4839	2.1	1,383,516	Open	16	278
6/24/2026	20:30:00	7.4	1.4271	2	1,383,538	Open	16	277
6/24/2026	20:45:00	7.4	0.0000	1.2	1,383,540	Closed	16.5	278
6/24/2026	21:00:00	7.4	1.1886	0.5	1,383,557	Open	16	278
6/24/2026	21:15:00	7.4	0.0000	3.1	1,383,561	Closed	16.3	278
6/24/2026	21:30:00	7.5	0.0000	6.1	1,383,562	Open	15.9	279
6/24/2026	21:45:00	7.5	1.4006	5.7	1,383,568	Open	15.7	285
6/24/2026	22:00:00	7.5	1.0258	5.6	1,383,591	Open	15.7	285
6/24/2026	22:15:00	7.4	0.5716	9.2	1,383,613	Closed	15.7	285
6/24/2026	22:30:00	7.5	1.3627	0	1,383,622	Open	17.1	109
6/24/2026	22:45:00	7.5	1.5369	0	1,383,645	Open	15.6	287
6/24/2026	23:15:00	7.5	1.4839	0.4	1,383,659	Open	15.5	289
6/24/2026	23:30:00	7.5	0.0000	0.3	1,383,670	Closed	15.6	289
6/24/2026	23:45:00	7.6	0.0000	5.8	1,383,672	Open	15.3	291
6/25/2026	0:00:00	7.5	0.9350	1.3	1,383,692	Open	15.3	291



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Valve Status	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/25/2026	0:15:00	7.5	0.0000	1.5	1,383,700	Closed	15.6	291
6/25/2026	0:30:00	7.5	1.4271	1.6	1,383,719	Open	15.2	291
6/25/2026	0:45:00	7.5	0.0000	1.4	1,383,739	Closed	15.2	291
6/25/2026	1:00:00	7.5	0.9009	1.7	1,383,747	Open	15.3	294
6/25/2026	1:15:00	7.5	0.0000	1.4	1,383,755	Closed	15.6	294
6/25/2026	1:30:00	7.6	0.0000	6.8	1,383,757	Open	15.4	294
6/25/2026	1:45:00	7.6	1.7640	8.4	1,383,765	Open	15.3	294
6/25/2026	2:00:00	7.5	0.9918	3.2	1,383,788	Open	15.3	294
6/25/2026	2:15:00	7.5	1.4536	0.4	1,383,808	Open	15.3	294
6/25/2026	2:30:00	7.5	0.7154	5.9	1,383,830	Open	15.2	294
6/25/2026	2:45:00	7.6	1.3590	1.9	1,383,831	Open	15.2	296
6/25/2026	3:00:00	7.5	0.8063	0.6	1,383,851	Open	15.2	298
6/25/2026	3:15:00	7.5	1.3552	0.8	1,383,869	Open	15.1	299
6/25/2026	3:30:00	7.5	0.0000	1.3	1,383,887	Closed	15.1	298
6/25/2026	3:45:00	7.6	1.2075	8.2	1,383,887	Open	15.1	299
6/25/2026	4:00:00	7.5	0.8328	1.4	1,383,893	Open	15.1	298
6/25/2026	4:15:00	7.5	1.3476	2.3	1,383,911	Open	15	298
6/25/2026	4:30:00	7.5	1.3703	3.5	1,383,932	Open	15	298
6/25/2026	4:45:00	7.6	0.0000	11.9	1,383,935	Open	15	299
6/25/2026	5:00:00	7.6	0.9199	11.8	1,383,937	Open	15.1	297
6/25/2026	5:15:00	7.5	1.6239	7.2	1,383,949	Open	14.9	299
6/25/2026	5:30:00	7.5	1.6694	5.9	1,383,962	Open	15.3	303
6/25/2026	5:45:00	7.5	0.0000	6.3	1,383,985	Closed	15	299
6/25/2026	6:00:00	7.5	1.0221	4.1	1,383,996	Open	15.1	294
6/25/2026	6:15:00	7.5	0.0000	3.5	1,384,005	Closed	15.9	298
6/25/2026	6:30:00	7.5	1.5823	3.8	1,384,026	Open	15.2	298
6/25/2026	6:45:00	7.5	0.0000	3.2	1,384,034	Closed	16.5	299
6/25/2026	7:00:00	7.5	0.0000	3.6	1,384,047	Closed	15.6	296
6/25/2026	7:15:00	7.5	1.5747	0.8	1,384,055	Open	15.5	294
6/25/2026	7:30:00	7.5	0.0000	0.1	1,384,060	Closed	16.7	296
6/25/2026	7:45:00	7.5	0.0000	0.2	1,384,076	Closed	15.8	291
6/25/2026	8:00:00	7.4	0.6435	8.1	1,384,086	Open	15.4	291



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Valve Status	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/25/2026	8:15:00	7.4	1.6126	1.6	1,384,092	Open	15.3	286
6/25/2026	8:30:00	7.4	0.0000	0.5	1,384,110	Closed	15	284
6/25/2026	8:45:00	7.4	1.5482	1.7	1,384,124	Open	14.7	283
6/25/2026	9:00:00	7.4	0.0000	1.9	1,384,131	Closed	15.5	281
6/25/2026	9:15:00	7.4	1.4120	3.9	1,384,150	Open	14.5	279
6/25/2026	9:30:00	7.4	0.0000	4.3	1,384,159	Closed	15.2	279
6/25/2026	9:45:00	7.4	1.4044	5.9	1,384,178	Open	14.5	279
6/25/2026	10:00:00	7.4	0.0000	6.2	1,384,189	Closed	14.9	279
6/25/2026	10:15:00	7.4	0.0000	4.9	1,384,206	Closed	14.5	278
6/25/2026	10:30:00	7.4	1.3855	6.1	1,384,217	Open	14.6	278
6/25/2026	10:45:00	7.4	1.3438	5.4	1,384,238	Open	14.6	275
6/25/2026	11:00:00	7.4	0.7760	14	1,384,242	Open	15.3	275
6/25/2026	11:15:00	7.4	1.3249	4	1,384,259	Open	14.6	275
6/25/2026	11:30:00	7.4	1.3173	4.2	1,384,269	Open	14.7	274
6/25/2026	11:45:00	7.5	1.3400	4.5	1,384,288	Open	14.6	274
6/25/2026	12:00:00	7.5	0.8252	13.6	1,384,295	Open	14.7	273
6/25/2026	12:15:00	7.4	0.0000	3.3	1,384,298	Closed	15.1	273
6/25/2026	12:30:00	7.5	1.3514	4.7	1,384,310	Open	14.7	273
6/25/2026	12:45:00	7.5	1.3173	4.8	1,384,330	Open	14.6	273
6/25/2026	13:00:00	7.5	0.7457	20.6	1,384,335	Open	14.7	273
6/25/2026	13:15:00	7.5	1.3098	2.8	1,384,353	Open	14.6	273
6/25/2026	13:30:00	7.5	1.3400	3.1	1,384,361	Open	15.1	277
6/25/2026	13:45:00	7.5	1.3249	1.7	1,384,381	Open	14.6	273
6/25/2026	14:00:00	7.4	0.0000	0.5	1,384,390	Closed	14.9	274
6/25/2026	14:15:00	7.4	1.3098	3.4	1,384,405	Open	14.6	274
6/25/2026	14:30:00	7.4	0.0000	0.8	1,384,421	Closed	14.7	277
6/25/2026	14:45:00	7.4	1.3173	1.5	1,384,435	Open	14.6	275
6/25/2026	15:00:00	7.4	0.8025	11.8	1,384,454	Open	14.6	275
6/25/2026	15:15:00	7.4	0.0000	0.7	1,384,463	Closed	14.8	275
6/25/2026	15:30:00	7.5	1.2908	2.4	1,384,481	Open	14.5	273
6/25/2026	15:45:00	7.5	0.0000	12.6	1,384,491	Open	14.4	273
6/25/2026	16:00:00	7.5	0.0000	5.9	1,384,494	Closed	14.8	277



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Valve Status	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/25/2026	16:15:00	7.5	1.4157	6.7	1,384,505	Open	14.6	275
6/25/2026	16:30:00	7.5	1.3817	5.9	1,384,526	Open	14.5	275
6/25/2026	16:45:00	7.5	1.4044	3.2	1,384,537	Open	14.6	275
6/25/2026	17:00:00	7.5	0.0000	6.1	1,384,557	Closed	14.6	275
6/25/2026	17:15:00	7.5	1.4044	32.6	1,384,557	Closed	14.6	273
6/25/2026	17:30:00	7.5	1.3703	1.4	1,384,572	Open	14.6	275
6/25/2026	17:45:00	7.5	1.3703	1.5	1,384,593	Open	14.6	275
6/25/2026	18:00:00	7.5	0.8555	7.2	1,384,613	Open	14.6	275
6/25/2026	18:15:00	7.5	1.4120	2.5	1,384,619	Open	14.7	273
6/25/2026	18:30:00	7.5	0.0000	2.2	1,384,635	Closed	14.7	273
6/25/2026	18:45:00	7.5	1.4120	2.1	1,384,643	Open	14.6	272
6/25/2026	19:00:00	7.5	0.0000	1.2	1,384,654	Closed	14.8	270
6/25/2026	19:15:00	7.5	1.3892	0.7	1,384,668	Open	14.5	270
6/25/2026	19:30:00	7.5	0.0000	1.4	1,384,675	Open	14.4	272
6/25/2026	19:45:00	7.5	0.0000	13.6	1,384,675	Closed	14.3	270
6/25/2026	20:00:00	7.5	1.3476	2.1	1,384,689	Open	14.2	270
6/25/2026	20:15:00	7.5	1.3400	1.8	1,384,709	Open	14.2	270
6/25/2026	20:30:00	7.5	0.0000	1.6	1,384,727	Closed	14.3	270
6/25/2026	20:45:00	7.5	0.4164	6.2	1,384,735	Open	14.2	269
6/25/2026	21:00:00	7.6	1.1394	162.4	1,384,739	Closed	14.2	270
6/25/2026	21:15:00	7.7	0.0000	21.9	1,384,746	Closed	14.7	272
6/25/2026	21:30:00	7.6	0.9047	2.9	1,384,752	Open	14.4	272
6/25/2026	21:45:00	7.6	1.3703	3.3	1,384,768	Closed	14.5	272
6/25/2026	22:00:00	7.6	1.4612	20.1	1,384,782	Open	14.3	273
6/25/2026	22:15:00	7.6	1.4612	0.8	1,384,803	Open	14.5	273
6/25/2026	22:30:00	7.5	0.9729	0.4	1,384,821	Open	14.4	273
6/25/2026	22:45:00	7.5	1.5709	0.6	1,384,826	Open	14.4	273
6/25/2026	23:00:00	7.6	0.0000	2.3	1,384,831	Closed	14.3	273
6/25/2026	23:15:00	7.6	1.3287	10.6	1,384,832	Closed	14.4	274
6/25/2026	23:30:00	7.6	0.9842	0.6	1,384,834	Open	15	276
6/25/2026	23:45:00	7.5	1.5482	0.2	1,384,857	Open	14.5	273
6/26/2026	0:00:00	7.5	1.5331	0.2	1,384,880	Open	14.5	273



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Valve Status	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/26/2026	0:15:00	7.5	1.5482	0.1	1,384,897	Open	14.5	273
6/26/2026	0:30:00	7.5	0.9388	0.4	1,384,918	Open	14.7	275
6/26/2026	0:45:00	7.5	0.0000	0	1,384,936	Closed	14.6	273
6/26/2026	1:00:00	7.5	1.5028	0.1	1,384,956	Open	14.5	273
6/26/2026	1:15:00	7.5	0.0000	0.5	1,384,973	Closed	14.6	273
6/26/2026	1:30:00	7.5	0.0000	0	1,384,973	Closed	15.6	273
6/26/2026	1:45:00	7.5	0.0000	5.1	1,384,982	Open	14.7	272
6/26/2026	2:00:00	7.6	0.0000	4.2	1,384,982	Open	14.7	274
6/26/2026	2:15:00	7.5	1.5066	1.6	1,384,991	Open	14.7	272
6/26/2026	2:30:00	7.5	0.9993	2.1	1,385,013	Open	14.9	271
6/26/2026	2:45:00	7.5	1.5558	1.8	1,385,035	Open	14.7	271
6/26/2026	3:00:00	7.5	1.5558	1.5	1,385,059	Open	14.6	271
6/26/2026	3:15:00	7.5	0.0000	1.4	1,385,067	Closed	15.1	269
6/26/2026	3:30:00	7.5	0.9918	1.7	1,385,086	Open	15	269
6/26/2026	3:45:00	7.5	1.5520	1.9	1,385,109	Open	14.9	271
6/26/2026	4:00:00	7.5	0.0000	1.9	1,385,113	Closed	15.4	271
6/26/2026	4:15:00	7.5	1.5179	1.4	1,385,133	Open	14.7	271
6/26/2026	4:30:00	7.4	0.0000	0.7	1,385,136	Closed	15.1	269
6/26/2026	4:45:00	7.5	1.4952	0.3	1,385,148	Open	14.4	269
6/26/2026	5:00:00	7.5	0.0000	17.8	1,385,152	Closed	14.2	272
6/26/2026	5:15:00	7.5	1.4498	1.3	1,385,165	Open	14.1	271
6/26/2026	5:30:00	7.5	0.0000	2.9	1,385,184	Closed	14	269
6/26/2026	5:45:00	7.5	1.5369	2.6	1,385,189	Open	14	269
6/26/2026	6:00:00	7.5	1.4687	2.3	1,385,212	Open	13.8	271
6/26/2026	6:15:00	7.5	0.0000	0.7	1,385,228	Closed	13.8	268
6/26/2026	6:30:00	7.5	0.9123	1.6	1,385,231	Open	13.8	268
6/26/2026	6:45:00	7.5	1.5066	1	1,385,253	Open	13.6	268
6/26/2026	7:00:00	7.5	0.0000	1	1,385,259	Closed	14	268
6/26/2026	7:15:00	7.5	1.4839	1	1,385,275	Open	13.6	268
6/26/2026	7:30:00	7.5	0.0000	1.3	1,385,293	Closed	13.6	269
6/26/2026	7:45:00	7.5	1.4536	1.5	1,385,295	Open	13.9	268
6/26/2026	8:00:00	7.5	1.4650	1.4	1,385,317	Open	13.5	269



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Valve Status	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/26/2026	8:15:00	7.5	0.8858	1.6	1,385,320	Open	13.7	268
6/26/2026	8:30:00	7.5	1.4347	1.5	1,385,341	Open	13.5	267
6/26/2026	8:45:00	7.5	0.0000	5.9	1,385,354	Closed	13.6	266
6/26/2026	9:00:00	7.5	0.0000	14.9	1,385,359	Open	13.4	266
6/26/2026	9:15:00	7.5	1.3627	2.3	1,385,374	Open	13.6	266
6/26/2026	9:30:00	7.5	0.0000	1.1	1,385,375	Closed	14	268
6/26/2026	9:45:00	7.5	1.6959	1.6	1,385,397	Open	13.6	268
6/26/2026	10:00:00	7.5	0.0000	2.1	1,385,421	Closed	13.7	268
6/26/2026	10:15:00	7.5	1.6164	2.9	1,385,438	Open	13.7	268
6/26/2026	10:30:00	7.5	1.5785	2.4	1,385,462	Open	13.8	272
6/26/2026	10:45:00	7.5	0.0000	1.7	1,385,473	Closed	14.1	273
6/26/2026	11:00:00	7.5	1.6088	1.7	1,385,489	Open	13.9	272
6/26/2026	11:15:00	7.5	0.0000	0.4	1,385,505	Closed	13.9	273
6/26/2026	11:30:00	7.5	1.5142	1.2	1,385,506	Open	14.3	272
6/26/2026	11:45:00	7.5	1.5672	0.7	1,385,511	Open	13.9	273
6/26/2026	12:00:00	7.5	1.4309	1.3	1,385,533	Open	13.9	273
6/26/2026	12:15:00	7.5	0.0000	1	1,385,547	Closed	14	274
6/26/2026	12:30:00	7.5	1.4915	1.6	1,385,558	Open	14.1	274
6/26/2026	12:45:00	7.5	1.5028	2.1	1,385,581	Open	14.1	273
6/26/2026	13:00:00	7.5	1.4536	2	1,385,599	Open	14.1	274
6/26/2026	13:15:00	7.5	1.3211	2.7	1,385,602	Closed	14.1	274
6/26/2026	13:30:00	7.5	1.4915	3.7	1,385,606	Open	14.2	277
6/26/2026	13:45:00	7.5	0.0000	3.9	1,385,627	Closed	14.1	277
6/26/2026	14:00:00	7.5	1.5028	3.6	1,385,627	Open	14.8	278
6/26/2026	14:15:00	7.5	1.4877	4.9	1,385,645	Open	14.2	277
6/26/2026	14:30:00	7.5	1.4650	6.1	1,385,667	Open	14.2	278
6/26/2026	14:45:00	7.5	1.4952	1.8	1,385,674	Open	14.3	277
6/26/2026	15:00:00	7.5	1.4460	1.9	1,385,690	Open	14.4	277
6/26/2026	15:15:00	7.5	1.4612	4.4	1,385,700	Open	14.4	277
6/26/2026	15:30:00	7.5	1.4574	1.6	1,385,713	Open	14.3	276
6/26/2026	15:45:00	7.5	1.3627	5	1,385,735	Open	14.2	276
6/26/2026	16:00:00	7.5	1.4460	0.6	1,385,757	Open	14.2	275



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Valve Status	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/26/2026	16:15:00	7.5	0.0000	0.4	1,385,760	Closed	14.5	276
6/26/2026	16:30:00	7.5	0.0000	2.6	1,385,766	Open	14.3	273
6/26/2026	16:45:00	7.5	1.4120	0.7	1,385,771	Closed	14.1	273
6/26/2026	17:00:00	7.5	1.5104	0.4	1,385,789	Open	14	273
6/26/2026	17:15:00	7.5	1.4498	0.4	1,385,808	Open	14	273
6/26/2026	17:30:00	7.5	1.4460	0.5	1,385,819	Open	14	273
6/26/2026	17:45:00	7.5	1.4574	0.4	1,385,837	Open	14	273
6/26/2026	18:00:00	7.5	0.0000	0.3	1,385,848	Closed	14.2	273
6/26/2026	18:15:00	7.5	1.4195	0.9	1,385,859	Open	14.1	275
6/26/2026	18:30:00	7.5	1.3627	1.4	1,385,880	Open	14.1	275
6/26/2026	18:45:00	7.5	1.3930	1.9	1,385,898	Open	14.1	275
6/26/2026	19:00:00	7.5	1.0031	8.4	1,385,900	Closed	14.2	272
6/26/2026	19:15:00	7.5	0.2158	25.4	1,385,900	Closed	14.1	272
6/26/2026	19:30:00	7.5	1.4271	4.2	1,385,905	Open	14.1	270
6/26/2026	19:45:00	7.5	1.4725	3.1	1,385,927	Open	14.2	270
6/26/2026	20:00:00	7.5	1.3438	2	1,385,945	Open	14.2	270
6/26/2026	20:15:00	7.5	0.0000	2	1,385,959	Closed	14.3	270
6/26/2026	20:30:00	7.5	1.3022	1.6	1,385,963	Open	14.2	268
6/26/2026	20:45:00	7.5	1.3552	1	1,385,977	Open	14.1	268
6/26/2026	21:00:00	7.5	1.3930	1.4	1,385,986	Open	14.1	268
6/26/2026	21:15:00	7.5	0.0000	10.1	1,386,000	Open	13.9	268
6/26/2026	21:30:00	7.5	1.0523	1.1	1,386,003	Open	13.7	272
6/26/2026	21:45:00	7.5	1.1432	0.8	1,386,018	Open	13.8	270
6/26/2026	22:00:00	7.5	0.0000	1	1,386,022	Closed	13.9	269
6/26/2026	22:15:00	7.5	0.6776	1.9	1,386,032	Open	13.9	270
6/26/2026	22:30:00	7.5	1.1318	1.9	1,386,047	Open	14	270
6/26/2026	22:45:00	7.5	1.1053	5.1	1,386,053	Open	13.9	270
6/26/2026	23:00:00	7.5	1.7034	6.6	1,386,068	Open	14	273
6/26/2026	23:15:00	7.5	0.0000	2.5	1,386,081	Closed	14.1	273
6/26/2026	23:30:00	7.5	0.1703	2.2	1,386,094	Closed	13.9	272
6/26/2026	23:45:00	7.5	1.5407	2.3	1,386,101	Open	13.8	273
6/27/2026	0:00:00	7.5	1.5293	2.1	1,386,113	Open	14.2	271



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Valve Status	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/27/2026	0:15:00	7.4	1.0410	6.3	1,386,130	Open	14.1	271
6/27/2026	0:30:00	7.4	1.3968	1.7	1,386,141	Closed	14.1	271
6/27/2026	0:45:00	7.4	1.3438	3	1,386,147	Closed	14.3	269
6/27/2026	1:00:00	7.4	0.0000	1.9	1,386,161	Closed	14.3	269
6/27/2026	1:15:00	7.4	0.7533	4.3	1,386,172	Closed	13.8	271
6/27/2026	1:30:00	7.4	1.5179	3.1	1,386,178	Open	13.7	269
6/27/2026	1:45:00	7.4	1.4915	2.9	1,386,194	Open	13.6	271
6/27/2026	2:00:00	7.4	0.0000	1.8	1,386,206	Closed	14.1	271
6/27/2026	2:15:00	7.4	0.9956	3.2	1,386,214	Open	13.8	269
6/27/2026	2:30:00	7.4	1.3627	2.4	1,386,217	Closed	13.8	269
6/27/2026	2:45:00	7.4	0.0000	10.2	1,386,228	Open	13.7	271
6/27/2026	3:00:00	7.4	1.5444	6.4	1,386,237	Open	13.7	271
6/27/2026	3:15:00	7.4	0.7268	12	1,386,251	Closed	14.1	271
6/27/2026	3:30:00	7.4	0.0000	5.6	1,386,251	Closed	14.1	270
6/27/2026	3:45:00	7.4	1.4839	4.2	1,386,271	Open	13.8	268
6/27/2026	4:00:00	7.4	0.0000	2.2	1,386,288	Closed	13.8	268
6/27/2026	4:15:00	7.4	0.8063	2.9	1,386,305	Open	13.6	271
6/27/2026	4:30:00	7.4	1.2719	9.2	1,386,323	Open	13.5	271
6/27/2026	4:45:00	7.4	0.0000	3.4	1,386,336	Closed	13.6	271
6/27/2026	5:00:00	7.5	1.2757	1.7	1,386,350	Open	13.5	268
6/27/2026	5:15:00	7.5	0.0000	1.9	1,386,356	Open	13.7	108
6/27/2026	5:30:00	7.5	1.2265	0.7	1,386,372	Open	13.4	271
6/27/2026	5:45:00	7.5	0.0000	0.5	1,386,380	Closed	14.3	271
6/27/2026	6:00:00	7.4	1.2492	0.1	1,386,381	Open	15	269
6/27/2026	6:15:00	7.4	0.8517	0	1,386,398	Open	14.3	271
6/27/2026	6:30:00	7.4	1.3135	0	1,386,406	Open	14.3	269
6/27/2026	6:45:00	7.4	1.2605	0	1,386,425	Open	14.1	269
6/27/2026	7:00:00	7.4	0.1098	0.6	1,386,441	Closed	14.2	269
6/27/2026	7:15:00	7.4	0.9880	0.2	1,386,456	Open	14.3	269
6/27/2026	7:30:00	7.4	1.2568	0.4	1,386,461	Open	14.2	271
6/27/2026	7:45:00	7.4	0.1173	0.1	1,386,477	Closed	14.2	271
6/27/2026	8:00:00	7.4	0.0000	7.6	1,386,488	Open	14.1	269



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Valve Status	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/27/2026	8:15:00	7.4	0.5224	0	1,386,494	Open	14.3	269
6/27/2026	8:30:00	7.4	0.7419	0.2	1,386,502	Open	14.2	268
6/27/2026	8:45:00	7.4	1.3022	0.5	1,386,519	Open	14	269
6/27/2026	9:00:00	7.4	1.2757	0.5	1,386,539	Open	13.8	273
6/27/2026	9:15:00	7.4	0.0000	1.1	1,386,554	Closed	14	273
6/27/2026	9:30:00	7.4	0.7874	0.8	1,386,559	Open	13.9	269
6/27/2026	9:45:00	7.4	0.4240	1.3	1,386,573	Open	13.7	270
6/27/2026	10:00:00	7.4	1.3438	1	1,386,576	Open	14.1	268
6/27/2026	10:15:00	7.4	1.2795	1	1,386,595	Open	13.9	270
6/27/2026	10:30:00	7.4	1.2643	1	1,386,614	Open	14	269
6/27/2026	10:45:00	7.4	0.2574	5.8	1,386,629	Open	13.8	272
6/27/2026	11:00:00	7.4	0.0000	0.2	1,386,637	Closed	14.5	270
6/27/2026	11:15:00	7.4	0.0000	1.6	1,386,643	Open	13.9	272
6/27/2026	11:30:00	7.4	1.5369	1.7	1,386,655	Open	13.9	270
6/27/2026	11:45:00	7.4	0.0000	0.8	1,386,672	Closed	14.3	270
6/27/2026	12:00:00	7.4	0.9274	1.4	1,386,691	Open	13.9	270
6/27/2026	12:15:00	7.4	0.0000	1.5	1,386,708	Closed	14.3	270
6/27/2026	12:30:00	7.4	1.5747	1.9	1,386,725	Open	14.1	268
6/27/2026	12:45:00	7.4	1.5823	2.1	1,386,738	Open	14.2	268
6/27/2026	13:00:00	7.4	0.0000	1.9	1,386,740	Closed	14.6	107
6/27/2026	13:15:00	7.4	1.4460	3.6	1,386,740	Closed	14.6	270
6/27/2026	13:30:00	7.4	1.6126	4.6	1,386,756	Open	14.3	268
6/27/2026	13:45:00	7.5	0.0000	1.5	1,386,759	Closed	14.9	265
6/27/2026	14:00:00	7.5	1.5785	4.5	1,386,766	Open	14.6	265
6/27/2026	14:15:00	7.5	0.0000	1.8	1,386,772	Closed	15	268
6/27/2026	14:30:00	7.5	1.6429	4.9	1,386,795	Open	14.6	268
6/27/2026	14:45:00	7.4	0.0000	4.6	1,386,801	Closed	15.2	267
6/27/2026	15:00:00	7.4	1.5104	7.2	1,386,812	Open	14.7	265
6/27/2026	15:15:00	7.5	1.9419	1.1	1,386,817	Open	15.1	267
6/27/2026	15:30:00	7.5	1.8056	3.1	1,386,844	Open	14.6	267
6/27/2026	15:45:00	7.5	1.7981	3.3	1,386,852	Open	15	267
6/27/2026	16:00:00	7.5	0.0000	1.1	1,386,870	Closed	14.8	267



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Valve Status	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/27/2026	16:15:00	7.5	0.0000	6.7	1,386,870	Open	15.3	265
6/27/2026	16:30:00	7.5	0.0000	7.9	1,386,874	Closed	14.8	265
6/27/2026	16:45:00	7.5	1.5369	0.8	1,386,885	Open	14.7	265
6/27/2026	17:00:00	7.5	0.0000	0.7	1,386,906	Closed	14.6	265
6/27/2026	17:15:00	7.5	1.3400	0.7	1,386,906	Closed	14.5	265
6/27/2026	17:30:00	7.5	1.4574	0.7	1,386,921	Open	14.4	265
6/27/2026	17:45:00	7.5	1.4990	0.8	1,386,931	Open	14.5	263
6/27/2026	18:00:00	7.5	1.4952	1.3	1,386,953	Open	14.5	263
6/27/2026	18:15:00	7.4	1.4877	1.8	1,386,959	Open	14.9	268
6/27/2026	18:30:00	7.5	1.4574	1.2	1,386,980	Open	14.6	267
6/27/2026	18:45:00	7.4	0.0000	1.4	1,386,984	Closed	14.9	270
6/27/2026	19:00:00	7.5	0.2688	7	1,386,984	Closed	14.6	272
6/27/2026	19:15:00	7.5	0.1817	7.2	1,386,984	Closed	14.6	273
6/27/2026	19:30:00	7.5	0.1438	9	1,386,989	Closed	14.7	275
6/27/2026	19:45:00	7.5	1.5142	2.6	1,387,009	Open	14.6	272
6/27/2026	20:00:00	7.5	1.5823	2.2	1,387,032	Open	14.6	272
6/27/2026	20:15:00	7.5	1.4309	1.4	1,387,035	Closed	14.6	273
6/27/2026	20:30:00	7.5	1.6012	1.4	1,387,040	Open	14.7	273
6/27/2026	20:45:00	7.5	1.3930	1.4	1,387,057	Closed	14.6	269
6/27/2026	21:00:00	7.4	0.0000	0.8	1,387,059	Closed	14.9	269
6/27/2026	21:15:00	7.4	0.0000	5.8	1,387,063	Open	14.5	272
6/27/2026	21:30:00	7.4	0.8555	4.8	1,387,065	Closed	14.4	273
6/27/2026	21:45:00	7.5	1.3590	1.4	1,387,069	Open	14.4	273
6/27/2026	22:00:00	7.4	0.9880	1.8	1,387,091	Open	14.5	275
6/27/2026	22:15:00	7.4	1.4990	3	1,387,111	Open	14.5	275
6/27/2026	22:30:00	7.4	1.4574	2.9	1,387,133	Open	14.5	275
6/27/2026	22:45:00	7.4	1.4309	3.6	1,387,154	Open	14.5	275
6/27/2026	23:00:00	7.4	0.0000	3	1,387,168	Closed	14.6	273
6/27/2026	23:15:00	7.4	0.2044	8.5	1,387,180	Closed	14.4	273
6/27/2026	23:30:00	7.4	0.0000	8.1	1,387,180	Closed	15.3	274
6/27/2026	23:45:00	7.4	1.3552	9.5	1,387,186	Open	14.5	274
6/28/2026	0:00:00	7.5	0.0000	25.6	1,387,195	Closed	14.6	274



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Valve Status	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/28/2026	0:15:00	7.5	1.6769	10.5	1,387,200	Open	14.6	274
6/28/2026	0:30:00	7.5	0.9047	10.2	1,387,220	Open	14.6	274
6/28/2026	0:45:00	7.5	0.0000	3.7	1,387,228	Closed	15	276
6/28/2026	1:00:00	7.5	0.2574	4	1,387,237	Closed	14.4	274
6/28/2026	1:15:00	7.5	1.4422	3.7	1,387,246	Open	14.5	277
6/28/2026	1:30:00	7.4	0.0000	2.6	1,387,263	Closed	15.1	276
6/28/2026	1:45:00	7.4	1.3362	0	1,387,268	Closed	14.8	273
6/28/2026	2:00:00	7.4	0.0000	0	1,387,270	Closed	16.3	273
6/28/2026	2:15:00	7.4	1.4952	0.1	1,387,286	Open	15	275
6/28/2026	2:30:00	7.4	0.0000	0	1,387,300	Closed	15.2	276
6/28/2026	2:45:00	7.4	1.5028	1.3	1,387,307	Open	14.5	276
6/28/2026	3:00:00	7.4	1.3438	1.5	1,387,315	Closed	14.4	279
6/28/2026	3:15:00	7.4	1.4763	1.5	1,387,323	Open	14.4	281
6/28/2026	3:30:00	7.4	0.9426	13.2	1,387,344	Open	14.5	284
6/28/2026	3:45:00	7.4	1.3438	0.2	1,387,355	Closed	14.6	282
6/28/2026	4:00:00	7.4	0.0000	0	1,387,359	Closed	15.3	282
6/28/2026	4:15:00	7.4	1.3476	0.4	1,387,359	Closed	15.1	278
6/28/2026	4:30:00	7.4	0.9577	10.6	1,387,368	Open	15.4	282
6/28/2026	4:45:00	7.4	0.0000	0.6	1,387,383	Closed	15.9	282
6/28/2026	5:00:00	7.5	0.1249	15.3	1,387,391	Closed	15.6	283
6/28/2026	5:15:00	7.4	1.4385	12.3	1,387,410	Open	15.5	281
6/28/2026	5:30:00	7.4	0.6587	15.3	1,387,420	Closed	15.2	281
6/28/2026	5:45:00	7.4	1.2946	11	1,387,420	Closed	15.1	283
6/28/2026	6:00:00	7.4	1.3779	11.4	1,387,431	Open	15.3	282
6/28/2026	6:15:00	7.4	1.3703	12.9	1,387,452	Open	15.2	282
6/28/2026	6:30:00	7.4	0.0000	15.6	1,387,460	Closed	15.8	282
6/28/2026	6:45:00	7.4	0.0000	16.9	1,387,469	Closed	15.3	281
6/28/2026	7:00:00	7.4	1.4195	0.3	1,387,480	Open	14.9	280
6/28/2026	7:15:00	7.4	1.4157	0.5	1,387,501	Open	14.9	279
6/28/2026	7:30:00	7.4	1.3968	0.8	1,387,522	Open	14.9	279
6/28/2026	7:45:00	7.4	0.0000	0.3	1,387,531	Closed	15.4	279
6/28/2026	8:00:00	7.4	0.0000	0.5	1,387,531	Closed	14.7	276



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Valve Status	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/28/2026	8:15:00	7.4	0.7306	7	1,387,540	Open	14.2	274
6/28/2026	8:30:00	7.4	0.3028	1.2	1,387,547	Open	14.2	276
6/28/2026	8:45:00	7.4	1.1659	0.5	1,387,552	Open	14	273
6/28/2026	9:00:00	7.4	1.2265	0.5	1,387,571	Open	14.1	274
6/28/2026	9:15:00	7.4	1.4233	1.7	1,387,586	Open	14.1	274
6/28/2026	9:30:00	7.4	0.0000	0.2	1,387,597	Closed	14.4	274
6/28/2026	9:45:00	7.4	1.2454	2.5	1,387,597	Closed	14.2	274
6/28/2026	10:00:00	7.4	0.0000	3.2	1,387,597	Closed	14.3	274
6/28/2026	10:15:00	7.4	1.3325	2.6	1,387,602	Open	14.4	274
6/28/2026	10:30:00	7.4	1.3665	2.9	1,387,615	Open	14.1	276
6/28/2026	10:45:00	7.4	0.7836	3.8	1,387,634	Open	14.3	276
6/28/2026	11:00:00	7.4	1.3703	3.1	1,387,653	Open	14.3	281
6/28/2026	11:15:00	7.4	1.3552	3.7	1,387,660	Open	14.6	281
6/28/2026	11:30:00	7.5	1.3855	5.5	1,387,676	Open	14.5	282
6/28/2026	11:45:00	7.5	1.3590	4	1,387,697	Open	14.4	284
6/28/2026	12:00:00	7.5	0.0000	4.7	1,387,712	Closed	14.6	284
6/28/2026	12:15:00	7.5	1.5293	4.3	1,387,729	Open	14.6	286
6/28/2026	12:30:00	7.5	0.8025	7.7	1,387,740	Open	14.7	288
6/28/2026	12:45:00	7.5	1.3325	3.8	1,387,748	Closed	14.7	288
6/28/2026	13:00:00	7.5	0.0000	3.2	1,387,754	Closed	14.9	288
6/28/2026	13:15:00	7.5	1.6845	12.7	1,387,764	Open	14.8	289
6/28/2026	13:30:00	7.5	1.3173	2.6	1,387,774	Open	14.9	288
6/28/2026	13:45:00	7.5	1.3665	2.1	1,387,787	Closed	14.9	288
6/28/2026	14:00:00	7.5	1.5028	1.5	1,387,810	Open	15.1	288
6/28/2026	14:15:00	7.5	0.7192	0.6	1,387,812	Closed	15.1	288
6/28/2026	14:30:00	7.5	1.6391	0.7	1,387,816	Open	15.3	288
6/28/2026	14:45:00	7.5	0.1968	0.1	1,387,838	Closed	15.3	288
6/28/2026	15:00:00	7.5	0.9047	2.2	1,387,839	Open	15.1	286
6/28/2026	15:15:00	7.5	0.4467	0	1,387,850	Open	15.1	286
6/28/2026	15:30:00	7.5	1.3211	0	1,387,868	Open	15.2	286
6/28/2026	15:45:00	7.4	1.3060	0	1,387,881	Open	15.5	286
6/28/2026	16:00:00	7.4	1.2946	0	1,387,901	Open	15.6	288



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Valve Status	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/28/2026	16:15:00	7.4	1.2492	0.1	1,387,920	Open	15.7	286
6/28/2026	16:30:00	7.4	1.1659	0.3	1,387,922	Closed	16.2	289
6/28/2026	16:45:00	7.4	1.1394	0.3	1,387,922	Closed	15.4	286
6/28/2026	17:00:00	7.4	1.5369	4.8	1,387,939	Open	15.3	286
6/28/2026	17:15:00	7.4	1.6429	2.1	1,387,960	Open	15.5	288
6/28/2026	17:30:00	7.5	1.6504	55.4	1,387,979	Open	15.5	289
6/28/2026	17:45:00	7.4	1.2530	1.1	1,387,993	Open	15.6	289
6/28/2026	18:00:00	7.4	1.1773	1.1	1,388,011	Open	15.6	291
6/28/2026	18:15:00	7.4	1.1962	1.4	1,388,029	Open	15.7	291
6/28/2026	18:30:00	7.4	1.2038	1.3	1,388,046	Open	15.7	291
6/28/2026	18:45:00	7.4	1.1735	1.5	1,388,060	Open	15.7	291
6/28/2026	19:00:00	7.4	1.2000	0.5	1,388,078	Open	15.7	291
6/28/2026	19:15:00	7.4	0.0000	6.6	1,388,083	Open	15.7	289
6/28/2026	19:30:00	7.4	1.4233	6.6	1,388,091	Open	15.6	289
6/28/2026	19:45:00	7.4	1.3627	7.3	1,388,108	Open	15.5	288
6/28/2026	20:00:00	7.4	1.3817	4.4	1,388,129	Open	15.4	287
6/28/2026	20:15:00	7.4	0.0000	3.9	1,388,138	Closed	15.5	284
6/28/2026	20:30:00	7.4	1.4082	4	1,388,150	Open	15.3	283
6/28/2026	20:45:00	7.4	0.0000	4.1	1,388,158	Closed	15.6	283
6/28/2026	21:00:00	7.4	1.4195	4.2	1,388,165	Open	15.2	281
6/28/2026	21:15:00	7.4	0.0000	0.5	1,388,184	Closed	15	280
6/28/2026	21:30:00	7.4	1.3855	1.5	1,388,185	Closed	15.2	280
6/28/2026	21:45:00	7.4	0.8479	9.2	1,388,185	Closed	14.8	282
6/28/2026	22:00:00	7.5	0.3937	8.1	1,388,198	Open	14.8	282
6/28/2026	22:15:00	7.5	1.8473	13.4	1,388,199	Open	14.8	286
6/28/2026	22:30:00	7.5	1.4801	1.4	1,388,219	Open	14.8	286
6/28/2026	22:45:00	7.5	1.4460	1.6	1,388,240	Open	14.8	288
6/28/2026	23:00:00	7.5	1.5028	2	1,388,263	Open	14.8	288
6/28/2026	23:15:00	7.4	0.0000	7	1,388,275	Closed	15	288
6/28/2026	23:30:00	7.4	0.0000	7.6	1,388,275	Closed	15.5	287
6/28/2026	23:45:00	7.5	0.0000	11.1	1,388,283	Closed	14.7	286

		Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope	
Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: BC1 Approved by: BC2 Date: July 16, 2026	

Appendix B: CP2 WTP Data Logs



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Valve Status	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/22/2026	0:00:00	7.41	2.1880	0	161677.4	ON	14.3	161
6/22/2026	0:15:00	7.41	2.1653	0	161711.4	ON	14.2	161
6/22/2026	0:30:00	7.4	1.6239	0	161741.5	ON	14.7	161
6/22/2026	0:45:00	7.38	2.1388	0	161771.5	ON	14.2	163
6/22/2026	1:00:00	7.38	1.5861	0	161801.8	ON	14.4	164
6/22/2026	1:15:00	7.33	0.8063	0	161809.6	ON	15.1	164
6/22/2026	1:30:00	7.35	2.0441	0	161839.5	ON	14.2	164
6/22/2026	1:45:00	7.34	1.5293	0	161866.1	ON	14.8	164
6/22/2026	2:00:00	7.31	0.2839	0	161874.2	ON	15.4	163
6/22/2026	2:15:00	7.33	1.5672	0	161890.4	ON	15	162
6/22/2026	2:30:00	7.33	1.9230	0	161919.3	ON	14.2	162
6/22/2026	2:45:00	7.33	1.6012	0	161944.9	ON	14.6	163
6/22/2026	3:00:00	7.3	1.7678	0	161968.9	ON	15.1	164
6/22/2026	3:15:00	7.29	1.6088	0	161995.3	ON	15.6	164
6/22/2026	3:30:00	7.27	1.4309	0	162017.7	ON	15.9	164
6/22/2026	3:45:00	7.31	2.0479	0	162045.2	ON	14.2	161
6/22/2026	4:00:00	7.3	1.4801	0	162072.7	ON	14.4	161
6/22/2026	4:15:00	7.3	1.8927	0	162100.3	ON	13.9	162
6/22/2026	4:30:00	7.31	1.0561	0	162126.0	ON	14.2	162
6/22/2026	4:45:00	7.28	0.3142	0	162130.8	ON	14.6	163
6/22/2026	5:00:00	7.27	0.4050	0	162137.2	ON	15	161
6/22/2026	5:15:00	7.25	1.5142	0	162151.8	ON	15.4	164
6/22/2026	5:30:00	7.24	1.4195	0	162165.1	ON	15.6	164
6/22/2026	5:45:00	7.27	2.0214	0	162184.5	ON	13.8	161
6/22/2026	6:00:00	7.25	1.5444	0	162212.6	ON	13.6	163
6/22/2026	6:15:00	7.24	2.3507	0	162243.4	ON	13.3	165
6/22/2026	6:30:00	7.24	1.5104	0	162269.3	ON	13.4	165
6/22/2026	6:45:00	7.24	0.9918	0	162300.3	ON	13.7	164
6/22/2026	7:00:00	7.23	0.4959	0	162310.7	ON	15.7	163
6/22/2026	7:15:00	7.23	2.2258	0	162319.4	ON	15.3	159
6/22/2026	7:30:00	7.28	2.3167	0	162353.4	ON	14.1	163
6/22/2026	7:45:00	7.29	2.3091	0	162383.7	ON	14	161



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Valve Status	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/22/2026	8:00:00	7.29	2.0138	0	162416.0	ON	14.1	164
6/22/2026	8:15:00	7.27	0.7949	0	162441.3	ON	14.8	163
6/22/2026	8:30:00	7.26	2.2258	1	162450.4	ON	15.8	163
6/22/2026	8:45:00	7.25	0.6965	0	162470.9	ON	15.9	164
6/22/2026	9:00:00	7.27	0.3710	0	162480.3	ON	16.5	161
6/22/2026	9:15:00	7.25	0.8934	0	162496.8	ON	15.9	161
6/22/2026	9:30:00	7.25	0.2990	0	162505.3	ON	17.4	164
6/22/2026	9:45:00	7.27	2.0025	0	162523.9	ON	15.6	161
6/22/2026	10:00:00	7.27	0.7647	0	162546.1	ON	15.9	162
6/22/2026	10:15:00	7.25	0.9123	0	162554.0	ON	17.2	163
6/22/2026	10:30:00	7.28	2.1766	0	162582.4	ON	15.4	162
6/22/2026	10:45:00	7.28	2.1842	0	162614.4	ON	15.3	164
6/22/2026	11:00:00	7.28	1.8473	0	162645.9	ON	15.4	164
6/22/2026	11:15:00	7.27	0.5754	0	162665.5	ON	16.3	165
6/22/2026	11:30:00	7.28	1.9760	0	162682.2	ON	15.9	164
6/22/2026	11:45:00	7.28	2.3280	0	162711.6	ON	15.8	164
6/22/2026	12:00:00	7.27	0.4694	0	162723.7	ON	17.5	165
6/22/2026	12:15:00	7.28	2.3091	0	162738.2	ON	16.7	163
6/22/2026	12:30:00	7.29	2.3318	0	162770.8	ON	16.1	164
6/22/2026	12:45:00	7.29	1.8397	0	162802.1	ON	16	164
6/22/2026	13:00:00	7.29	1.9722	0	162834.0	ON	15.8	163
6/22/2026	13:15:00	7.27	0.4429	0	162847.4	ON	17.1	164
6/22/2026	13:30:00	7.28	2.0025	0	162868.4	ON	16.2	164
6/22/2026	13:45:00	7.29	2.3053	0	162900.7	ON	16.1	164
6/22/2026	14:00:00	7.28	2.1350	0	162929.9	ON	16.2	164
6/22/2026	14:15:00	7.29	1.5785	0	162962.6	ON	16	164
6/22/2026	14:30:00	7.26	0.6284	0	162974.0	ON	17.2	167
6/22/2026	14:45:00	7.28	0.8366	0	162999.7	ON	16.5	163
6/22/2026	15:00:00	7.27	2.2599	0	163013.3	ON	16.5	164
6/22/2026	15:15:00	7.28	2.3129	0	163047.3	ON	15.9	163
6/22/2026	15:30:00	7.26	0.5489	0	163059.3	ON	17.4	164
6/22/2026	15:45:00	7.28	2.2107	0	163077.5	ON	16.5	162



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Valve Status	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/22/2026	16:00:00	7.3	1.5861	0	163109.7	ON	16.3	164
6/22/2026	16:15:00	7.31	2.3167	0	163139.6	ON	16.1	164
6/22/2026	16:30:00	7.3	2.3015	0	163173.7	ON	16.1	164
6/22/2026	16:45:00	7.28	0.7192	0	163196.6	ON	16.9	164
6/22/2026	17:00:00	7.28	2.2750	0	163213.8	ON	16.5	163
6/22/2026	17:15:00	7.28	1.7754	0	163245.6	ON	16.4	162
6/22/2026	17:30:00	7.27	0.8744	0	163266.5	ON	16.8	164
6/22/2026	17:45:00	7.27	2.2864	0	163290.8	ON	16.1	160
6/22/2026	18:00:00	7.28	0.8934	0	163323.5	ON	16	161
6/22/2026	18:15:00	7.26	0.4391	0	163333.2	ON	17.5	163
6/22/2026	18:30:00	7.24	2.1236	0	163341.3	ON	18.1	161
6/22/2026	18:45:00	7.28	2.1653	0	163370.5	ON	16.1	160
6/22/2026	19:00:00	7.29	2.2296	0	163404.0	ON	15.5	161
6/22/2026	19:15:00	7.37	0.0416	727	163435.4	OFF	15.8	146
6/22/2026	19:30:00	7.3	1.8700	0	163462.5	ON	15.1	161
6/22/2026	19:45:00	7.29	0.2498	0	163474.5	ON	16.4	161
6/22/2026	20:00:00	7.29	2.1463	0	163494.2	ON	15.2	160
6/22/2026	20:15:00	7.29	2.1312	0	163523.1	ON	14.8	159
6/22/2026	20:30:00	7.29	1.7564	0	163548.1	ON	15	160
6/22/2026	20:45:00	7.3	2.0366	0	163577.5	ON	14.8	159
6/22/2026	21:00:00	7.3	1.3817	0	163603.4	ON	15.1	160
6/22/2026	21:15:00	7.3	1.9495	0	163629.4	ON	14.9	160
6/22/2026	21:30:00	7.29	1.2151	0	163655.4	ON	14.9	159
6/22/2026	21:45:00	7.29	0.6776	0	163671.0	ON	15.8	161
6/22/2026	22:00:00	7.26	0.7003	0	163675.7	ON	17.2	163
6/22/2026	22:15:00	7.28	1.7224	0	163694.2	ON	15.7	160
6/22/2026	22:30:00	7.29	0.6738	0	163714.6	ON	15.5	161
6/22/2026	22:45:00	7.27	0.8441	0	163723.1	ON	16.4	163
6/22/2026	23:00:00	7.28	0.4542	0	163733.2	ON	16.3	161
6/22/2026	23:15:00	7.25	0.0341	0	163734.6	ON	17.4	162
6/22/2026	23:30:00	7.28	1.6807	0	163754.6	ON	15.3	163
6/22/2026	23:45:00	7.27	1.6164	0	163776.4	ON	15	162



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Valve Status	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/23/2026	0:00:00	7.27	1.7867	0	163799.2	ON	15.1	163
6/23/2026	0:15:00	7.26	1.1356	0	163821.6	ON	15	163
6/23/2026	0:30:00	7.26	2.0895	0	163850.0	ON	14.6	163
6/23/2026	0:45:00	7.25	1.7375	0	163884.8	ON	14.4	162
6/23/2026	1:00:00	7.26	2.6649	0	163921.5	ON	14.4	162
6/23/2026	1:15:00	7.29	2.5249	0	163956.1	ON	14.5	163
6/23/2026	1:30:00	7.28	0.1590	0	163974.6	ON	15.4	163
6/23/2026	1:45:00	7.25	0.3293	0	163978.5	ON	16.3	163
6/23/2026	2:00:00	7.29	2.2750	0	164008.7	ON	14.8	163
6/23/2026	2:15:00	7.3	1.5142	0	164043.9	ON	14.6	162
6/23/2026	2:30:00	7.29	2.1880	0	164060.4	ON	14.8	164
6/23/2026	2:45:00	7.29	2.5059	0	164096.6	ON	14.3	164
6/23/2026	3:00:00	7.3	2.2069	0	164130.1	ON	14.5	164
6/23/2026	3:15:00	7.31	2.1993	0	164164.7	ON	14.6	165
6/23/2026	3:30:00	7.31	1.4120	0	164196.1	ON	15	164
6/23/2026	3:45:00	7.29	0.2309	0	164202.8	ON	15.8	165
6/23/2026	4:00:00	7.27	1.9381	1	164208.1	ON	16.3	167
6/23/2026	4:15:00	7.3	2.2712	0	164241.9	ON	14.6	165
6/23/2026	4:30:00	7.3	2.3886	0	164272.5	ON	14.7	165
6/23/2026	4:45:00	7.3	0.1060	0	164294.6	ON	15.1	165
6/23/2026	5:00:00	7.27	0.1401	0	164295.8	ON	15.8	165
6/23/2026	5:15:00	7.25	0.2839	0	164299.2	ON	16.3	168
6/23/2026	5:30:00	7.28	0.9691	0	164313.3	ON	15.1	165
6/23/2026	5:45:00	7.3	2.2750	0	164331.5	ON	14.4	165
6/23/2026	6:00:00	7.29	1.6656	0	164363.8	ON	14.1	165
6/23/2026	6:15:00	7.3	0.7003	0	164384.5	ON	14.4	165
6/23/2026	6:30:00	7.27	0.3861	0	164392.1	ON	15.3	166
6/23/2026	6:45:00	7.28	2.1728	0	164409.4	ON	14.3	165
6/23/2026	7:00:00	7.26	0.8214	0	164437.0	ON	14.3	165
6/23/2026	7:15:00	7.25	0.3861	0	164445.3	ON	15	165
6/23/2026	7:30:00	7.27	2.0441	0	164469.0	ON	14.3	165
6/23/2026	7:45:00	7.27	1.2605	0	164497.7	ON	14.3	166



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Valve Status	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/23/2026	8:00:00	7.27	1.8965	0	164524.3	ON	14.3	165
6/23/2026	8:15:00	7.28	1.7754	0	164547.6	ON	14.5	165
6/23/2026	8:30:00	7.27	0.9047	0	164565.6	ON	14.8	165
6/23/2026	8:45:00	7.27	0.9009	0	164584.0	ON	15	164
6/23/2026	9:00:00	7.25	0.1741	0	164591.7	ON	16.1	166
6/23/2026	9:15:00	7.23	0.0227	0	164593.1	ON	17.6	166
6/23/2026	9:30:00	7.21	0.0227	0	164594.4	ON	18.9	168
6/23/2026	9:45:00	7.25	1.3438	1	164605.1	ON	17.4	163
6/23/2026	10:00:00	7.26	1.0448	0	164625.5	ON	16.4	162
6/23/2026	10:15:00	7.27	1.8321	0	164647.0	ON	16	161
6/23/2026	10:30:00	7.28	2.3810	0	164679.2	ON	15.5	161
6/23/2026	10:45:00	7.28	2.3545	0	164710.3	ON	15.6	162
6/23/2026	11:00:00	7.29	2.0933	0	164739.3	ON	16.1	163
6/23/2026	11:15:00	7.3	2.3735	0	164772.1	ON	16.1	161
6/23/2026	11:30:00	7.28	0.1211	0	164788.6	ON	17.6	162
6/23/2026	11:45:00	7.29	2.2637	0	164811.9	ON	16.5	159
6/23/2026	12:00:00	7.28	1.3514	0	164835.1	ON	16.5	159
6/23/2026	12:15:00	7.26	1.1924	0	164856.1	ON	18.3	162
6/23/2026	12:30:00	7.22	0.3558	1	164861.1	ON	19.8	164
6/23/2026	12:45:00	7.2	0.3710	1	164867.7	ON	21.2	165
6/23/2026	13:00:00	7.25	2.0668	1	164876.5	ON	17.2	158
6/23/2026	13:15:00	7.26	0.3104	0	164899.1	ON	17.8	161
6/23/2026	13:30:00	7.3	2.2031	1	164919.9	ON	15.7	163
6/23/2026	13:45:00	7.3	1.9154	0	164952.3	ON	16.1	162
6/23/2026	14:00:00	7.31	1.0713	0	164980.3	ON	16.9	161
6/23/2026	14:15:00	7.29	2.1804	8	164986.7	ON	17.4	158
6/23/2026	14:30:00	7.31	2.3735	0	165020.2	ON	15.5	163
6/23/2026	14:45:00	7.33	1.5407	0	165052.4	ON	16.1	162
6/23/2026	15:00:00	7.29	0.2877	0	165060.3	ON	18.3	163
6/23/2026	15:15:00	7.27	0.3180	1	165064.5	ON	20.1	164
6/23/2026	15:30:00	7.21	0.3710	1	165070.0	ON	21.6	165
6/23/2026	15:45:00	7.29	2.0517	0	165086.6	ON	16.8	162



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Valve Status	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/23/2026	16:00:00	7.3	0.1438	1	165105.8	ON	18.2	162
6/23/2026	16:15:00	7.3	0.7571	3	165114.9	ON	18.4	162
6/23/2026	16:30:00	7.31	2.0706	0	165134.9	ON	17.5	160
6/23/2026	16:45:00	7.32	2.0517	0	165165.6	ON	17	160
6/23/2026	17:00:00	7.31	0.1401	0	165186.4	ON	18.3	161
6/23/2026	17:15:00	7.27	0.1703	0	165189.5	ON	20.3	164
6/23/2026	17:30:00	7.29	2.3697	0	165217.5	ON	16.9	160
6/23/2026	17:45:00	7.29	0.1173	0	165237.9	ON	18.4	161
6/23/2026	18:00:00	7.3	2.3697	0	165251.5	ON	17.3	160
6/23/2026	18:15:00	7.33	2.3621	0	165285.6	ON	16.5	161
6/23/2026	18:30:00	7.33	2.3470	0	165319.7	ON	16.4	162
6/23/2026	18:45:00	7.32	0.8896	0	165348.3	ON	17.3	163
6/23/2026	19:00:00	7.31	2.3318	1	165357.0	ON	16.8	161
6/23/2026	19:15:00	7.32	1.3022	0	165388.0	ON	16.9	161
6/23/2026	19:30:00	7.29	0.1514	0	165392.5	ON	18.9	164
6/23/2026	19:45:00	7.28	2.3053	1	165401.1	ON	17.2	160
6/23/2026	20:00:00	7.3	2.0063	0	165434.6	ON	15.9	161
6/23/2026	20:15:00	7.29	1.9873	0	165467.7	ON	16.1	160
6/23/2026	20:30:00	7.27	0.2612	0	165481.7	ON	17.6	161
6/23/2026	20:45:00	7.24	0.2801	1	165485.1	ON	19.1	163
6/23/2026	21:00:00	7.21	0.2461	1	165488.5	ON	20.3	163
6/23/2026	21:15:00	7.19	0.2082	1	165491.9	ON	21.1	163
6/23/2026	21:30:00	7.26	1.7602	0	165514.5	ON	16.7	158
6/23/2026	21:45:00	7.24	0.4694	1	165525.7	ON	18.1	161
6/23/2026	22:00:00	7.22	1.2605	1	165533.4	ON	19.2	165
6/23/2026	22:15:00	7.27	2.1047	0	165562.6	ON	15.7	157
6/23/2026	22:30:00	7.27	2.0782	0	165593.3	ON	15.2	160
6/23/2026	22:45:00	7.29	2.0820	0	165624.0	ON	15.1	160
6/23/2026	23:00:00	7.3	2.0366	0	165654.6	ON	15.1	162
6/23/2026	23:15:00	7.29	0.1893	0	165670.2	ON	16.4	163
6/23/2026	23:30:00	7.29	1.9949	1	165679.1	ON	15.5	162
6/23/2026	23:45:00	7.3	1.9949	0	165709.8	ON	15.2	161



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Valve Status	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/24/2026	0:00:00	7.29	0.1741	0	165726.0	ON	16.4	162
6/24/2026	0:15:00	7.3	0.5527	2	165730.6	ON	17.3	165
6/24/2026	0:30:00	7.28	0.2612	2	165742.1	ON	17.7	165
6/24/2026	0:45:00	7.3	2.0403	1	165755.6	ON	15.6	161
6/24/2026	1:00:00	7.28	1.9533	1	165784.3	ON	15.6	164
6/24/2026	1:15:00	7.28	1.8549	1	165810.0	ON	16.1	163
6/24/2026	1:30:00	7.3	2.3091	0	165839.5	ON	14.7	161
6/24/2026	1:45:00	7.31	1.6694	1	165870.3	ON	14.9	163
6/24/2026	2:00:00	7.3	0.0265	1	165897.5	ON	15.2	161
6/24/2026	2:15:00	7.27	0.5413	1	165901.0	ON	16.1	165
6/24/2026	2:30:00	7.31	0.6359	5	165910.5	ON	15.2	161
6/24/2026	2:45:00	7.29	0.3823	2	165925.8	ON	15.6	161
6/24/2026	3:00:00	7.3	2.3507	0	165956.8	ON	14.2	161
6/24/2026	3:15:00	7.29	0.1438	1	165972.7	ON	15.3	161
6/24/2026	3:30:00	7.27	0.3180	1	165976.1	ON	16.1	162
6/24/2026	3:45:00	7.29	2.3924	1	166003.7	ON	14.2	161
6/24/2026	4:00:00	7.3	1.9533	0	166039.1	ON	14.1	162
6/24/2026	4:15:00	7.31	2.3659	0	166072.0	ON	13.9	162
6/24/2026	4:30:00	7.3	0.2158	0	166085.0	ON	15.1	161
6/24/2026	4:45:00	7.3	2.3583	0	166109.0	ON	14	163
6/24/2026	5:00:00	7.3	0.1022	0	166127.8	ON	14.9	161
6/24/2026	5:15:00	7.28	0.2120	0	166131.1	ON	15.6	163
6/24/2026	5:30:00	7.26	0.2196	0	166134.5	ON	16.3	164
6/24/2026	5:45:00	7.28	2.3621	0	166150.0	ON	14.3	161
6/24/2026	6:00:00	7.3	2.2334	0	166184.8	ON	13.9	161
6/24/2026	6:15:00	7.3	2.3545	0	166216.3	ON	13.8	161
6/24/2026	6:30:00	7.31	1.1508	0	166246.0	ON	14.3	161
6/24/2026	6:45:00	7.29	0.1703	0	166249.5	ON	15.1	161
6/24/2026	7:00:00	7.31	0.4580	1	166254.7	ON	14.8	163
6/24/2026	7:15:00	7.31	2.3583	0	166284.4	ON	13.9	161
6/24/2026	7:30:00	7.33	1.6126	0	166315.0	ON	14.2	158
6/24/2026	7:45:00	7.3	0.1968	0	166324.3	ON	15.2	161



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Valve Status	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/24/2026	8:00:00	7.3	2.3583	0	166339.9	ON	14.3	160
6/24/2026	8:15:00	7.29	2.3167	0	166373.6	ON	14	160
6/24/2026	8:30:00	7.29	1.6618	0	166405.4	ON	14.6	159
6/24/2026	8:45:00	7.28	2.1993	0	166435.7	ON	14.4	159
6/24/2026	9:00:00	7.28	2.1918	0	166468.4	ON	14.4	160
6/24/2026	9:15:00	7.28	2.1312	0	166496.6	ON	14.6	158
6/24/2026	9:30:00	7.27	0.0946	0	166510.1	ON	16.1	159
6/24/2026	9:45:00	7.25	0.1363	0	166511.3	ON	17.5	160
6/24/2026	10:00:00	7.23	0.1590	0	166514.7	ON	18.7	161
6/24/2026	10:15:00	7.27	1.6656	1	166520.7	ON	18.7	158
6/24/2026	10:30:00	7.24	0.2271	1	166536.1	ON	19.6	164
6/24/2026	10:45:00	7.26	0.2990	0	166552.1	ON	17.6	159
6/24/2026	11:00:00	7.24	0.2574	1	166555.7	ON	18.8	161
6/24/2026	11:15:00	7.25	1.4915	0	166579.4	ON	17.3	159
6/24/2026	11:30:00	7.25	1.8700	0	166595.9	ON	15.6	159
6/24/2026	11:45:00	7.25	2.1123	0	166622.8	ON	15.4	160
6/24/2026	12:00:00	7.24	2.0820	1	166651.6	ON	16.5	161
6/24/2026	12:15:00	7.22	1.1470	0	166675.9	ON	17.5	159
6/24/2026	12:30:00	7.2	0.0189	1	166693.3	ON	19.1	163
6/24/2026	12:45:00	7.18	0.1249	1	166694.8	ON	20.4	163
6/24/2026	13:00:00	7.24	1.9268	0	166712.7	ON	16.5	158
6/24/2026	13:15:00	7.28	0.0379	0	166733.5	ON	16.5	159
6/24/2026	13:30:00	7.26	1.5861	1	166735.5	ON	18.1	163
6/24/2026	13:45:00	7.29	1.9760	1	166763.4	ON	16.8	159
6/24/2026	14:00:00	7.29	1.9684	1	166794.1	ON	16.4	161
6/24/2026	14:15:00	7.29	1.8586	1	166819.6	ON	16	160
6/24/2026	14:30:00	7.29	0.4732	1	166839.3	ON	16.9	161
6/24/2026	14:45:00	7.27	0.9918	1	166847.5	ON	17.5	161
6/24/2026	15:00:00	7.29	0.7722	1	166874.4	ON	16.8	161
6/24/2026	15:15:00	7.28	0.4997	0	166888.1	ON	17.2	162
6/24/2026	15:30:00	7.3	0.9993	1	166914.6	ON	16.6	162
6/24/2026	15:45:00	7.27	0.3634	1	166922.7	ON	18.4	163



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Valve Status	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/24/2026	16:00:00	7.31	2.0479	1	166941.8	ON	16.8	161
6/24/2026	16:15:00	7.29	1.6769	1	166958.8	ON	16.7	161
6/24/2026	16:30:00	7.28	0.4391	1	166969.2	ON	17.7	164
6/24/2026	16:45:00	7.25	0.2612	1	166974.9	ON	19.5	165
6/24/2026	17:00:00	7.29	0.5640	3	166978.9	ON	20.1	164
6/24/2026	17:15:00	7.26	2.2183	1	166999.6	ON	16.7	161
6/24/2026	17:30:00	7.27	2.1993	0	167033.1	ON	16.1	162
6/24/2026	17:45:00	7.26	0.4807	1	167045.7	ON	17.2	164
6/24/2026	18:00:00	7.25	0.4164	1	167052.5	ON	18.3	164
6/24/2026	18:15:00	7.24	0.4240	1	167059.2	ON	18.6	165
6/24/2026	18:30:00	7.27	1.2568	1	167075.3	ON	17	160
6/24/2026	18:45:00	7.27	1.2643	1	167096.7	ON	16.4	162
6/24/2026	19:00:00	7.29	2.1160	1	167125.6	ON	15.7	162
6/24/2026	19:15:00	7.3	2.0744	0	167156.2	ON	15.5	163
6/24/2026	19:30:00	7.3	2.0328	0	167182.5	ON	15.4	163
6/24/2026	19:45:00	7.3	1.9722	0	167213.2	ON	15.3	163
6/24/2026	20:00:00	7.29	1.7791	0	167238.2	ON	15.5	161
6/24/2026	20:15:00	7.28	0.3748	0	167249.8	ON	16.5	163
6/24/2026	20:30:00	7.29	1.1243	0	167268.9	ON	15.6	160
6/24/2026	20:45:00	7.29	1.7224	0	167289.9	ON	15.3	161
6/24/2026	21:00:00	7.28	0.1552	1	167301.2	ON	16.3	161
6/24/2026	21:15:00	7.24	0.6852	0	167304.4	ON	17.6	164
6/24/2026	21:30:00	7.28	0.4278	0	167312.4	ON	16.8	160
6/24/2026	21:45:00	7.28	0.4883	1	167318.4	ON	17	160
6/24/2026	22:00:00	7.29	0.9009	1	167325.7	ON	16.1	159
6/24/2026	22:15:00	7.3	1.4990	1	167343.5	ON	15.1	160
6/24/2026	22:30:00	7.29	1.3362	0	167361.4	ON	15	160
6/24/2026	22:45:00	7.28	0.5602	0	167374.6	ON	15.4	162
6/24/2026	23:00:00	7.29	2.2069	1	167385.7	ON	14.9	161
6/24/2026	23:15:00	7.3	1.8208	1	167418.3	ON	14.9	161
6/24/2026	23:30:00	7.3	2.2826	1	167450.6	ON	14.5	162
6/24/2026	23:45:00	7.29	0.1211	1	167466.1	ON	15.8	161



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Valve Status	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/25/2026	0:00:00	7.29	1.5520	1	167472.1	ON	16.8	165
6/25/2026	0:15:00	7.25	0.0341	1	167478.1	ON	17.6	163
6/25/2026	0:30:00	7.3	2.2599	1	167490.9	ON	15.1	161
6/25/2026	0:45:00	7.32	2.2599	1	167524.3	ON	14.6	163
6/25/2026	1:00:00	7.32	2.2712	1	167554.5	ON	14.6	162
6/25/2026	1:15:00	7.33	1.0448	1	167584.1	ON	15.2	163
6/25/2026	1:30:00	7.31	0.1060	1	167586.0	ON	16.3	164
6/25/2026	1:45:00	7.31	2.2826	1	167596.2	ON	15	163
6/25/2026	2:00:00	7.34	1.8019	0	167629.5	ON	14.6	163
6/25/2026	2:15:00	7.31	0.1476	1	167642.3	ON	15.6	163
6/25/2026	2:30:00	7.29	0.0454	1	167644.7	ON	16.4	165
6/25/2026	2:45:00	7.3	0.4050	1	167648.0	ON	17	166
6/25/2026	3:00:00	7.33	1.8586	1	167659.0	ON	15.2	163
6/25/2026	3:15:00	7.31	0.2158	1	167670.1	ON	16.1	165
6/25/2026	3:30:00	7.33	2.3091	1	167691.9	ON	14.4	164
6/25/2026	3:45:00	7.33	2.3167	1	167725.6	ON	14.1	164
6/25/2026	4:00:00	7.34	2.2410	1	167758.7	ON	14.1	168
6/25/2026	4:15:00	7.35	2.2334	1	167791.9	ON	14	166
6/25/2026	4:30:00	7.34	0.4845	1	167812.1	ON	14.6	165
6/25/2026	4:45:00	7.33	2.2258	1	167828.0	ON	14.1	165
6/25/2026	5:00:00	7.33	0.7382	1	167855.5	ON	14.3	165
6/25/2026	5:15:00	7.32	0.5262	1	167865.4	ON	14.6	165
6/25/2026	5:30:00	7.31	0.4656	1	167872.1	ON	15.1	166
6/25/2026	5:45:00	7.29	0.8252	1	167879.1	ON	15.6	167
6/25/2026	6:00:00	7.33	1.5709	1	167907.8	ON	14.2	166
6/25/2026	6:15:00	7.33	2.0858	1	167936.4	ON	13.9	165
6/25/2026	6:30:00	7.33	2.0858	1	167966.6	ON	13.9	165
6/25/2026	6:45:00	7.33	2.0441	1	167993.5	ON	13.9	166
6/25/2026	7:00:00	7.33	0.6624	1	168014.9	ON	14.4	165
6/25/2026	7:15:00	7.32	1.0561	1	168024.4	ON	14.6	166
6/25/2026	7:30:00	7.33	1.9571	1	168054.9	ON	14.2	166
6/25/2026	7:45:00	7.33	1.2265	1	168081.0	ON	14.3	163



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Valve Status	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/25/2026	8:00:00	7.32	0.6852	1	168099.6	ON	14.5	164
6/25/2026	8:15:00	7.3	0.3180	1	168106.3	ON	15.4	164
6/25/2026	8:30:00	7.28	0.2612	1	168109.8	ON	16.3	165
6/25/2026	8:45:00	7.3	0.7949	1	168118.2	ON	15.5	163
6/25/2026	9:00:00	7.3	0.0265	1	168125.2	ON	15.8	164
6/25/2026	9:15:00	7.27	1.8700	1	168126.2	ON	16.4	166
6/25/2026	9:30:00	7.3	1.0940	1	168149.5	ON	14.9	161
6/25/2026	9:45:00	7.29	1.6959	0	168168.5	ON	14.8	162
6/25/2026	10:00:00	7.27	1.1318	0	168187.1	ON	14.9	162
6/25/2026	10:15:00	7.27	1.4574	0	168204.8	ON	14.9	164
6/25/2026	10:30:00	7.27	1.4725	1	168224.4	ON	14.7	163
6/25/2026	10:45:00	7.27	1.9495	1	168252.9	ON	14.5	163
6/25/2026	11:00:00	7.27	1.5709	1	168281.4	ON	15.5	162
6/25/2026	11:15:00	7.24	1.6542	1	168304.3	ON	16.6	165
6/25/2026	11:30:00	7.27	1.5823	0	168333.0	ON	15.5	162
6/25/2026	11:45:00	7.24	0.1211	0	168348.8	ON	16.6	163
6/25/2026	12:00:00	7.25	0.2461	1	168352.2	ON	17.4	164
6/25/2026	12:15:00	7.27	1.9306	1	168373.9	ON	14.8	163
6/25/2026	12:30:00	7.27	0.5602	1	168394.4	ON	15.1	161
6/25/2026	12:45:00	7.25	0.3028	1	168399.3	ON	16.3	164
6/25/2026	13:00:00	7.27	1.0523	1	168406.7	ON	15.9	161
6/25/2026	13:15:00	7.27	2.0063	0	168437.6	ON	14.6	161
6/25/2026	13:30:00	7.27	0.3255	0	168455.0	ON	15.4	162
6/25/2026	13:45:00	7.25	0.1211	1	168457.3	ON	16.5	164
6/25/2026	14:00:00	7.28	0.4656	1	168465.4	ON	15.8	162
6/25/2026	14:15:00	7.31	1.7261	1	168478.3	ON	15.2	165
6/25/2026	14:30:00	7.3	0.7457	1	168494.4	ON	15.6	164
6/25/2026	14:45:00	7.31	0.7079	1	168511.8	ON	14.9	166
6/25/2026	15:00:00	7.33	0.9085	1	168530.7	ON	15	168
6/25/2026	15:15:00	7.33	0.7344	1	168542.8	ON	15.1	168
6/25/2026	15:30:00	7.33	2.1236	1	168558.4	ON	14.7	167
6/25/2026	15:45:00	7.32	1.6202	1	168585.6	ON	14.8	168



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Valve Status	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/25/2026	16:00:00	7.31	0.5981	1	168599.8	ON	15.2	165
6/25/2026	16:15:00	7.31	0.8820	8	168608.1	ON	15.4	167
6/25/2026	16:30:00	7.3	1.4650	1	168622.7	ON	14.8	165
6/25/2026	16:45:00	7.29	0.2461	1	168633.1	ON	15.6	165
6/25/2026	17:00:00	7.3	2.3924	1	168643.3	ON	14.9	164
6/25/2026	17:15:00	7.31	2.5665	1	168678.6	ON	14.6	164
6/25/2026	17:30:00	7.31	2.1955	1	168709.7	ON	14.5	164
6/25/2026	17:45:00	7.31	2.2069	1	168744.9	ON	14.4	162
6/25/2026	18:00:00	7.3	0.2650	1	168761.5	ON	15.5	163
6/25/2026	18:15:00	7.31	0.9464	1	168772.4	ON	15	161
6/25/2026	18:30:00	7.32	0.9199	1	168793.3	ON	15	161
6/25/2026	18:45:00	7.33	2.4529	1	168824.1	ON	14.3	162
6/25/2026	19:00:00	7.34	1.5747	0	168857.1	ON	14.7	161
6/25/2026	19:15:00	7.34	2.0895	0	168887.2	ON	14.4	159
6/25/2026	19:30:00	7.34	1.3514	0	168917.2	ON	14.8	160
6/25/2026	19:45:00	7.32	0.1855	0	168923.1	ON	15.8	161
6/25/2026	20:00:00	7.29	1.2000	1	168926.8	ON	16.5	164
6/25/2026	20:15:00	7.31	1.4801	0	168953.1	ON	15.4	161
6/25/2026	20:30:00	7.31	1.3249	0	168978.6	ON	15.1	159
6/25/2026	20:45:00	7.28	0.2120	1	168984.6	ON	15.8	161
6/25/2026	21:00:00	7.26	0.2271	1	168988.0	ON	16.5	161
6/25/2026	21:15:00	7.3	2.2334	1	169012.8	ON	14.3	159
6/25/2026	21:30:00	7.31	1.2605	0	169043.4	ON	14.4	159
6/25/2026	21:45:00	7.3	0.5527	1	169050.7	ON	15	161
6/25/2026	22:00:00	7.31	2.2410	1	169069.3	ON	14	159
6/25/2026	22:15:00	7.3	0.1817	0	169094.2	ON	14.8	158
6/25/2026	22:30:00	7.28	0.2650	1	169097.6	ON	15.4	161
6/25/2026	22:45:00	7.32	1.6542	0	169119.5	ON	14.5	160
6/25/2026	23:00:00	7.29	0.3369	1	169129.2	ON	15.2	161
6/25/2026	23:15:00	7.27	0.1855	1	169132.8	ON	15.8	161
6/25/2026	23:30:00	7.31	1.9760	1	169159.2	ON	13.8	161
6/25/2026	23:45:00	7.31	1.9684	1	169189.8	ON	13.6	161



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Valve Status	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/26/2026	0:00:00	7.3	1.9381	0	169216.3	ON	13.7	161
6/26/2026	0:15:00	7.3	1.2227	0	169244.3	ON	13.7	163
6/26/2026	0:30:00	7.29	0.1552	0	169251.7	ON	14.6	163
6/26/2026	0:45:00	7.29	1.8586	0	169273.5	ON	13.7	161
6/26/2026	1:00:00	7.29	0.4959	1	169291.9	ON	14.1	163
6/26/2026	1:15:00	7.27	0.2158	0	169296.8	ON	14.8	163
6/26/2026	1:30:00	7.25	0.2044	1	169301.3	ON	15.3	163
6/26/2026	1:45:00	7.3	1.6504	1	169313.5	ON	13.9	163
6/26/2026	2:00:00	7.31	1.5558	0	169335.3	ON	13.7	162
6/26/2026	2:15:00	7.31	1.4801	0	169360.6	ON	13.6	163
6/26/2026	2:30:00	7.31	1.1697	0	169379.4	ON	13.8	162
6/26/2026	2:45:00	7.32	1.9419	0	169401.5	ON	13.8	161
6/26/2026	3:00:00	7.31	1.4082	1	169429.8	ON	13.5	162
6/26/2026	3:15:00	7.3	2.1955	1	169458.1	ON	13.3	164
6/26/2026	3:30:00	7.3	0.2725	0	169469.8	ON	14	162
6/26/2026	3:45:00	7.28	0.1931	0	169473.8	ON	14.6	162
6/26/2026	4:00:00	7.29	1.8624	0	169490.4	ON	13.5	163
6/26/2026	4:15:00	7.29	0.9615	0	169515.3	ON	13.5	162
6/26/2026	4:30:00	7.28	0.1968	1	169522.2	ON	14.1	162
6/26/2026	4:45:00	7.3	1.3627	1	169534.2	ON	13.5	161
6/26/2026	5:00:00	7.3	1.8700	0	169561.9	ON	13.3	161
6/26/2026	5:15:00	7.3	2.1918	1	169591.6	ON	13.3	163
6/26/2026	5:30:00	7.3	1.8624	0	169618.6	ON	13.3	161
6/26/2026	5:45:00	7.3	0.3975	0	169634.9	ON	13.7	161
6/26/2026	6:00:00	7.29	2.1955	1	169647.3	ON	13.4	161
6/26/2026	6:15:00	7.27	1.8700	0	169677.6	ON	13.2	162
6/26/2026	6:30:00	7.27	1.5937	0	169706.3	ON	13.3	162
6/26/2026	6:45:00	7.27	0.1287	1	169715.9	ON	13.9	161
6/26/2026	7:00:00	7.29	0.4694	1	169726.1	ON	13.7	161
6/26/2026	7:15:00	7.27	0.2688	1	169730.1	ON	14.5	161
6/26/2026	7:30:00	7.31	2.1804	1	169741.7	ON	13.7	161
6/26/2026	7:45:00	7.32	2.1388	1	169771.3	ON	13.5	161



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Valve Status	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/26/2026	8:00:00	7.31	0.7798	1	169793.1	ON	14.1	162
6/26/2026	8:15:00	7.31	1.8776	1	169808.5	ON	14.6	159
6/26/2026	8:30:00	7.3	1.3249	1	169831.7	ON	14.5	159
6/26/2026	8:45:00	7.29	0.9918	1	169847.6	ON	14.5	160
6/26/2026	9:00:00	7.28	0.8782	1	169862.1	ON	15.4	159
6/26/2026	9:15:00	7.29	1.5331	1	169887.9	ON	15.7	158
6/26/2026	9:30:00	7.29	1.5861	1	169910.6	ON	16.3	157
6/26/2026	9:45:00	7.29	1.5596	1	169938.9	ON	17	156
6/26/2026	10:00:00	7.3	0.5110	1	169946.9	ON	18.2	161
6/26/2026	10:15:00	7.28	1.4839	2	169958.0	ON	19.8	156
6/26/2026	10:30:00	7.25	0.4921	2	169965.9	ON	20.2	157
6/26/2026	10:45:00	7.28	1.1697	2	169980.2	ON	21.5	157
6/26/2026	11:00:00	7.29	0.3861	2	169993.8	ON	24.1	162
6/26/2026	11:15:00	7.3	2.2637	1	170023.7	ON	16	156
6/26/2026	11:30:00	7.29	0.2347	1	170041.2	ON	18.8	158
6/26/2026	11:45:00	7.29	2.2675	1	170051.2	ON	16.5	154
6/26/2026	12:00:00	7.3	2.2485	1	170085.2	ON	15.7	158
6/26/2026	12:15:00	7.31	1.6845	1	170116.7	ON	16.7	158
6/26/2026	12:30:00	7.33	2.2183	1	170149.8	ON	15.5	157
6/26/2026	12:45:00	7.3	0.1325	1	170160.8	ON	19.1	159
6/26/2026	13:00:00	7.32	2.1918	1	170175.5	ON	16.1	155
6/26/2026	13:15:00	7.34	2.1955	1	170199.1	ON	15.3	158
6/26/2026	13:30:00	7.36	1.6012	1	170231.0	ON	15.5	159
6/26/2026	13:45:00	7.32	0.5262	1	170242.0	ON	18.4	161
6/26/2026	14:00:00	7.32	0.1552	2	170252.5	ON	20.5	164
6/26/2026	14:15:00	7.3	0.2461	3	170256.0	ON	24.1	164
6/26/2026	14:30:00	7.27	0.3596	2	170260.0	ON	24.9	165
6/26/2026	14:45:00	7.34	1.9873	1	170287.3	ON	15.9	159
6/26/2026	15:00:00	7.33	1.5520	1	170313.2	ON	17	159
6/26/2026	15:15:00	7.31	1.5634	1	170338.0	ON	18.4	162
6/26/2026	15:30:00	7.28	0.1438	1	170346.7	ON	19.5	163
6/26/2026	15:45:00	7.33	1.7375	1	170371.5	ON	14.7	158



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Valve Status	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/26/2026	16:00:00	7.33	1.6467	1	170393.3	ON	14.6	160
6/26/2026	16:15:00	7.33	2.2675	1	170426.0	ON	14.3	160
6/26/2026	16:30:00	7.32	2.3659	1	170458.2	ON	14.3	161
6/26/2026	16:45:00	7.35	0.0114	67	170484.0	ON	14.2	161
6/26/2026	17:00:00	7.43	0.1968	725	170503.1	ON	17.6	0
6/26/2026	17:15:00	7.67	0.1855	1	170506.5	ON	19	370
6/26/2026	17:30:00	7.68	0.1401	1	170509.9	ON	19.6	366
6/26/2026	17:45:00	7.32	1.9116	1	170524.1	ON	15.9	162
6/26/2026	18:00:00	7.32	2.2447	1	170555.4	ON	14.5	163
6/26/2026	18:15:00	7.32	2.2372	1	170589.5	ON	14.2	163
6/26/2026	18:30:00	7.31	2.2675	2	170620.6	ON	14.1	165
6/26/2026	18:45:00	7.31	1.3173	1	170651.7	ON	14.5	165
6/26/2026	19:00:00	7.3	0.2461	1	170656.3	ON	15.1	165
6/26/2026	19:15:00	7.29	2.2258	1	170686.7	ON	13.8	166
6/26/2026	19:30:00	7.3	1.8397	0	170720.3	ON	13.8	166
6/26/2026	19:45:00	7.29	0.1022	1	170738.8	ON	14.7	164
6/26/2026	20:00:00	7.28	0.2725	1	170742.1	ON	15.2	166
6/26/2026	20:15:00	7.28	2.2750	1	170768.3	ON	13.7	165
6/26/2026	20:30:00	7.28	2.2523	0	170802.4	ON	13.5	165
6/26/2026	20:45:00	7.28	1.9722	0	170833.7	ON	14	164
6/26/2026	21:00:00	7.29	0.1136	0	170848.2	ON	14.3	162
6/26/2026	21:15:00	7.28	0.2385	1	170851.6	ON	14.8	163
6/26/2026	21:30:00	7.27	0.2461	1	170855.0	ON	15.3	164
6/26/2026	21:45:00	7.28	2.1955	1	170873.2	ON	13.5	162
6/26/2026	22:00:00	7.29	2.2107	1	170904.3	ON	13.3	162
6/26/2026	22:15:00	7.3	2.1918	0	170938.4	ON	13.1	162
6/26/2026	22:30:00	7.29	1.9495	0	170968.8	ON	13.7	160
6/26/2026	22:45:00	7.31	2.1728	0	171002.6	ON	13.1	161
6/26/2026	23:00:00	7.31	0.3558	0	171015.5	ON	14.1	161
6/26/2026	23:15:00	7.3	0.2120	1	171019.5	ON	14.5	161
6/26/2026	23:30:00	7.3	1.5331	2	171038.1	ON	14.8	161
6/26/2026	23:45:00	7.28	1.5066	1	171060.7	ON	15.1	161



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Valve Status	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/27/2026	0:00:00	7.29	2.0782	0	171089.5	ON	13.2	158
6/27/2026	0:15:00	7.31	1.5369	1	171118.7	ON	13.7	158
6/27/2026	0:30:00	7.3	1.8813	0	171142.8	ON	13.6	159
6/27/2026	0:45:00	7.32	1.7791	0	171168.9	ON	13.9	159
6/27/2026	1:00:00	7.3	1.5066	0	171191.7	ON	14.2	159
6/27/2026	1:15:00	7.3	0.1741	0	171203.9	ON	14.4	160
6/27/2026	1:30:00	7.3	1.1735	1	171208.3	ON	14.2	158
6/27/2026	1:45:00	7.33	1.5937	1	171232.3	ON	13.8	160
6/27/2026	2:00:00	7.32	0.2915	1	171248.0	ON	14.1	161
6/27/2026	2:15:00	7.31	0.9880	1	171265.0	ON	14	160
6/27/2026	2:30:00	7.34	1.5785	1	171272.0	ON	13.5	160
6/27/2026	2:45:00	7.31	0.7609	1	171286.0	ON	13.7	161
6/27/2026	3:00:00	7.35	0.9615	2	171292.3	ON	13.4	161
6/27/2026	3:15:00	7.3	0.0151	47	171302.3	OFF	12.7	161
6/27/2026	3:30:00	7.31	0.0341	3	171306.5	ON	12.8	161
6/27/2026	3:45:00	7.3	2.3318	1	171320.1	ON	12.5	165
6/27/2026	4:00:00	7.28	2.1955	1	171351.3	ON	12.4	165
6/27/2026	4:15:00	7.29	1.9306	0	171381.8	ON	12.4	164
6/27/2026	4:30:00	7.29	1.8889	1	171406.8	ON	12.4	163
6/27/2026	4:45:00	7.29	0.3558	0	171425.1	ON	12.8	161
6/27/2026	5:00:00	7.28	0.0908	1	171426.7	ON	13.4	160
6/27/2026	5:15:00	7.27	0.2915	0	171428.4	ON	13.7	161
6/27/2026	5:30:00	7.29	1.9533	0	171454.4	ON	12.6	163
6/27/2026	5:45:00	7.29	2.2485	1	171482.0	ON	12.6	163
6/27/2026	6:00:00	7.29	2.2523	1	171514.1	ON	12.5	163
6/27/2026	6:15:00	7.3	0.8934	0	171541.7	ON	12.6	163
6/27/2026	6:30:00	7.3	0.3975	1	171549.8	ON	13.1	161
6/27/2026	6:45:00	7.3	1.5293	0	171570.1	ON	12.5	162
6/27/2026	7:00:00	7.29	2.2523	1	171600.2	ON	12.5	162
6/27/2026	7:15:00	7.29	0.8820	0	171614.5	ON	12.8	161
6/27/2026	7:30:00	7.28	2.1047	1	171643.4	ON	12.6	163
6/27/2026	7:45:00	7.28	0.5640	1	171666.5	ON	13.1	159



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Valve Status	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/27/2026	8:00:00	7.27	0.1287	0	171669.9	ON	14	160
6/27/2026	8:15:00	7.28	0.7987	4	171676.6	ON	14.2	161
6/27/2026	8:30:00	7.27	1.7678	1	171688.9	ON	14.1	161
6/27/2026	8:45:00	7.28	1.6694	1	171712.1	ON	14	160
6/27/2026	9:00:00	7.29	1.4157	1	171734.1	ON	14.2	161
6/27/2026	9:15:00	7.28	1.3930	1	171757.8	ON	15.5	161
6/27/2026	9:30:00	7.25	2.1577	2	171771.7	ON	17.5	167
6/27/2026	9:45:00	7.23	0.7306	1	171782.2	ON	18.9	170
6/27/2026	10:00:00	7.24	1.9836	1	171806.6	ON	15.9	181
6/27/2026	10:15:00	7.23	1.7754	1	171836.0	ON	15.4	185
6/27/2026	10:30:00	7.22	1.5179	1	171860.7	ON	16.8	186
6/27/2026	10:45:00	7.2	1.4915	1	171884.2	ON	18.8	188
6/27/2026	11:00:00	7.22	1.5293	1	171903.6	ON	18.2	182
6/27/2026	11:15:00	7.25	2.1993	1	171932.1	ON	14.8	175
6/27/2026	11:30:00	7.25	0.1098	1	171955.5	ON	16.2	176
6/27/2026	11:45:00	7.23	1.0826	1	171966.4	ON	17.2	177
6/27/2026	12:00:00	7.27	1.8132	1	171983.9	ON	16.4	172
6/27/2026	12:15:00	7.27	0.0114	1	172001.9	ON	16.9	172
6/27/2026	12:30:00	7.27	2.1804	2	172015.0	ON	15.2	170
6/27/2026	12:45:00	7.27	2.2183	1	172049.1	ON	14.9	166
6/27/2026	13:00:00	7.27	2.1236	1	172083.0	ON	14.9	167
6/27/2026	13:15:00	7.27	2.1615	1	172115.8	ON	14.9	165
6/27/2026	13:30:00	7.26	0.2990	1	172131.3	ON	16.8	165
6/27/2026	13:45:00	7.26	1.8435	1	172145.0	ON	15.2	165
6/27/2026	14:00:00	7.28	1.2113	4	172163.6	ON	15.2	163
6/27/2026	14:15:00	7.26	1.9457	1	172187.0	ON	15.1	164
6/27/2026	14:30:00	7.28	1.1243	2	172204.2	ON	15.2	162
6/27/2026	14:45:00	7.28	1.7526	1	172226.7	ON	15.1	161
6/27/2026	15:00:00	7.31	1.3135	6	172249.0	ON	15.4	160
6/27/2026	15:15:00	7.31	1.2795	5	172258.3	ON	15.3	161
6/27/2026	15:30:00	7.28	1.1697	2	172277.9	ON	15.9	160
6/27/2026	15:45:00	7.28	1.3287	4	172293.8	ON	15.9	160



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Valve Status	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/27/2026	16:00:00	7.3	1.8321	2	172318.0	ON	15.5	160
6/27/2026	16:15:00	7.28	0.2385	1	172336.1	ON	16.7	160
6/27/2026	16:30:00	7.31	0.8176	3	172346.4	ON	17.4	162
6/27/2026	16:45:00	7.27	0.9501	4	172358.8	ON	17	161
6/27/2026	17:00:00	7.26	0.0189	4	172374.2	ON	17.3	161
6/27/2026	17:15:00	7.27	2.1388	1	172397.3	ON	15.4	157
6/27/2026	17:30:00	7.27	2.3886	1	172429.4	ON	15	158
6/27/2026	17:45:00	7.29	1.5709	1	172462.7	ON	15.5	160
6/27/2026	18:00:00	7.27	0.2233	2	172470.5	ON	16.7	160
6/27/2026	18:15:00	7.27	2.4492	2	172496.2	ON	15.4	159
6/27/2026	18:30:00	7.28	2.4037	2	172533.6	ON	15	159
6/27/2026	18:45:00	7.28	0.0189	1	172559.1	ON	15.8	160
6/27/2026	19:00:00	7.25	0.2763	2	172559.8	ON	17	162
6/27/2026	19:15:00	7.28	2.1123	2	172576.5	ON	17	161
6/27/2026	19:30:00	7.27	2.1236	1	172609.5	ON	15.1	159
6/27/2026	19:45:00	7.27	2.1047	1	172640.2	ON	14.8	160
6/27/2026	20:00:00	7.25	0.0000	1	172664.5	ON	15.5	161
6/27/2026	20:15:00	7.24	0.1703	1	172666.7	ON	16.3	161
6/27/2026	20:30:00	7.23	1.3968	1	172676.9	ON	16.9	162
6/27/2026	20:45:00	7.21	0.9993	2	172696.9	ON	17.3	162
6/27/2026	21:00:00	7.25	2.3697	1	172719.4	ON	14.7	158
6/27/2026	21:15:00	7.25	1.3098	1	172748.9	ON	14.7	160
6/27/2026	21:30:00	7.23	0.2196	1	172751.3	ON	15.3	161
6/27/2026	21:45:00	7.24	2.2069	2	172759.1	ON	15.2	163
6/27/2026	22:00:00	7.26	2.0517	1	172790.3	ON	14.2	165
6/27/2026	22:15:00	7.27	1.5407	1	172820.1	ON	14.4	166
6/27/2026	22:30:00	7.26	1.8700	2	172846.2	ON	14.5	166
6/27/2026	22:45:00	7.25	1.7261	2	172873.4	ON	14.9	166
6/27/2026	23:00:00	7.23	0.0871	2	172886.8	ON	15.4	167
6/27/2026	23:15:00	7.26	1.8397	1	172899.6	ON	14.8	168
6/27/2026	23:30:00	7.23	2.3129	2	172927.8	ON	14.5	167
6/27/2026	23:45:00	7.21	2.1804	2	172960.6	ON	14	168



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Valve Status	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/28/2026	0:00:00	7.21	1.3476	2	172985.5	ON	14.5	169
6/28/2026	0:15:00	7.2	0.0833	2	172992.8	ON	15	170
6/28/2026	0:30:00	7.18	0.2801	2	172995.5	ON	15.4	170
6/28/2026	0:45:00	7.18	0.3672	2	172999.7	ON	15.6	171
6/28/2026	1:00:00	7.21	1.9571	2	173013.0	ON	14.4	169
6/28/2026	1:15:00	7.22	2.1463	2	173044.1	ON	13.9	167
6/28/2026	1:30:00	7.21	1.1432	2	173065.9	ON	14.3	167
6/28/2026	1:45:00	7.19	1.2454	1	173081.4	ON	14.6	168
6/28/2026	2:00:00	7.22	2.0366	2	173093.9	ON	13.8	167
6/28/2026	2:15:00	7.22	0.1401	2	173117.1	ON	14.1	167
6/28/2026	2:30:00	7.21	0.1022	2	173120.1	ON	14.4	168
6/28/2026	2:45:00	7.24	1.6656	2	173131.0	ON	14	169
6/28/2026	3:00:00	7.23	2.1425	2	173159.7	ON	13.6	166
6/28/2026	3:15:00	7.22	1.9873	2	173190.4	ON	13.6	167
6/28/2026	3:30:00	7.21	1.4990	1	173216.2	ON	13.9	167
6/28/2026	3:45:00	7.21	1.5293	2	173240.0	ON	14.3	167
6/28/2026	4:00:00	7.2	0.1552	2	173258.0	ON	14.6	168
6/28/2026	4:15:00	7.19	0.2082	1	173261.4	ON	14.8	167
6/28/2026	4:30:00	7.16	1.5293	1	173269.4	ON	15	168
6/28/2026	4:45:00	7.21	2.3242	2	173289.5	ON	14.5	165
6/28/2026	5:00:00	7.21	2.2069	2	173322.0	ON	13.5	166
6/28/2026	5:15:00	7.21	0.8858	2	173349.0	ON	13.6	166
6/28/2026	5:30:00	7.2	0.1931	2	173351.8	ON	13.9	167
6/28/2026	5:45:00	7.21	2.1577	2	173366.6	ON	13.3	168
6/28/2026	6:00:00	7.21	2.5362	2	173404.0	ON	13.2	168
6/28/2026	6:15:00	7.21	2.1577	2	173441.4	ON	13.2	168
6/28/2026	6:30:00	7.22	1.4915	2	173473.6	ON	13.5	167
6/28/2026	6:45:00	7.2	1.5407	2	173487.1	ON	13.8	167
6/28/2026	7:00:00	7.19	0.0189	2	173503.7	ON	14.3	168
6/28/2026	7:15:00	7.18	0.2233	2	173506.3	ON	14.9	170
6/28/2026	7:30:00	7.22	0.7495	4	173516.6	ON	15.2	170
6/28/2026	7:45:00	7.22	0.7609	2	173526.8	ON	15.8	171



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Valve Status	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/28/2026	8:00:00	7.22	1.9495	2	173552.2	ON	14.7	166
6/28/2026	8:15:00	7.23	1.3211	2	173578.8	ON	14.4	168
6/28/2026	8:30:00	7.22	1.6202	2	173600.1	ON	14.8	167
6/28/2026	8:45:00	7.22	0.0341	2	173614.5	ON	16.8	170
6/28/2026	9:00:00	7.24	1.7413	3	173620.9	ON	17.4	168
6/28/2026	9:15:00	7.21	0.8025	2	173637.9	ON	16	168
6/28/2026	9:30:00	7.19	2.4340	2	173657.3	ON	15.1	168
6/28/2026	9:45:00	7.18	2.4113	2	173693.3	ON	14.8	167
6/28/2026	10:00:00	7.18	0.2158	2	173708.6	ON	16.5	169
6/28/2026	10:15:00	7.21	2.5173	2	173734.6	ON	15.2	168
6/28/2026	10:30:00	7.2	0.6095	2	173745.1	ON	17.2	168
6/28/2026	10:45:00	7.19	2.4946	3	173758.8	ON	17	165
6/28/2026	11:00:00	7.21	1.4233	2	173790.4	ON	16.2	169
6/28/2026	11:15:00	7.21	2.4454	2	173804.5	ON	15.9	169
6/28/2026	11:30:00	7.23	2.3318	2	173840.5	ON	15.2	169
6/28/2026	11:45:00	7.22	2.1918	2	173870.4	ON	15.6	168
6/28/2026	12:00:00	7.21	0.1060	2	173889.9	ON	17.7	169
6/28/2026	12:15:00	7.19	0.1741	2	173892.5	ON	19.2	171
6/28/2026	12:30:00	7.18	1.5293	2	173904.4	ON	19.3	171
6/28/2026	12:45:00	7.17	0.1173	2	173915.2	ON	20	173
6/28/2026	13:00:00	7.16	0.1287	2	173918.3	ON	20.5	172
6/28/2026	13:15:00	7.15	1.6050	2	173927.1	ON	20.7	172
6/28/2026	13:30:00	7.2	2.3886	2	173956.7	ON	16.4	165
6/28/2026	13:45:00	7.19	2.2220	2	173991.0	ON	15.4	168
6/28/2026	14:00:00	7.18	0.1060	2	174009.1	ON	16.3	168
6/28/2026	14:15:00	7.17	0.0265	2	174010.9	ON	17.4	169
6/28/2026	14:30:00	7.21	0.5110	5	174017.0	ON	17.5	173
6/28/2026	14:45:00	7.19	2.1690	2	174041.5	ON	15.5	167
6/28/2026	15:00:00	7.2	2.1539	2	174075.0	ON	15.1	168
6/28/2026	15:15:00	7.2	0.8063	2	174097.7	ON	15.5	168
6/28/2026	15:30:00	7.21	2.1198	2	174116.2	ON	15.3	168
6/28/2026	15:45:00	7.21	0.2725	2	174130.3	ON	16.1	167



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Date	Time	Discharge pH	Discharge Flow Rate (m3PM)	Discharge NTU	Flow Total (m3)	Discharge Valve Status	Discharge Temperature (C°)	Discharge Conductivity (uS/cm)
6/28/2026	16:00:00	7.19	0.1968	2	174133.7	ON	17.2	167
6/28/2026	16:15:00	7.18	0.1855	2	174136.0	ON	18.2	170
6/28/2026	16:30:00	7.16	0.0303	2	174136.5	ON	19	171
6/28/2026	16:45:00	7.2	1.8094	2	174146.6	ON	16.7	165
6/28/2026	17:00:00	7.21	2.1653	2	174178.0	ON	15.6	168
6/28/2026	17:15:00	7.21	2.1274	2	174209.5	ON	15.5	170
6/28/2026	17:30:00	7.21	0.1325	2	174221.6	ON	16.5	170
6/28/2026	17:45:00	7.19	0.1855	2	174224.2	ON	17.6	170
6/28/2026	18:00:00	7.2	1.9608	2	174232.8	ON	17.3	168
6/28/2026	18:15:00	7.21	2.1312	2	174266.6	ON	15.7	168
6/28/2026	18:30:00	7.21	0.9653	2	174287.3	ON	15.9	169
6/28/2026	18:45:00	7.21	2.3167	2	174314.6	ON	15.4	169
6/28/2026	19:00:00	7.21	0.6852	2	174340.0	ON	15.6	170
6/28/2026	19:15:00	7.2	0.6587	2	174343.6	ON	16.5	169
6/28/2026	19:30:00	7.2	1.9533	2	174371.2	ON	15.3	168
6/28/2026	19:45:00	7.19	1.8700	2	174395.8	ON	15.1	168
6/28/2026	20:00:00	7.19	1.7451	2	174421.5	ON	14.9	166
6/28/2026	20:15:00	7.19	2.1160	2	174442.4	ON	14.8	168
6/28/2026	20:30:00	7.21	0.6700	2	174464.1	ON	15	167
6/28/2026	20:45:00	7.19	0.4883	2	174466.9	ON	15.8	168
6/28/2026	21:00:00	7.18	0.3407	2	174473.2	ON	16.6	167
6/28/2026	21:15:00	7.17	0.4807	2	174479.9	ON	17.2	168
6/28/2026	21:30:00	7.13	0.4694	2	174486.7	ON	17.5	168
6/28/2026	21:45:00	7.19	1.3400	8	174493.9	ON	15.4	164
6/28/2026	22:00:00	7.21	1.0675	4	174510.6	ON	15.6	168
6/28/2026	22:15:00	7.23	1.6353	3	174526.7	ON	15.4	168
6/28/2026	22:30:00	7.21	1.9608	3	174546.3	ON	15.7	168
6/28/2026	22:45:00	7.18	2.2220	2	174580.4	ON	14.4	168
6/28/2026	23:00:00	7.17	2.1425	2	174612.1	ON	14.3	169
6/28/2026	23:15:00	7.19	1.3930	2	174641.5	ON	14.6	168
6/28/2026	23:30:00	7.17	0.2233	2	174646.5	ON	15.2	169
6/28/2026	23:45:00	7.19	0.5110	7	174651.2	ON	15.5	172

		Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope	
Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: BC1 Approved by: BC2 Date: July 16, 2026	

Appendix C: Photos



Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Photo 1: No visible sheen observed in the Portal WTP water, June 22





Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Photo 2: No visible sheen observed in the CP2 WTP, June 22





Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Photo 3: No visible sheen observed in the Portal WTP water, June 23





Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Photo 4: No visible sheen observed in the CP2 WTP water, June 23





Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Photo 5: No visible sheen observed in the Portal WTP water, June 24





Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Photo 6: No visible sheen observed in the CP2 WTP water, June 24





Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Photo 7: No visible sheen observed in the Portal WTP water, June 25





Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Photo 8: No visible sheen observed in the CP2 WTP water, June 25





Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Photo 9: No visible sheen observed in the Portal WTP water, June 26





Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Photo 10: No visible sheen observed in the CP2 WTP water, June 26





Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Photo 11: No visible sheen observed in the Portal WTP water, June 27





Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Photo 12: No visible sheen observed in the CP2 WTP water, June 27





Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Photo 13: No visible sheen observed in the Portal WTP water, June 28






Eagle Mountain- Woodfibre Gas Pipeline Project- Tunnel Scope

Title	Woodfibre Weekly Water Discharge Report	Revision:	1
Data Range	June 22, 2026 to June 28, 2026	Prepared by: Approved by: Date:	BC1 BC2 July 16, 2026

Photo 14: No visible sheen observed in the CP2 WTP water, June 28



Water Quality Field Data Sheet



Project: FORTIS11234

Location Information	
Site ID:	<u>WLNG EOP</u>
Site Name:	<u>East Creek</u>
Crew:	<u>HM</u>
Weather:	<u>Sun</u>
Date:	<u>June 23, 2026</u>
Time:	<u>11:11</u>

In Situ Parameters			
pH:	<u>7.4</u>	DO:	<u>3.3</u> (mg/L)
Temp:	<u>14.8</u> (°C)	Cond:	<u>231.3</u> (us/cm)
Turbidity:	<u>0</u> NTU	Salinity:	<u>0.11</u> (ppt)
		ORP:	<u>25</u> (mV)
Visible Sheen: <u>N</u>			
Water Surface Condition: <u>Clear</u>			



Observations
<u>No issues observed.</u>

 Eagle Mountain – Woodfibre Gas Pipeline Project Waste Discharge Permit PE-110163 Report	Reporting Week	June 22 to June 28, 2026
	Report #	118
	Appendix D	D-1

Appendix D:
Woodfibre Site Receiving Environment
Documentation

 Eagle Mountain – Woodfibre Gas Pipeline Project Waste Discharge Permit PE-110163 Report	Reporting Week	June 22 to June 28, 2026
	Report #	118
	Appendix D	D-2

Woodfibre Site Receiving Environment
Sample Analysis

Analyte	Unit	BC Approved Water Quality Guideline - Freshwater Aquatic Life - Long Term Average	BC Approved Water Quality Guideline - Freshwater Aquatic Life - Short Term Max	BC Working Water Quality Guideline - Freshwater Aquatic Life - Long Term Average	BC Approved Water Quality Guideline - Marine Aquatic Life - Long Term Average	BC Approved Water Quality Guideline - Marine Aquatic Life - Short Term Max	BC Working Water Quality Guideline - Marine Aquatic Life - Long Term Average	WLNG US 2026-06-23 12:06:00	WLNG DS 2026-06-23 11:42:00
In situ Parameters									
Field pH	pH Units		6.5 - 9			7 - 8.7		7.8	7.6
Field Temperature	°C	18	19					15.9	14.3
General Parameters									
pH	pH Units							6.67	7.66
Alkalinity (Total as CaCO ₃)	mg/L							7.5	48
Alkalinity (PP as CaCO ₃)	mg/L							<1	<1
Hardness (CaCO ₃)-Total	mg/L							7.55	58.1
Hardness (CaCO ₃)-Dissolved	mg/L							7.4	57.9
Sulphide-Total	mg/L							<0.0018	<0.0018
Sulphide (as H ₂ S)	mg/L			0.002				<0.002	<0.002
Un-ionized Hydrogen Sulfide as H ₂ S-Total	mg/L							<0.0019	<0.0019
Un-ionized Hydrogen Sulfide as S-Total	mg/L							<0.0018	<0.0018
Anions and Nutrients									
Ammonia (N)-Total	mg/L	1.42	10.8		2.2	15		<0.015	0.026
Bicarbonate (HCO ₃)	mg/L							9.2	59
Carbonate (CO ₃)	mg/L							<1	<1
Hydroxide (OH)	mg/L							<1	<1
Nitrate (N)	mg/L	3	32.8		3.7			<0.02	0.066
Nitrite (N)	mg/L	0.02	0.06					<0.005	<0.005
Nitrate plus Nitrite (N)	mg/L							<0.02	0.066
Nitrogen (N)-Total	mg/L							0.069	0.254
Phosphorus (P)-Total (4500-P)	mg/L							0.013	0.0037
Bromide (Br)	mg/L							<0.01	<0.01
Chloride (Cl)	mg/L	150	600					<1	11
Fluoride (F)	mg/L		0.4			1.5		<0.05	0.33
Sulphate (SO ₄)-Dissolved	mg/L	128						2.3	14
Total Metals									
Aluminum (Al)-Total	mg/L	0.0729508						0.0412	0.181
Antimony (Sb)-Total	mg/L	0.074	0.25					<0.00002	0.000644
Arsenic (As)-Total	mg/L	0.005			0.0125			0.000098	0.000843
Barium (Ba)-Total	mg/L			1				0.00421	0.00454
Beryllium (Be)-Total	mg/L			0.00013			0.1	<0.00001	<0.00001
Bismuth (Bi)-Total	mg/L							<0.000005	<0.000005
Boron (B)-Total	mg/L	1.2			1.2			<0.01	0.014
Cadmium (Cd)-Total	mg/L						0.00012	0.0000056	<0.000005
Calcium (Ca)-Total	mg/L							2.58	21.4
Cesium (Cs)-Total	mg/L							<0.00005	<0.00005
Chromium (Cr)-Total	mg/L							<0.0001	0.00014

¹ Guideline calculated using the in-situ measurements (pH (field),Temperature (field), Turbidity (field), Hardness (as CaCO₃) – total, Dissolved Organic Carbon (DOC), Total Alkalinity (CaCO₃), and Chloride).

² Guideline values presented represent the lower of the co-factor dependent guidelines for the upstream and downstream stations when they differ, but exceedance bolding is dependent on guidelines calculated using in situ co-factor considerations.

³ **Bold text** denotes value exceeding guidelines, except in cases where they are below a station-specific guideline that isn't displayed as per ¹ and ² above. Given that application of chronic BC water quality guidelines for protection of aquatic life in the receiving environment downstream of the discharge does not represent a regulatory requirement and instead data are intended to be assessed relative to monthly average concentrations, exceedances of these guidelines are highlighted for information purposes, but detailed interpretation of guideline exceedances are not provided given that an interpretation of monthly trends and consideration of background influences and discharge chemistry is required.

⁴ **Bold and shaded text** outlines a reportable exceedance given that it exceeds the applicable BC water quality guideline (i.e., the short-term acute freshwater aquatic life guideline), or discharge concentration limit, consistent with recommendations outlined in Hatfield (2024).

Analyte	Unit	BC Approved Water Quality Guideline - Freshwater Aquatic Life - Long Term Average	BC Approved Water Quality Guideline - Freshwater Aquatic Life - Short Term Max	BC Working Water Quality Guideline - Freshwater Aquatic Life - Long Term Average	BC Approved Water Quality Guideline - Marine Aquatic Life - Long Term Average	BC Approved Water Quality Guideline - Marine Aquatic Life - Short Term Max	BC Working Water Quality Guideline - Marine Aquatic Life - Long Term Average	WLNG US 2026-06-23 12:06:00	WLNG DS 2026-06-23 11:42:00
Total Metals (cont'd.)									
Chromium (Cr III)-Total	mg/L			0.0089			0.056	<0.00099	<0.00099
Chromium (Cr VI)-Total	mg/L			0.0025			0.0015	<0.00099	<0.00099
Cobalt (Co)-Total	mg/L							0.000024	0.0000284
Copper (Cu)-Total	mg/L				0.002	0.003		0.000562	0.000087
Iron (Fe)-Total	mg/L	0.055	1					0.0358	0.0141
Lead (Pb)-Total	mg/L				0.002	0.14		0.0000164	0.0000086
Lithium (Li)-Total	mg/L							<0.0005	0.00742
Magnesium (Mg)-Total	mg/L							0.268	1.14
Manganese (Mn)-Total	mg/L						0.1	0.00124	0.0201
Mercury (Hg)-Total	mg/L	0.00002			0.0001			<0.0000019	<0.0000019
Molybdenum (Mo)-Total	mg/L	7.6	46					0.000453	0.0331
Nickel (Ni)-Total	mg/L						0.0083	0.000229	0.000112
Phosphorus (P)-Total (ICPMS)	mg/L							0.0099	0.0044
Potassium (K)-Total	mg/L							0.172	2.04
Rubidium (Rb)-Total	mg/L							0.000389	0.00413
Selenium (Se)-Total	mg/L	0.002			0.002			<0.00004	0.000043
Silicon (Si)-Total	mg/L							4.68	7.04
Silver (Ag)-Total	mg/L	0.00012			0.0005	0.0037	0.0005	<0.000005	<0.000005
Sodium (Na)-Total	mg/L							1.75	7.04
Strontium (Sr)-Total	mg/L							0.0147	0.0472
Sulphur (S)-Total	mg/L							<3	4.9
Tellurium (Te)-Total	mg/L							<0.00002	<0.00002
Thallium (Tl)-Total	mg/L			0.00003				<0.000002	0.0000113
Thorium (Th)-Total	mg/L							<0.00005	<0.00005
Tin (Sn)-Total	mg/L							<0.0002	<0.0002
Titanium (Ti)-Total	mg/L							0.00051	<0.0005
Uranium (U)-Total	mg/L		0.0165	0.0075				0.0000442	0.000488
Vanadium (V)-Total	mg/L			0.06			0.005	<0.0002	<0.0002
Zinc (Zn)-Total	mg/L				0.01	0.055		0.00064	0.00142
Zirconium (Zr)-Total	mg/L							<0.0001	<0.0001
Dissolved Metals									
Aluminum (Al)-Dissolved	mg/L							0.0321	0.0724
Antimony (Sb)-Dissolved	mg/L							<0.00002	0.000616
Arsenic (As)-Dissolved	mg/L							0.000107	0.000789
Barium (Ba)-Dissolved	mg/L							0.0042	0.00442
Beryllium (Be)-Dissolved	mg/L							<0.00001	<0.00001
Bismuth (Bi)-Dissolved	mg/L							<0.000005	<0.000005
Boron (B)-Dissolved	mg/L							<0.01	0.011

¹ Guideline calculated using the in-situ measurements (pH (field),Temperature (field), Turbidity (field), Hardness (as CaCO₃) – total, Dissolved Organic Carbon (DOC), Total Alkalinity (CaCO₃), and Chloride).

² Guideline values presented represent the lower of the co-factor dependent guidelines for the upstream and downstream stations when they differ, but exceedance bolding is dependent on guidelines calculated using in situ co-factor considerations.

³ **Bold text** denotes value exceeding guidelines, except in cases where they are below a station-specific guideline that isn't displayed as per ¹ and ² above. Given that application of chronic BC water quality guidelines for protection of aquatic life in the receiving environment downstream of the discharge does not represent a regulatory requirement and instead data are intended to be assessed relative to monthly average concentrations, exceedances of these guidelines are highlighted for information purposes, but detailed interpretation of guideline exceedances are not provided given that an interpretation of monthly trends and consideration of background influences and discharge chemistry is required.

⁴ **Bold and shaded text** outlines a reportable exceedance given that it exceeds the applicable BC water quality guideline (i.e., the short-term acute freshwater aquatic life guideline), or discharge concentration limit, consistent with recommendations outlined in Hatfield (2024).

Analyte	Unit	BC Approved Water Quality Guideline - Freshwater Aquatic Life - Long Term Average	BC Approved Water Quality Guideline - Freshwater Aquatic Life - Short Term Max	BC Working Water Quality Guideline - Freshwater Aquatic Life - Long Term Average	BC Approved Water Quality Guideline - Marine Aquatic Life - Long Term Average	BC Approved Water Quality Guideline - Marine Aquatic Life - Short Term Max	BC Working Water Quality Guideline - Marine Aquatic Life - Long Term Average	WLNG US 2026-06-23 12:06:00	WLNG DS 2026-06-23 11:42:00
Dissolved Metals (cont'd.)									
Cadmium (Cd)-Dissolved	mg/L	0.0000316	0.0000411					0.0000058	<0.000005
Calcium (Ca)-Dissolved	mg/L							2.55	21.4
Cesium (Cs)-Dissolved	mg/L							<0.00005	<0.00005
Chromium (Cr)-Dissolved	mg/L							<0.0001	0.00012
Cobalt (Co)-Dissolved	mg/L	0.0003889						0.0000125	0.0000246
Copper (Cu)-Dissolved	mg/L	0.00034	0.00204					0.00051	0.000086
Iron (Fe)-Dissolved	mg/L							0.0233	0.0016
Lead (Pb)-Dissolved	mg/L	0.0014888						0.0000107	<0.000005
Lithium (Li)-Dissolved	mg/L							<0.0005	0.00753
Manganese (Mn)-Dissolved	mg/L	0.195	0.3443889					0.000724	0.0178
Magnesium (Mg)-Dissolved	mg/L							0.251	1.09
Mercury (Hg)-Dissolved	mg/L							<0.0000019	<0.0000019
Molybdenum (Mo)-Dissolved	mg/L							0.000435	0.032
Nickel (Ni)-Dissolved	mg/L	0.001	0.0132					0.000202	0.000086
Phosphorus (P)-Dissolved	mg/L							0.0106	0.0047
Potassium (K)-Dissolved	mg/L							0.166	2.02
Rubidium (Rb)-Dissolved	mg/L							0.000359	0.004
Selenium (Se)-Dissolved	mg/L							<0.00004	<0.00004
Silicon (Si)-Dissolved	mg/L							4.44	6.73
Silver (Ag)-Dissolved	mg/L							<0.000005	<0.000005
Sodium (Na)-Dissolved	mg/L							1.66	6.69
Strontium (Sr)-Dissolved	mg/L			1.25				0.0133	0.0449
Sulphur (S)-Dissolved	mg/L							<3	5.1
Tellurium (Te)-Dissolved	mg/L							<0.00002	<0.00002
Thallium (Tl)-Dissolved	mg/L							0.0000022	0.0000126
Thorium (Th)-Dissolved	mg/L							0.0000068	<0.000005
Tin (Sn)-Dissolved	mg/L							<0.0002	<0.0002
Titanium (Ti)-Dissolved	mg/L							<0.0005	<0.0005
Uranium (U)-Dissolved	mg/L							0.0000428	0.000466
Vanadium (V)-Dissolved	mg/L							<0.0002	0.00022
Zinc (Zn)-Dissolved	mg/L	0.0022132	0.0086735					0.00063	0.00074
Zirconium (Zr)-Dissolved	mg/L							<0.0001	<0.0001

¹ Guideline calculated using the in-situ measurements (pH (field),Temperature (field), Turbidity (field), Hardness (as CaCO₃) – total, Dissolved Organic Carbon (DOC), Total Alkalinity (CaCO₃), and Chloride).

² Guideline values presented represent the lower of the co-factor dependent guidelines for the upstream and downstream stations when they differ, but exceedance bolding is dependent on guidelines calculated using in situ co-factor considerations.

³ **Bold text** denotes value exceeding guidelines, except in cases where they are below a station-specific guideline that isn't displayed as per ¹ and ² above. Given that application of chronic BC water quality guidelines for protection of aquatic life in the receiving environment downstream of the discharge does not represent a regulatory requirement and instead data are intended to be assessed relative to monthly average concentrations, exceedances of these guidelines are highlighted for information purposes, but detailed interpretation of guideline exceedances are not provided given that an interpretation of monthly trends and consideration of background influences and discharge chemistry is required.

⁴ **Bold and shaded text** outlines a reportable exceedance given that it exceeds the applicable BC water quality guideline (i.e., the short-term acute freshwater aquatic life guideline), or discharge concentration limit, consistent with recommendations outlined in Hatfield (2024).

Analyte	Unit	BC Approved Water Quality Guideline - Freshwater Aquatic Life - Long Term Average	BC Approved Water Quality Guideline - Freshwater Aquatic Life - Short Term Max	BC Working Water Quality Guideline - Freshwater Aquatic Life - Long Term Average	BC Approved Water Quality Guideline - Marine Aquatic Life - Long Term Average	BC Approved Water Quality Guideline - Marine Aquatic Life - Short Term Max	BC Working Water Quality Guideline - Marine Aquatic Life - Long Term Average	WLNG US 2026-06-23 12:06:00	WLNG DS 2026-06-23 11:42:00
Inorganics									
Organic Carbon (C)-Total	mg/L							1.5	0.98
Organic Carbon (C)-Dissolved	mg/L							1.8	0.66
Solids-Total Dissolved	mg/L							40	100
Solids-Total Suspended	mg/L	6	26					<1	2

¹ Guideline calculated using the in-situ measurements (pH (field),Temperature (field), Turbidity (field), Hardness (as CaCO₃) – total, Dissolved Organic Carbon (DOC), Total Alkalinity (CaCO₃), and Chloride).

² Guideline values presented represent the lower of the co-factor dependent guidelines for the upstream and downstream stations when they differ, but exceedance bolding is dependent on guidelines calculated using in situ co-factor considerations.

³ **Bold text** denotes value exceeding guidelines, except in cases where they are below a station-specific guideline that isn't displayed as per ¹ and ² above. Given that application of chronic BC water quality guidelines for protection of aquatic life in the receiving environment downstream of the discharge does not represent a regulatory requirement and instead data are intended to be assessed relative to monthly average concentrations, exceedances of these guidelines are highlighted for information purposes, but detailed interpretation of guideline exceedances are not provided given that an interpretation of monthly trends and consideration of background influences and discharge chemistry is required.

⁴ **Bold and shaded text** outlines a reportable exceedance given that it exceeds the applicable BC water quality guideline (i.e., the short-term acute freshwater aquatic life guideline), or discharge concentration limit, consistent with recommendations outlined in Hatfield (2024).

 Eagle Mountain – Woodfibre Gas Pipeline Project Waste Discharge Permit PE-110163 Report	Reporting Week	June 22 to June 28, 2026
	Report #	118
	Appendix D	D-3

Woodfibre Site Receiving Environment
Field Notes and Logs

Water Quality Field Data Sheet



Project: FORTIS11234

Location Information

Site ID:	<u>WLNG (EAS) DS</u>		Date:	<u>June 23, 2026</u>
Site Name:	<u>East Creek</u>		Time:	<u>11:42</u>
Site UTM:	Zone: 10U	E: <u>482092</u>	Crew:	<u>HM</u>
(NAD83)		N: <u>5501875</u>	Weather:	<u>Sun</u>

In Situ Parameters

pH:	<u>7.63</u>	DO:	<u>3.75</u> (mg/L)
Temp:	<u>14.3</u> (°C)	Cond:	<u>209.3</u> (us/cm)
Turbidity:	<u>3.51</u> NTU	Salinity:	<u>0.1</u> (ppt)
Visible Sheen:	<u>N</u>	ORP:	<u>53.7</u> (mV)

Water Surface Condition: Clear, some foam

Photo Record



Observations

No issues observed

Water Quality Field Data Sheet



Project: FORTIS11234

Location Information

Site ID:	<u>WLNG (EAS) US</u>	Date:	<u>June 23, 2026</u>
Site Name:	<u>East Creek</u>	Time:	<u>12:06</u>
Site UTM:	Zone:10U E: <u>481908</u>	Crew:	<u>HM</u>
(NAD83)	N: <u>5501909</u>	Weather:	<u>Sun</u>

In Situ Parameters

pH:	<u>7.76</u>	DO:	<u>3.03</u> (mg/L)
Temp.:	<u>15.9</u> (°C)	Cond:	<u>65.3</u> (us)
Turbidity:	<u>2.54</u> NTU	Salinity:	<u>0.03</u> (ppt)
Visible Sheen:	<u>N</u>	ORP:	<u>42.9</u> (mV)
Water Surface Condition:	<u>Clear</u>		

Photo Record



Observations

No issues observed.

Woodfibre LNG (East Creek)								
Station	Date/Time	Temperature (C)	Specific Conductivity (µS/cm)	ORP (V)	pH (pH units)	Dissolved Oxygen (mg/L)	Turbidity (NTU)	Salinity (PSU)
EAS-DS	2026-06-22 00:00:00	13.48	166.73	0.28	7.84	9.58	9.77	0.08
EAS-DS	2026-06-22 00:15:00	13.19	162.78	0.28	7.84	9.70	9.63	0.08
EAS-DS	2026-06-22 00:30:00	13.08	158.93	0.28	7.83	9.73	9.42	0.08
EAS-DS	2026-06-22 00:45:00	13.14	164.22	0.28	7.87	9.77	9.53	0.08
EAS-DS	2026-06-22 01:00:00	13.36	170.49	0.28	7.84	9.62	9.57	0.08
EAS-DS	2026-06-22 01:15:00	13.25	159.95	0.29	7.52	9.32	9.32	0.08
EAS-DS	2026-06-22 01:30:00	13.34	172.66	0.28	7.86	9.69	9.54	0.08
EAS-DS	2026-06-22 01:45:00	12.98	159.19	0.28	7.83	9.65	9.37	0.08
EAS-DS	2026-06-22 02:00:00	13.07	158.36	0.29	7.68	9.51	9.33	0.08
EAS-DS	2026-06-22 02:15:00	13.28	171.64	0.28	7.83	9.59	9.79	0.08
EAS-DS	2026-06-22 02:30:00	13.22	172.50	0.28	7.81	9.67	9.47	0.08
EAS-DS	2026-06-22 02:45:00	12.88	158.63	0.28	7.82	9.77	9.59	0.08
EAS-DS	2026-06-22 03:00:00	13.15	172.06	0.28	7.83	9.76	9.38	0.08
EAS-DS	2026-06-22 03:15:00	12.85	158.43	0.28	7.82	9.71	9.52	0.08
EAS-DS	2026-06-22 03:30:00	13.21	174.72	0.28	7.81	9.67	9.42	0.08
EAS-DS	2026-06-22 03:45:00	13.19	173.46	0.28	7.84	9.70	9.64	0.08
EAS-DS	2026-06-22 04:00:00	13.08	172.62	0.28	7.82	9.77	10.29	0.08
EAS-DS	2026-06-22 04:15:00	13.04	169.88	0.28	7.81	9.61	9.40	0.08
EAS-DS	2026-06-22 04:30:00	13.04	170.90	0.28	7.81	9.69	9.38	0.08
EAS-DS	2026-06-22 04:45:00	13.31	173.89	0.28	7.74	9.42	9.41	0.08
EAS-DS	2026-06-22 05:00:00	13.35	172.96	0.28	7.83	9.62	9.41	0.08
EAS-DS	2026-06-22 05:15:00	12.96	156.47	0.28	7.78	9.32	9.66	0.07
EAS-DS	2026-06-22 05:30:00	12.83	159.23	0.28	7.68	9.61	9.33	0.08
EAS-DS	2026-06-22 05:45:00	13.12	166.08	0.28	7.83	9.68	9.54	0.08
EAS-DS	2026-06-22 06:00:00	12.59	158.86	0.28	7.83	9.83	10.23	0.08
EAS-DS	2026-06-22 06:15:00	12.75	161.76	0.29	7.80	9.70	9.42	0.08
EAS-DS	2026-06-22 06:30:00	12.81	166.38	0.29	7.80	9.75	9.45	0.08
EAS-DS	2026-06-22 06:45:00	12.56	159.92	0.29	7.80	9.83	9.45	0.08
EAS-DS	2026-06-22 07:00:00	12.97	167.35	0.28	7.82	9.70	9.54	0.08
EAS-DS	2026-06-22 07:15:00	13.01	164.35	0.29	7.54	8.99	9.39	0.08
EAS-DS	2026-06-22 07:30:00	12.81	165.98	0.28	7.80	9.79	9.52	0.08
EAS-DS	2026-06-22 07:45:00	12.60	159.09	0.29	7.81	9.84	9.38	0.08
EAS-DS	2026-06-22 08:00:00	12.84	166.62	0.29	7.80	9.73	9.53	0.08
EAS-DS	2026-06-22 08:15:00	12.72	158.80	0.29	7.80	9.75	9.31	0.08
EAS-DS	2026-06-22 08:30:00	13.17	169.89	0.28	7.83	9.69	9.74	0.08
EAS-DS	2026-06-22 08:45:00	13.01	160.52	0.29	7.74	9.54	9.35	0.08
EAS-DS	2026-06-22 09:00:00	13.26	167.03	0.28	7.82	9.66	9.55	0.08
EAS-DS	2026-06-22 09:15:00	13.12	158.09	0.29	7.77	9.49	9.32	0.07
EAS-DS	2026-06-22 09:30:00	13.36	167.82	0.28	7.80	9.56	9.75	0.08
EAS-DS	2026-06-22 09:45:00	13.40	153.76	0.29	7.78	9.46	9.65	0.07
EAS-DS	2026-06-22 10:00:00	13.48	166.24	0.29	7.81	9.61	9.61	0.08
EAS-DS	2026-06-22 10:15:00	13.33	161.37	0.29	7.57	9.03	9.38	0.08
EAS-DS	2026-06-22 10:30:00	13.67	160.56	0.29	7.81	9.52	9.50	0.08
EAS-DS	2026-06-22 10:45:00	13.76	165.65	0.29	7.82	9.65	9.68	0.08
EAS-DS	2026-06-22 11:00:00	13.78	160.45	0.29	7.83	9.59	9.42	0.08
EAS-DS	2026-06-22 11:15:00	13.99	166.30	0.29	7.82	9.44	9.55	0.08
EAS-DS	2026-06-22 11:30:00	14.31	162.57	0.29	7.87	9.43	10.51	0.08
EAS-DS	2026-06-22 11:45:00	14.32	162.55	0.29	7.84	9.46	9.48	0.08
EAS-DS	2026-06-22 12:00:00	14.60	169.71	0.29	7.83	9.36	9.52	0.08
EAS-DS	2026-06-22 12:15:00	14.73	156.15	0.29	7.75	8.72	9.49	0.07
EAS-DS	2026-06-22 12:30:00	14.76	165.26	0.29	7.83	9.31	9.51	0.08
EAS-DS	2026-06-22 12:45:00	14.80	168.24	0.29	7.85	9.34	9.54	0.08
EAS-DS	2026-06-22 13:00:00	14.63	161.09	0.29	7.86	9.38	9.58	0.08
EAS-DS	2026-06-22 13:15:00	14.99	166.34	0.29	7.83	9.27	9.75	0.08
EAS-DS	2026-06-22 13:30:00	15.01	160.49	0.29	7.85	9.25	9.47	0.08

Woodfibre LNG (East Creek)								
Station	Date/Time	Temperature (C)	Specific Conductivity (µS/cm)	ORP (V)	pH (pH units)	Dissolved Oxygen (mg/L)	Turbidity (NTU)	Salinity (PSU)
EAS-DS	2026-06-22 13:45:00	14.85	160.61	0.29	7.86	9.35	9.54	0.08
EAS-DS	2026-06-22 14:00:00	14.85	160.69	0.29	7.83	9.30	10.44	0.08
EAS-DS	2026-06-22 14:15:00	14.91	163.88	0.29	7.85	9.32	9.52	0.08
EAS-DS	2026-06-22 14:30:00	15.24	165.33	0.29	7.84	9.20	9.61	0.08
EAS-DS	2026-06-22 14:45:00	15.18	167.00	0.29	7.85	9.29	9.66	0.08
EAS-DS	2026-06-22 15:00:00	15.06	164.19	0.29	7.67	9.05	9.44	0.08
EAS-DS	2026-06-22 15:15:00	15.05	166.84	0.29	7.85	9.33	9.66	0.08
EAS-DS	2026-06-22 15:30:00	14.96	162.71	0.30	7.59	8.99	9.52	0.08
EAS-DS	2026-06-22 15:45:00	15.24	158.94	0.30	7.87	9.10	9.72	0.08
EAS-DS	2026-06-22 16:00:00	14.97	161.96	0.30	7.84	9.29	9.66	0.08
EAS-DS	2026-06-22 16:15:00	14.86	160.99	0.30	7.84	9.27	9.60	0.08
EAS-DS	2026-06-22 16:30:00	14.81	162.07	0.29	7.85	9.32	9.53	0.08
EAS-DS	2026-06-22 16:45:00	15.08	168.37	0.30	7.84	9.27	9.98	0.08
EAS-DS	2026-06-22 17:00:00	15.03	158.73	0.30	7.73	8.55	9.59	0.08
EAS-DS	2026-06-22 17:15:00	15.02	166.61	0.30	7.81	9.22	12.91	0.08
EAS-DS	2026-06-22 17:30:00	14.71	159.88	0.30	7.83	9.21	9.55	0.08
EAS-DS	2026-06-22 17:45:00	14.96	166.14	0.30	7.84	9.32	9.81	0.08
EAS-DS	2026-06-22 18:00:00	14.40	159.68	0.30	7.83	9.43	9.60	0.08
EAS-DS	2026-06-22 18:15:00	14.77	163.65	0.30	7.82	9.20	9.76	0.08
EAS-DS	2026-06-22 18:30:00	14.81	157.19	0.30	7.65	8.35	9.59	0.07
EAS-DS	2026-06-22 18:45:00	14.44	159.14	0.30	7.86	9.34	9.73	0.08
EAS-DS	2026-06-22 19:00:00	14.37	161.85	0.30	7.83	9.37	9.57	0.08
EAS-DS	2026-06-22 19:15:00	14.37	165.75	0.30	7.84	9.46	9.77	0.08
EAS-DS	2026-06-22 19:30:00	14.05	160.30	0.29	7.83	9.46	9.49	0.08
EAS-DS	2026-06-22 19:45:00	14.46	167.74	0.30	7.83	9.35	9.80	0.08
EAS-DS	2026-06-22 20:00:00	14.07	157.60	0.29	7.83	9.31	9.53	0.07
EAS-DS	2026-06-22 20:15:00	14.21	166.34	0.29	7.87	9.50	9.66	0.08
EAS-DS	2026-06-22 20:30:00	13.68	157.48	0.30	7.81	9.51	9.47	0.07
EAS-DS	2026-06-22 20:45:00	14.13	166.13	0.30	7.83	9.52	9.81	0.08
EAS-DS	2026-06-22 21:00:00	13.53	157.23	0.29	7.84	9.57	9.54	0.07
EAS-DS	2026-06-22 21:15:00	14.02	166.36	0.29	7.85	9.59	9.89	0.08
EAS-DS	2026-06-22 21:30:00	13.42	156.87	0.29	7.83	9.62	9.53	0.07
EAS-DS	2026-06-22 21:45:00	13.57	158.26	0.29	7.81	9.61	9.70	0.07
EAS-DS	2026-06-22 22:00:00	14.50	172.73	0.29	7.80	9.26	9.73	0.08
EAS-DS	2026-06-22 22:15:00	13.62	158.24	0.29	7.83	9.60	9.60	0.07
EAS-DS	2026-06-22 22:30:00	13.92	167.00	0.29	7.82	9.49	9.89	0.08
EAS-DS	2026-06-22 22:45:00	13.92	160.88	0.30	7.55	8.71	9.54	0.08
EAS-DS	2026-06-22 23:00:00	14.32	177.99	0.29	7.83	9.38	9.95	0.08
EAS-DS	2026-06-22 23:15:00	14.22	170.10	0.29	7.58	8.67	9.58	0.08
EAS-DS	2026-06-22 23:30:00	14.06	174.33	0.29	7.82	9.43	9.86	0.08
EAS-DS	2026-06-22 23:45:00	13.35	158.93	0.29	7.81	9.64	9.87	0.08
EAS-DS	2026-06-23 00:00:00	13.33	160.57	0.29	7.78	9.54	9.69	0.08
EAS-DS	2026-06-23 00:15:00	13.86	174.64	0.29	7.82	9.45	9.77	0.08
EAS-DS	2026-06-23 00:30:00	13.68	174.63	0.29	7.84	9.67	9.94	0.08
EAS-DS	2026-06-23 00:45:00	13.19	162.04	0.29	7.79	9.69	9.83	0.08
EAS-DS	2026-06-23 01:00:00	13.75	179.63	0.29	7.83	9.57	10.00	0.09
EAS-DS	2026-06-23 01:15:00	13.11	160.83	0.29	7.81	9.72	9.71	0.08
EAS-DS	2026-06-23 01:30:00	13.77	181.59	0.29	7.82	9.50	9.76	0.09
EAS-DS	2026-06-23 01:45:00	13.90	167.09	0.29	7.76	8.76	9.98	0.08
EAS-DS	2026-06-23 02:00:00	13.58	171.38	0.28	7.84	9.49	9.72	0.08
EAS-DS	2026-06-23 02:15:00	13.65	182.13	0.29	7.86	9.67	10.26	0.09
EAS-DS	2026-06-23 02:30:00	13.94	187.90	0.28	7.80	9.29	9.91	0.09
EAS-DS	2026-06-23 02:45:00	13.69	183.61	0.29	7.87	9.64	12.11	0.09
EAS-DS	2026-06-23 03:00:00	13.20	165.84	0.29	7.82	9.66	9.73	0.08
EAS-DS	2026-06-23 03:15:00	13.09	164.23	0.29	7.82	9.57	9.78	0.08

Woodfibre LNG (East Creek)								
Station	Date/Time	Temperature (C)	Specific Conductivity (µS/cm)	ORP (V)	pH (pH units)	Dissolved Oxygen (mg/L)	Turbidity (NTU)	Salinity (PSU)
EAS-DS	2026-06-23 03:30:00	13.45	178.85	0.29	7.82	9.60	13.14	0.08
EAS-DS	2026-06-23 03:45:00	13.82	191.67	0.29	7.86	9.38	11.48	0.09
EAS-DS	2026-06-23 04:00:00	13.79	190.72	0.28	7.85	9.49	13.26	0.09
EAS-DS	2026-06-23 04:15:00	13.16	169.58	0.29	7.84	9.78	9.95	0.08
EAS-DS	2026-06-23 04:30:00	13.27	173.15	0.29	7.82	9.61	10.45	0.08
EAS-DS	2026-06-23 04:45:00	13.33	179.40	0.29	7.81	9.64	11.09	0.09
EAS-DS	2026-06-23 05:00:00	13.61	185.63	0.29	7.69	9.32	11.10	0.09
EAS-DS	2026-06-23 05:15:00	13.63	188.02	0.29	7.84	9.30	15.14	0.09
EAS-DS	2026-06-23 05:30:00	13.36	180.99	0.28	7.81	9.63	11.61	0.09
EAS-DS	2026-06-23 05:45:00	13.19	163.01	0.29	7.73	9.28	9.75	0.08
EAS-DS	2026-06-23 06:00:00	13.11	174.38	0.29	7.80	9.70	10.70	0.08
EAS-DS	2026-06-23 06:15:00	13.05	172.77	0.30	7.81	9.64	10.36	0.08
EAS-DS	2026-06-23 06:30:00	13.29	178.52	0.29	7.73	9.55	10.12	0.08
EAS-DS	2026-06-23 06:45:00	13.16	174.95	0.29	7.81	9.46	10.36	0.08
EAS-DS	2026-06-23 07:00:00	12.86	162.10	0.29	7.80	9.74	9.53	0.08
EAS-DS	2026-06-23 07:15:00	13.03	163.89	0.30	7.78	9.51	10.46	0.08
EAS-DS	2026-06-23 07:30:00	13.02	170.12	0.30	7.79	9.75	10.00	0.08
EAS-DS	2026-06-23 07:45:00	13.01	169.51	0.30	7.78	9.57	9.93	0.08
EAS-DS	2026-06-23 08:00:00	12.90	161.79	0.30	7.80	9.75	9.54	0.08
EAS-DS	2026-06-23 08:15:00	13.11	169.20	0.30	7.78	9.69	10.99	0.08
EAS-DS	2026-06-23 08:30:00	13.07	160.07	0.30	7.79	9.68	9.79	0.08
EAS-DS	2026-06-23 08:45:00	13.20	167.28	0.30	7.80	9.51	11.86	0.08
EAS-DS	2026-06-23 09:00:00	13.19	163.43	0.31	7.56	9.12	9.54	0.08
EAS-DS	2026-06-23 09:15:00	13.42	167.06	0.30	7.79	9.22	11.14	0.08
EAS-DS	2026-06-23 09:30:00	13.42	165.98	0.31	7.61	9.08	14.78	0.08
EAS-DS	2026-06-23 09:45:00	13.69	170.63	0.30	7.80	9.57	10.40	0.08
EAS-DS	2026-06-23 10:00:00	13.82	165.48	0.30	7.81	9.57	9.76	0.08
EAS-DS	2026-06-23 10:15:00	13.77	168.52	0.30	7.80	9.36	9.69	0.08
EAS-DS	2026-06-23 10:30:00	13.76	165.58	0.30	7.80	9.58	9.85	0.08
EAS-DS	2026-06-23 10:45:00	13.83	167.95	0.30	7.80	9.46	9.79	0.08
EAS-DS	2026-06-23 11:00:00	13.88	159.07	0.30	7.83	9.52	9.78	0.08
EAS-DS	2026-06-23 11:15:00	14.04	166.44	0.30	7.81	9.46	10.47	0.08
EAS-DS	2026-06-23 11:30:00	14.09	158.44	0.30	7.77	9.29	9.62	0.07
EAS-DS	2026-06-23 11:45:00	14.72	0.07	0.25	9.51	9.68	70.17	0.00
EAS-DS	2026-06-23 12:00:00	14.58	167.81	0.27	7.89	9.65	10.25	0.08
EAS-DS	2026-06-23 12:15:00	14.61	170.81	0.27	7.89	9.62	9.70	0.08
EAS-DS	2026-06-23 12:30:00	14.58	164.45	0.27	7.75	9.17	12.46	0.08
EAS-DS	2026-06-23 12:45:00	15.05	176.80	0.27	7.88	9.45	9.39	0.08
EAS-DS	2026-06-23 13:00:00	14.99	163.70	0.28	7.66	8.84	9.29	0.08
EAS-DS	2026-06-23 13:15:00	15.23	165.84	0.28	7.88	9.36	10.01	0.08
EAS-DS	2026-06-23 13:30:00	15.35	159.33	0.28	7.91	9.42	9.50	0.08
EAS-DS	2026-06-23 13:45:00	15.10	169.15	0.28	7.91	9.52	9.55	0.08
EAS-DS	2026-06-23 14:00:00	15.14	171.80	0.28	7.88	9.41	9.37	0.08
EAS-DS	2026-06-23 14:15:00	15.54	183.97	0.28	7.91	9.30	9.70	0.09
EAS-DS	2026-06-23 14:30:00	15.22	164.68	0.28	7.91	9.44	9.85	0.08
EAS-DS	2026-06-23 14:45:00	15.15	171.67	0.28	7.92	9.49	10.55	0.08
EAS-DS	2026-06-23 15:00:00	15.04	161.72	0.29	7.77	9.23	9.30	0.08
EAS-DS	2026-06-23 15:15:00	15.60	171.60	0.29	7.84	9.14	10.70	0.08
EAS-DS	2026-06-23 15:30:00	15.70	180.92	0.28	7.91	9.30	9.47	0.09
EAS-DS	2026-06-23 15:45:00	15.66	176.21	0.28	7.92	9.36	9.50	0.08
EAS-DS	2026-06-23 16:00:00	15.38	175.58	0.28	7.90	9.39	10.17	0.08
EAS-DS	2026-06-23 16:15:00	15.55	172.57	0.28	7.89	9.26	9.62	0.08
EAS-DS	2026-06-23 16:30:00	15.41	164.48	0.29	7.90	9.42	9.55	0.08
EAS-DS	2026-06-23 16:45:00	15.08	164.71	0.29	7.92	9.47	9.40	0.08
EAS-DS	2026-06-23 17:00:00	15.17	174.07	0.29	7.91	9.44	9.46	0.08

Woodfibre LNG (East Creek)								
Station	Date/Time	Temperature (C)	Specific Conductivity (µS/cm)	ORP (V)	pH (pH units)	Dissolved Oxygen (mg/L)	Turbidity (NTU)	Salinity (PSU)
EAS-DS	2026-06-23 17:15:00	15.49	183.68	0.29	7.88	9.22	9.35	0.09
EAS-DS	2026-06-23 17:30:00	15.27	171.44	0.28	7.90	9.45	9.93	0.08
EAS-DS	2026-06-23 17:45:00	15.14	175.56	0.29	7.90	9.45	9.35	0.08
EAS-DS	2026-06-23 18:00:00	15.42	158.16	0.29	7.86	9.16	11.14	0.07
EAS-DS	2026-06-23 18:15:00	15.02	170.37	0.29	7.90	9.49	9.44	0.08
EAS-DS	2026-06-23 18:30:00	14.87	171.85	0.29	7.90	9.55	9.50	0.08
EAS-DS	2026-06-23 18:45:00	14.65	163.64	0.29	7.88	9.44	9.89	0.08
EAS-DS	2026-06-23 19:00:00	15.06	181.21	0.29	7.89	9.43	9.79	0.09
EAS-DS	2026-06-23 19:15:00	14.46	162.15	0.29	7.90	9.58	9.50	0.08
EAS-DS	2026-06-23 19:30:00	14.70	170.26	0.30	7.75	9.25	9.32	0.08
EAS-DS	2026-06-23 19:45:00	14.64	172.90	0.29	7.85	9.47	9.63	0.08
EAS-DS	2026-06-23 20:00:00	14.31	167.10	0.29	7.87	9.65	9.80	0.08
EAS-DS	2026-06-23 20:15:00	13.98	159.20	0.29	7.88	9.69	9.98	0.08
EAS-DS	2026-06-23 20:30:00	14.27	174.63	0.29	7.86	9.57	9.86	0.08
EAS-DS	2026-06-23 20:45:00	14.46	169.85	0.29	7.74	9.00	9.34	0.08
EAS-DS	2026-06-23 21:00:00	14.58	180.02	0.29	7.88	9.52	10.22	0.09
EAS-DS	2026-06-23 21:15:00	14.65	181.09	0.28	7.87	9.42	9.44	0.09
EAS-DS	2026-06-23 21:30:00	14.30	170.40	0.29	7.87	9.65	11.29	0.08
EAS-DS	2026-06-23 21:45:00	14.15	162.08	0.29	7.85	9.51	10.42	0.08
EAS-DS	2026-06-23 22:00:00	14.66	185.33	0.28	7.87	9.51	12.86	0.09
EAS-DS	2026-06-23 22:15:00	13.83	162.00	0.29	7.86	9.72	10.31	0.08
EAS-DS	2026-06-23 22:30:00	13.80	166.39	0.29	7.88	9.72	12.88	0.08
EAS-DS	2026-06-23 22:45:00	13.55	163.78	0.29	7.87	9.78	10.17	0.08
EAS-DS	2026-06-23 23:00:00	14.00	178.12	0.29	7.89	9.72	12.49	0.08
EAS-DS	2026-06-23 23:15:00	13.93	175.29	0.29	7.87	9.60	9.89	0.08
EAS-DS	2026-06-23 23:30:00	14.83	197.38	0.28	7.90	9.45	11.96	0.09
EAS-DS	2026-06-23 23:45:00	13.87	167.01	0.29	7.87	9.68	13.56	0.08
EAS-DS	2026-06-24 00:00:00	13.62	159.41	0.29	7.85	9.67	9.38	0.08
EAS-DS	2026-06-24 00:15:00	14.49	187.44	0.29	7.78	9.36	9.50	0.09
EAS-DS	2026-06-24 00:30:00	14.40	189.45	0.29	7.88	9.58	13.71	0.09
EAS-DS	2026-06-24 00:45:00	14.42	188.37	0.28	7.88	9.57	10.27	0.09
EAS-DS	2026-06-24 01:00:00	13.86	176.85	0.29	7.87	9.72	10.24	0.08
EAS-DS	2026-06-24 01:15:00	13.97	180.76	0.29	7.88	9.73	9.59	0.09
EAS-DS	2026-06-24 01:30:00	13.47	161.10	0.29	7.86	9.75	9.81	0.08
EAS-DS	2026-06-24 01:45:00	13.70	173.99	0.29	7.86	9.77	11.36	0.08
EAS-DS	2026-06-24 02:00:00	13.70	173.94	0.29	7.85	9.70	10.56	0.08
EAS-DS	2026-06-24 02:15:00	14.17	188.19	0.29	7.88	9.64	10.35	0.09
EAS-DS	2026-06-24 02:30:00	13.76	163.01	0.29	7.82	9.54	10.88	0.08
EAS-DS	2026-06-24 02:45:00	13.76	176.58	0.29	7.84	9.61	9.95	0.08
EAS-DS	2026-06-24 03:00:00	13.54	172.74	0.29	7.86	9.83	9.56	0.08
EAS-DS	2026-06-24 03:15:00	13.41	165.75	0.29	7.84	9.74	9.37	0.08
EAS-DS	2026-06-24 03:30:00	13.70	169.36	0.30	7.83	9.66	9.58	0.08
EAS-DS	2026-06-24 03:45:00	13.33	168.37	0.29	7.85	9.88	10.06	0.08
EAS-DS	2026-06-24 04:00:00	13.01	159.81	0.30	7.86	9.90	9.74	0.08
EAS-DS	2026-06-24 04:15:00	13.15	167.19	0.30	7.86	9.92	9.76	0.08
EAS-DS	2026-06-24 04:30:00	13.39	170.78	0.30	7.84	9.69	9.61	0.08
EAS-DS	2026-06-24 04:45:00	13.23	167.27	0.30	7.87	9.88	9.36	0.08
EAS-DS	2026-06-24 05:00:00	13.24	167.42	0.30	7.85	9.81	9.36	0.08
EAS-DS	2026-06-24 05:15:00	13.60	169.57	0.30	7.82	9.59	9.92	0.08
EAS-DS	2026-06-24 05:30:00	13.61	170.40	0.30	7.80	9.40	9.49	0.08
EAS-DS	2026-06-24 05:45:00	13.38	169.20	0.30	7.87	9.85	9.67	0.08
EAS-DS	2026-06-24 06:00:00	12.93	160.04	0.30	7.87	9.95	10.04	0.08
EAS-DS	2026-06-24 06:15:00	13.07	165.30	0.30	7.86	9.94	10.73	0.08
EAS-DS	2026-06-24 06:30:00	13.08	165.24	0.30	7.87	9.95	10.13	0.08
EAS-DS	2026-06-24 06:45:00	13.13	160.37	0.30	7.71	9.43	9.37	0.08

Woodfibre LNG (East Creek)								
Station	Date/Time	Temperature (C)	Specific Conductivity (µS/cm)	ORP (V)	pH (pH units)	Dissolved Oxygen (mg/L)	Turbidity (NTU)	Salinity (PSU)
EAS-DS	2026-06-24 07:00:00	13.37	166.91	0.30	7.85	9.78	9.91	0.08
EAS-DS	2026-06-24 07:15:00	12.97	160.85	0.30	7.87	9.96	9.57	0.08
EAS-DS	2026-06-24 07:30:00	12.94	158.53	0.30	7.87	9.94	9.68	0.08
EAS-DS	2026-06-24 07:45:00	13.17	163.22	0.31	7.84	9.83	9.73	0.08
EAS-DS	2026-06-24 08:00:00	13.21	155.18	0.30	7.85	9.76	9.40	0.07
EAS-DS	2026-06-24 08:15:00	13.06	161.93	0.30	7.86	9.97	10.68	0.08
EAS-DS	2026-06-24 08:30:00	12.99	157.12	0.31	7.86	9.95	10.02	0.07
EAS-DS	2026-06-24 08:45:00	13.05	161.08	0.31	7.86	9.94	9.87	0.08
EAS-DS	2026-06-24 09:00:00	13.05	156.45	0.31	7.86	9.92	9.58	0.07
EAS-DS	2026-06-24 09:15:00	13.13	158.75	0.31	7.86	9.93	9.52	0.08
EAS-DS	2026-06-24 09:30:00	13.18	160.99	0.31	7.83	9.79	9.32	0.08
EAS-DS	2026-06-24 09:45:00	13.42	154.72	0.31	7.81	9.73	9.33	0.07
EAS-DS	2026-06-24 10:00:00	13.35	161.00	0.31	7.81	9.71	9.24	0.08
EAS-DS	2026-06-24 10:15:00	13.54	159.91	0.31	7.84	9.76	9.60	0.08
EAS-DS	2026-06-24 10:30:00	13.79	155.36	0.31	7.86	9.67	9.32	0.07
EAS-DS	2026-06-24 10:45:00	13.67	160.57	0.31	7.85	9.74	9.42	0.08
EAS-DS	2026-06-24 11:00:00	13.83	159.48	0.31	7.84	9.64	9.29	0.08
EAS-DS	2026-06-24 11:15:00	13.88	160.47	0.31	7.87	9.74	9.38	0.08
EAS-DS	2026-06-24 11:30:00	13.98	160.30	0.31	7.87	9.71	10.00	0.08
EAS-DS	2026-06-24 11:45:00	14.05	161.49	0.31	7.88	9.71	9.49	0.08
EAS-DS	2026-06-24 12:00:00	14.17	160.46	0.31	7.88	9.68	10.23	0.08
EAS-DS	2026-06-24 12:15:00	14.27	162.26	0.31	7.89	9.66	9.80	0.08
EAS-DS	2026-06-24 12:30:00	14.34	157.05	0.31	7.87	9.59	9.44	0.07
EAS-DS	2026-06-24 12:45:00	14.57	164.57	0.31	7.89	9.49	9.45	0.08
EAS-DS	2026-06-24 13:00:00	14.68	163.62	0.31	7.90	9.53	10.20	0.08
EAS-DS	2026-06-24 13:15:00	14.61	162.44	0.31	7.89	9.57	10.92	0.08
EAS-DS	2026-06-24 13:30:00	14.76	165.20	0.31	7.73	9.16	9.45	0.08
EAS-DS	2026-06-24 13:45:00	14.84	164.98	0.31	7.90	9.53	10.40	0.08
EAS-DS	2026-06-24 14:00:00	14.67	159.25	0.31	7.90	9.53	9.49	0.08
EAS-DS	2026-06-24 14:15:00	14.93	166.45	0.30	7.91	9.50	9.86	0.08
EAS-DS	2026-06-24 14:30:00	15.06	167.22	0.30	7.89	9.40	10.39	0.08
EAS-DS	2026-06-24 14:45:00	15.33	172.76	0.30	7.91	9.39	10.33	0.08
EAS-DS	2026-06-24 15:00:00	15.13	160.76	0.30	7.89	9.38	9.48	0.08
EAS-DS	2026-06-24 15:15:00	15.33	171.64	0.30	7.91	9.39	9.64	0.08
EAS-DS	2026-06-24 15:30:00	15.17	160.90	0.30	7.90	9.39	9.41	0.08
EAS-DS	2026-06-24 15:45:00	15.49	175.37	0.30	7.89	9.27	9.59	0.08
EAS-DS	2026-06-24 16:00:00	15.53	168.80	0.30	7.90	9.34	9.70	0.08
EAS-DS	2026-06-24 16:15:00	15.46	173.23	0.30	7.91	9.35	10.40	0.08
EAS-DS	2026-06-24 16:30:00	15.39	166.80	0.30	7.89	9.22	9.46	0.08
EAS-DS	2026-06-24 16:45:00	15.48	172.33	0.30	7.65	9.01	9.43	0.08
EAS-DS	2026-06-24 17:00:00	15.87	170.05	0.30	7.87	9.11	9.70	0.08
EAS-DS	2026-06-24 17:15:00	15.53	163.35	0.30	7.90	9.30	11.17	0.08
EAS-DS	2026-06-24 17:30:00	15.20	169.87	0.30	7.91	9.41	9.88	0.08
EAS-DS	2026-06-24 17:45:00	15.19	163.92	0.30	7.88	9.33	9.60	0.08
EAS-DS	2026-06-24 18:00:00	15.48	180.03	0.29	7.88	9.21	9.99	0.09
EAS-DS	2026-06-24 18:15:00	15.42	166.58	0.30	7.82	9.14	9.48	0.08
EAS-DS	2026-06-24 18:30:00	15.39	174.65	0.29	7.90	9.33	10.33	0.08
EAS-DS	2026-06-24 18:45:00	15.18	173.89	0.30	7.90	9.39	10.30	0.08
EAS-DS	2026-06-24 19:00:00	14.72	161.61	0.30	7.88	9.46	9.49	0.08
EAS-DS	2026-06-24 19:15:00	14.55	164.43	0.30	7.88	9.52	9.52	0.08
EAS-DS	2026-06-24 19:30:00	14.62	169.65	0.30	7.90	9.49	10.34	0.08
EAS-DS	2026-06-24 19:45:00	14.32	163.11	0.30	7.88	9.57	9.86	0.08
EAS-DS	2026-06-24 20:00:00	14.28	163.33	0.30	7.88	9.55	10.08	0.08
EAS-DS	2026-06-24 20:15:00	14.66	172.99	0.30	7.87	9.49	9.92	0.08
EAS-DS	2026-06-24 20:30:00	14.45	169.93	0.30	7.88	9.55	9.84	0.08

Woodfibre LNG (East Creek)								
Station	Date/Time	Temperature (C)	Specific Conductivity (µS/cm)	ORP (V)	pH (pH units)	Dissolved Oxygen (mg/L)	Turbidity (NTU)	Salinity (PSU)
EAS-DS	2026-06-24 20:45:00	14.09	160.61	0.30	7.85	9.50	9.33	0.08
EAS-DS	2026-06-24 21:00:00	14.47	171.53	0.30	7.87	9.52	10.61	0.08
EAS-DS	2026-06-24 21:15:00	14.59	171.68	0.30	7.81	9.31	9.40	0.08
EAS-DS	2026-06-24 21:30:00	14.32	156.48	0.30	7.84	9.39	10.25	0.07
EAS-DS	2026-06-24 21:45:00	14.34	153.71	0.31	7.68	8.80	9.35	0.07
EAS-DS	2026-06-24 22:00:00	14.51	175.78	0.30	7.88	9.50	10.55	0.08
EAS-DS	2026-06-24 22:15:00	14.25	174.97	0.30	7.87	9.58	9.69	0.08
EAS-DS	2026-06-24 22:30:00	13.85	162.61	0.30	7.88	9.66	9.56	0.08
EAS-DS	2026-06-24 22:45:00	14.21	176.95	0.30	7.87	9.60	9.65	0.08
EAS-DS	2026-06-24 23:00:00	14.30	173.54	0.30	7.76	9.01	9.36	0.08
EAS-DS	2026-06-24 23:15:00	13.72	168.51	0.30	7.87	9.74	9.46	0.08
EAS-DS	2026-06-24 23:30:00	13.70	165.48	0.30	7.89	9.67	10.44	0.08
EAS-DS	2026-06-24 23:45:00	13.54	159.92	0.30	7.87	9.65	9.46	0.08
EAS-DS	2026-06-25 00:00:00	14.27	183.01	0.30	7.86	9.49	9.85	0.09
EAS-DS	2026-06-25 00:15:00	14.12	181.48	0.30	7.87	9.49	9.53	0.09
EAS-DS	2026-06-25 00:30:00	14.12	178.20	0.30	7.87	9.60	10.91	0.08
EAS-DS	2026-06-25 00:45:00	13.78	174.27	0.30	7.89	9.72	9.99	0.08
EAS-DS	2026-06-25 01:00:00	13.44	160.79	0.30	7.89	9.74	10.94	0.08
EAS-DS	2026-06-25 01:15:00	13.65	171.42	0.30	7.87	9.69	10.15	0.08
EAS-DS	2026-06-25 01:30:00	13.64	163.61	0.31	7.72	9.17	9.34	0.08
EAS-DS	2026-06-25 01:45:00	13.88	160.59	0.31	7.70	8.94	9.44	0.08
EAS-DS	2026-06-25 02:00:00	13.66	174.98	0.30	7.87	9.74	10.74	0.08
EAS-DS	2026-06-25 02:15:00	13.83	183.14	0.30	7.86	9.59	9.48	0.09
EAS-DS	2026-06-25 02:30:00	14.11	189.68	0.30	7.86	9.50	9.81	0.09
EAS-DS	2026-06-25 02:45:00	14.10	181.89	0.30	7.71	8.83	9.57	0.09
EAS-DS	2026-06-25 03:00:00	14.04	188.40	0.30	7.89	9.57	10.05	0.09
EAS-DS	2026-06-25 03:15:00	13.88	187.76	0.30	7.86	9.56	10.13	0.09
EAS-DS	2026-06-25 03:30:00	13.64	177.13	0.30	7.88	9.72	9.93	0.08
EAS-DS	2026-06-25 03:45:00	13.27	163.06	0.30	7.88	9.81	10.88	0.08
EAS-DS	2026-06-25 04:00:00	13.23	162.32	0.30	7.89	9.81	9.47	0.08
EAS-DS	2026-06-25 04:15:00	13.50	176.75	0.30	7.88	9.78	12.23	0.08
EAS-DS	2026-06-25 04:30:00	13.64	182.39	0.30	7.87	9.69	12.65	0.09
EAS-DS	2026-06-25 04:45:00	13.59	169.50	0.30	7.86	9.58	10.33	0.08
EAS-DS	2026-06-25 05:00:00	13.21	162.19	0.30	7.86	9.78	10.12	0.08
EAS-DS	2026-06-25 05:15:00	13.49	170.80	0.30	7.85	9.64	9.78	0.08
EAS-DS	2026-06-25 05:30:00	13.79	189.86	0.30	7.88	9.59	9.99	0.09
EAS-DS	2026-06-25 05:45:00	13.82	191.17	0.29	7.87	9.65	11.16	0.09
EAS-DS	2026-06-25 06:00:00	13.40	174.00	0.30	7.86	9.80	14.25	0.08
EAS-DS	2026-06-25 06:15:00	13.39	170.52	0.30	7.88	9.77	9.55	0.08
EAS-DS	2026-06-25 06:30:00	13.45	178.28	0.29	7.88	9.81	10.88	0.08
EAS-DS	2026-06-25 06:45:00	13.33	167.03	0.29	7.88	9.78	10.46	0.08
EAS-DS	2026-06-25 07:00:00	13.55	183.19	0.30	7.89	9.74	10.32	0.09
EAS-DS	2026-06-25 07:15:00	13.47	163.33	0.30	7.80	9.44	9.49	0.08
EAS-DS	2026-06-25 07:30:00	13.30	163.39	0.30	7.90	9.78	10.51	0.08
EAS-DS	2026-06-25 07:45:00	13.49	176.89	0.30	7.89	9.79	10.22	0.08
EAS-DS	2026-06-25 08:00:00	13.34	163.68	0.30	7.89	9.79	9.59	0.08
EAS-DS	2026-06-25 08:15:00	13.57	172.36	0.30	7.81	9.55	9.45	0.08
EAS-DS	2026-06-25 08:30:00	13.65	178.50	0.30	7.88	9.70	12.19	0.08
EAS-DS	2026-06-25 08:45:00	13.65	171.74	0.30	7.86	9.72	12.54	0.08
EAS-DS	2026-06-25 09:00:00	13.58	170.32	0.30	7.85	9.63	9.71	0.08
EAS-DS	2026-06-25 09:15:00	13.62	172.90	0.30	7.85	9.67	11.14	0.08
EAS-DS	2026-06-25 09:30:00	13.53	164.52	0.30	7.87	9.68	10.06	0.08
EAS-DS	2026-06-25 09:45:00	13.54	167.95	0.30	7.87	9.77	13.49	0.08
EAS-DS	2026-06-25 10:00:00	13.55	167.80	0.30	7.87	9.69	10.63	0.08
EAS-DS	2026-06-25 10:15:00	13.57	167.98	0.30	7.88	9.74	13.76	0.08

Woodfibre LNG (East Creek)								
Station	Date/Time	Temperature (C)	Specific Conductivity (µS/cm)	ORP (V)	pH (pH units)	Dissolved Oxygen (mg/L)	Turbidity (NTU)	Salinity (PSU)
EAS-DS	2026-06-25 10:30:00	13.62	165.55	0.30	7.89	9.74	14.29	0.08
EAS-DS	2026-06-25 10:45:00	13.58	165.85	0.30	7.87	9.77	11.34	0.08
EAS-DS	2026-06-25 11:00:00	13.55	160.37	0.30	7.87	9.69	9.65	0.08
EAS-DS	2026-06-25 11:15:00	13.70	165.23	0.30	7.88	9.74	12.68	0.08
EAS-DS	2026-06-25 11:30:00	13.61	159.70	0.30	7.90	9.72	10.19	0.08
EAS-DS	2026-06-25 11:45:00	13.68	164.76	0.30	7.87	9.68	13.29	0.08
EAS-DS	2026-06-25 12:00:00	13.81	163.73	0.31	7.80	9.44	10.72	0.08
EAS-DS	2026-06-25 12:15:00	13.72	160.39	0.30	7.89	9.68	10.23	0.08
EAS-DS	2026-06-25 12:30:00	13.62	163.49	0.31	7.89	9.73	10.75	0.08
EAS-DS	2026-06-25 12:45:00	13.79	165.53	0.31	7.87	9.63	10.70	0.08
EAS-DS	2026-06-25 13:00:00	13.81	161.46	0.31	7.80	9.46	9.95	0.08
EAS-DS	2026-06-25 13:15:00	13.63	163.77	0.31	7.89	9.76	10.76	0.08
EAS-DS	2026-06-25 13:30:00	13.66	162.84	0.30	7.89	9.65	10.99	0.08
EAS-DS	2026-06-25 13:45:00	13.82	166.59	0.31	7.87	9.61	10.11	0.08
EAS-DS	2026-06-25 14:00:00	13.83	165.05	0.30	7.90	9.65	10.74	0.08
EAS-DS	2026-06-25 14:15:00	13.96	166.71	0.30	7.89	9.66	10.48	0.08
EAS-DS	2026-06-25 14:30:00	13.87	166.12	0.30	7.88	9.62	11.02	0.08
EAS-DS	2026-06-25 14:45:00	13.77	166.32	0.30	7.89	9.71	10.40	0.08
EAS-DS	2026-06-25 15:00:00	13.64	167.73	0.30	7.90	9.71	10.17	0.08
EAS-DS	2026-06-25 15:15:00	13.69	167.28	0.30	7.87	9.62	9.82	0.08
EAS-DS	2026-06-25 15:30:00	13.70	167.67	0.30	7.91	9.69	10.08	0.08
EAS-DS	2026-06-25 15:45:00	13.60	166.40	0.30	7.90	9.73	10.10	0.08
EAS-DS	2026-06-25 16:00:00	13.63	164.66	0.30	7.91	9.66	9.94	0.08
EAS-DS	2026-06-25 16:15:00	13.75	157.71	0.30	7.89	9.66	10.13	0.07
EAS-DS	2026-06-25 16:30:00	13.66	166.80	0.30	7.90	9.71	10.71	0.08
EAS-DS	2026-06-25 16:45:00	13.68	160.96	0.30	7.88	9.62	9.77	0.08
EAS-DS	2026-06-25 17:00:00	13.75	167.30	0.30	7.90	9.68	10.36	0.08
EAS-DS	2026-06-25 17:15:00	13.60	162.01	0.29	7.90	9.73	10.15	0.08
EAS-DS	2026-06-25 17:30:00	13.55	165.42	0.29	7.89	9.75	10.46	0.08
EAS-DS	2026-06-25 17:45:00	13.47	164.99	0.30	7.90	9.78	9.97	0.08
EAS-DS	2026-06-25 18:00:00	13.54	165.48	0.30	7.89	9.69	10.01	0.08
EAS-DS	2026-06-25 18:15:00	13.57	159.62	0.30	7.83	9.50	9.70	0.08
EAS-DS	2026-06-25 18:30:00	13.46	163.81	0.29	7.90	9.74	10.29	0.08
EAS-DS	2026-06-25 18:45:00	13.34	161.47	0.29	7.91	9.80	10.23	0.08
EAS-DS	2026-06-25 19:00:00	13.33	161.48	0.29	7.91	9.76	9.81	0.08
EAS-DS	2026-06-25 19:15:00	13.31	162.82	0.29	7.90	9.80	15.00	0.08
EAS-DS	2026-06-25 19:30:00	13.19	158.93	0.30	7.88	9.73	12.60	0.08
EAS-DS	2026-06-25 19:45:00	13.25	157.52	0.30	7.78	9.48	9.88	0.07
EAS-DS	2026-06-25 20:00:00	13.45	156.23	0.30	7.84	9.61	12.14	0.07
EAS-DS	2026-06-25 20:15:00	13.17	161.11	0.30	7.88	9.80	10.03	0.08
EAS-DS	2026-06-25 20:30:00	13.07	161.05	0.30	7.89	9.83	9.98	0.08
EAS-DS	2026-06-25 20:45:00	13.18	154.90	0.30	7.81	9.55	10.51	0.07
EAS-DS	2026-06-25 21:00:00	13.27	158.73	0.30	7.86	9.62	10.75	0.08
EAS-DS	2026-06-25 21:15:00	13.06	158.51	0.30	7.88	9.82	13.84	0.08
EAS-DS	2026-06-25 21:30:00	12.94	159.00	0.30	7.89	9.86	22.95	0.08
EAS-DS	2026-06-25 21:45:00	13.23	163.47	0.30	7.86	9.75	11.20	0.08
EAS-DS	2026-06-25 22:00:00	13.10	160.64	0.29	7.87	9.81	23.10	0.08
EAS-DS	2026-06-25 22:15:00	13.05	162.51	0.29	7.85	9.82	17.96	0.08
EAS-DS	2026-06-25 22:30:00	13.26	164.12	0.28	7.85	9.68	9.59	0.08
EAS-DS	2026-06-25 22:45:00	12.97	159.27	0.28	7.87	9.82	9.67	0.08
EAS-DS	2026-06-25 23:00:00	13.09	162.84	0.27	7.81	9.60	32.31	0.08
EAS-DS	2026-06-25 23:15:00	13.19	151.78	0.28	7.75	9.40	9.59	0.07
EAS-DS	2026-06-25 23:30:00	12.87	157.53	0.27	7.86	9.82	10.98	0.07
EAS-DS	2026-06-25 23:45:00	12.96	163.93	0.28	7.88	9.86	15.40	0.08
EAS-DS	2026-06-26 00:00:00	12.99	164.53	0.27	7.88	9.83	11.86	0.08

Woodfibre LNG (East Creek)								
Station	Date/Time	Temperature (C)	Specific Conductivity (µS/cm)	ORP (V)	pH (pH units)	Dissolved Oxygen (mg/L)	Turbidity (NTU)	Salinity (PSU)
EAS-DS	2026-06-26 00:15:00	12.94	164.04	0.28	7.88	9.85	10.80	0.08
EAS-DS	2026-06-26 00:30:00	13.14	165.87	0.27	7.87	9.76	11.06	0.08
EAS-DS	2026-06-26 00:45:00	12.99	164.28	0.27	7.87	9.85	10.91	0.08
EAS-DS	2026-06-26 01:00:00	13.05	164.74	0.26	7.88	9.79	16.67	0.08
EAS-DS	2026-06-26 01:15:00	13.19	165.65	0.27	7.89	9.75	10.54	0.08
EAS-DS	2026-06-26 01:30:00	13.21	158.70	0.27	7.75	9.21	10.58	0.08
EAS-DS	2026-06-26 01:45:00	13.08	151.37	0.28	7.85	9.73	12.91	0.07
EAS-DS	2026-06-26 02:00:00	12.87	156.86	0.28	7.87	9.78	11.40	0.07
EAS-DS	2026-06-26 02:15:00	12.81	158.46	0.28	7.87	9.83	9.29	0.08
EAS-DS	2026-06-26 02:30:00	12.96	163.31	0.28	7.88	9.81	9.82	0.08
EAS-DS	2026-06-26 02:45:00	12.94	163.12	0.28	7.89	9.84	9.51	0.08
EAS-DS	2026-06-26 03:00:00	12.90	162.71	0.28	7.88	9.87	10.15	0.08
EAS-DS	2026-06-26 03:15:00	12.78	159.15	0.28	7.88	9.87	9.29	0.08
EAS-DS	2026-06-26 03:30:00	12.96	163.08	0.28	7.87	9.79	9.28	0.08
EAS-DS	2026-06-26 03:45:00	13.08	163.56	0.28	7.88	9.79	9.19	0.08
EAS-DS	2026-06-26 04:00:00	12.90	158.13	0.29	7.87	9.77	9.27	0.07
EAS-DS	2026-06-26 04:15:00	12.86	162.58	0.29	7.87	9.87	9.33	0.08
EAS-DS	2026-06-26 04:30:00	12.94	161.01	0.29	7.72	9.65	9.52	0.08
EAS-DS	2026-06-26 04:45:00	12.91	158.17	0.30	7.85	9.84	9.45	0.07
EAS-DS	2026-06-26 05:00:00	12.67	157.72	0.29	7.84	9.80	9.25	0.07
EAS-DS	2026-06-26 05:15:00	12.74	161.94	0.29	7.86	9.90	9.64	0.08
EAS-DS	2026-06-26 05:30:00	12.76	162.12	0.29	7.86	9.90	9.44	0.08
EAS-DS	2026-06-26 05:45:00	12.69	157.54	0.29	7.80	9.66	9.18	0.07
EAS-DS	2026-06-26 06:00:00	12.84	162.64	0.29	7.88	9.85	9.90	0.08
EAS-DS	2026-06-26 06:15:00	12.68	161.51	0.29	7.87	9.92	9.26	0.08
EAS-DS	2026-06-26 06:30:00	12.55	157.31	0.30	7.87	9.88	9.41	0.07
EAS-DS	2026-06-26 06:45:00	12.77	161.60	0.30	7.86	9.81	9.17	0.08
EAS-DS	2026-06-26 07:00:00	12.72	158.57	0.30	7.87	9.82	9.24	0.08
EAS-DS	2026-06-26 07:15:00	12.81	158.27	0.30	7.86	9.84	10.11	0.07
EAS-DS	2026-06-26 07:30:00	12.76	160.87	0.30	7.87	9.86	12.53	0.08
EAS-DS	2026-06-26 07:45:00	12.64	156.69	0.30	7.88	9.90	9.62	0.07
EAS-DS	2026-06-26 08:00:00	12.70	160.69	0.30	7.88	9.89	9.75	0.08
EAS-DS	2026-06-26 08:15:00	12.73	154.23	0.30	7.84	9.75	9.36	0.07
EAS-DS	2026-06-26 08:30:00	12.67	160.09	0.30	7.88	9.89	9.59	0.08
EAS-DS	2026-06-26 08:45:00	12.68	159.36	0.30	7.84	9.84	9.19	0.08
EAS-DS	2026-06-26 09:00:00	12.72	152.86	0.30	7.87	9.75	9.49	0.07
EAS-DS	2026-06-26 09:15:00	12.65	159.58	0.30	7.87	9.90	9.69	0.08
EAS-DS	2026-06-26 09:30:00	12.65	154.77	0.30	7.87	9.87	9.92	0.07
EAS-DS	2026-06-26 09:45:00	12.65	160.30	0.30	7.88	9.94	11.17	0.08
EAS-DS	2026-06-26 10:00:00	12.79	161.42	0.29	7.88	9.82	9.48	0.08
EAS-DS	2026-06-26 10:15:00	12.83	159.48	0.30	7.87	9.85	9.31	0.08
EAS-DS	2026-06-26 10:30:00	12.88	162.14	0.29	7.88	9.80	9.36	0.08
EAS-DS	2026-06-26 10:45:00	12.81	159.88	0.29	7.87	9.77	9.59	0.08
EAS-DS	2026-06-26 11:00:00	12.89	159.67	0.29	7.89	9.80	9.75	0.08
EAS-DS	2026-06-26 11:15:00	12.86	159.96	0.29	7.89	9.88	10.97	0.08
EAS-DS	2026-06-26 11:30:00	12.87	152.12	0.29	7.88	9.76	11.18	0.07
EAS-DS	2026-06-26 11:45:00	13.07	149.70	0.30	7.75	9.34	9.22	0.07
EAS-DS	2026-06-26 12:00:00	13.00	161.33	0.29	7.90	9.85	9.76	0.08
EAS-DS	2026-06-26 12:15:00	13.03	161.47	0.29	7.90	9.83	9.71	0.08
EAS-DS	2026-06-26 12:30:00	13.04	160.51	0.29	7.90	9.84	25.02	0.08
EAS-DS	2026-06-26 12:45:00	13.16	164.96	0.29	7.90	9.76	9.95	0.08
EAS-DS	2026-06-26 13:00:00	13.20	164.00	0.29	7.90	9.77	11.35	0.08
EAS-DS	2026-06-26 13:15:00	13.21	150.49	0.29	7.90	9.73	11.78	0.07
EAS-DS	2026-06-26 13:30:00	13.06	155.16	0.29	7.92	9.80	9.34	0.07
EAS-DS	2026-06-26 13:45:00	13.24	166.75	0.29	7.91	9.76	9.38	0.08

Woodfibre LNG (East Creek)								
Station	Date/Time	Temperature (C)	Specific Conductivity (µS/cm)	ORP (V)	pH (pH units)	Dissolved Oxygen (mg/L)	Turbidity (NTU)	Salinity (PSU)
EAS-DS	2026-06-26 14:00:00	13.17	155.27	0.29	7.82	9.61	9.23	0.07
EAS-DS	2026-06-26 14:15:00	13.35	161.38	0.30	7.89	9.72	9.27	0.08
EAS-DS	2026-06-26 14:30:00	13.32	166.35	0.29	7.91	9.71	9.57	0.08
EAS-DS	2026-06-26 14:45:00	13.18	157.99	0.29	7.92	9.79	9.25	0.07
EAS-DS	2026-06-26 15:00:00	13.11	157.55	0.29	7.92	9.78	9.71	0.07
EAS-DS	2026-06-26 15:15:00	13.15	164.30	0.29	7.92	9.79	9.67	0.08
EAS-DS	2026-06-26 15:30:00	13.21	161.75	0.30	7.75	9.33	9.25	0.08
EAS-DS	2026-06-26 15:45:00	13.18	164.23	0.29	7.90	9.79	15.47	0.08
EAS-DS	2026-06-26 16:00:00	13.21	164.94	0.29	7.89	9.75	11.39	0.08
EAS-DS	2026-06-26 16:15:00	13.03	156.40	0.29	7.89	9.82	9.54	0.07
EAS-DS	2026-06-26 16:30:00	13.00	156.50	0.29	7.90	9.78	9.53	0.07
EAS-DS	2026-06-26 16:45:00	13.10	157.15	0.29	7.91	9.84	9.77	0.07
EAS-DS	2026-06-26 17:00:00	13.13	163.61	0.29	7.89	9.76	9.56	0.08
EAS-DS	2026-06-26 17:15:00	13.23	162.31	0.29	7.87	9.70	9.32	0.08
EAS-DS	2026-06-26 17:30:00	13.24	163.81	0.29	7.82	9.55	9.31	0.08
EAS-DS	2026-06-26 17:45:00	13.26	164.21	0.29	7.89	9.78	13.33	0.08
EAS-DS	2026-06-26 18:00:00	13.14	162.60	0.29	7.90	9.79	9.60	0.08
EAS-DS	2026-06-26 18:15:00	13.10	163.64	0.29	7.89	9.81	9.40	0.08
EAS-DS	2026-06-26 18:30:00	13.12	164.77	0.29	7.89	9.82	10.28	0.08
EAS-DS	2026-06-26 18:45:00	13.11	164.45	0.29	7.89	9.84	9.61	0.08
EAS-DS	2026-06-26 19:00:00	13.19	162.33	0.29	7.73	9.29	9.21	0.08
EAS-DS	2026-06-26 19:15:00	13.13	159.97	0.29	7.89	9.82	9.34	0.08
EAS-DS	2026-06-26 19:30:00	13.11	160.71	0.29	7.91	9.80	10.13	0.08
EAS-DS	2026-06-26 19:45:00	13.17	164.65	0.29	7.88	9.78	9.44	0.08
EAS-DS	2026-06-26 20:00:00	13.30	164.07	0.29	7.86	9.64	9.36	0.08
EAS-DS	2026-06-26 20:15:00	13.17	163.92	0.29	7.88	9.83	9.93	0.08
EAS-DS	2026-06-26 20:30:00	12.97	158.58	0.29	7.90	9.83	9.74	0.08
EAS-DS	2026-06-26 20:45:00	12.93	160.09	0.29	7.89	9.87	9.40	0.08
EAS-DS	2026-06-26 21:00:00	12.96	161.19	0.29	7.85	9.71	9.60	0.08
EAS-DS	2026-06-26 21:15:00	13.05	159.81	0.30	7.82	9.74	9.50	0.08
EAS-DS	2026-06-26 21:30:00	13.05	156.00	0.30	7.66	9.02	9.18	0.07
EAS-DS	2026-06-26 21:45:00	12.87	161.78	0.30	7.87	9.88	10.06	0.08
EAS-DS	2026-06-26 22:00:00	12.72	156.53	0.29	7.89	9.88	9.46	0.07
EAS-DS	2026-06-26 22:15:00	12.70	160.67	0.30	7.87	9.91	9.39	0.08
EAS-DS	2026-06-26 22:30:00	12.71	161.13	0.29	7.88	9.88	9.63	0.08
EAS-DS	2026-06-26 22:45:00	12.60	156.55	0.30	7.88	9.94	9.70	0.07
EAS-DS	2026-06-26 23:00:00	12.83	161.31	0.30	7.85	9.75	9.41	0.08
EAS-DS	2026-06-26 23:15:00	12.95	162.56	0.30	7.85	9.75	9.51	0.08
EAS-DS	2026-06-26 23:30:00	12.79	162.69	0.30	7.88	9.88	9.54	0.08
EAS-DS	2026-06-26 23:45:00	12.58	154.17	0.30	7.87	9.88	9.68	0.07
EAS-DS	2026-06-27 00:00:00	12.57	157.73	0.30	7.88	9.94	9.61	0.07
EAS-DS	2026-06-27 00:15:00	12.51	157.70	0.30	7.87	9.92	10.15	0.07
EAS-DS	2026-06-27 00:30:00	12.52	160.15	0.30	7.86	9.91	9.56	0.08
EAS-DS	2026-06-27 00:45:00	12.39	154.71	0.30	7.88	9.99	9.43	0.07
EAS-DS	2026-06-27 01:00:00	12.48	160.94	0.30	7.87	9.94	9.33	0.08
EAS-DS	2026-06-27 01:15:00	12.49	159.50	0.30	7.86	9.94	9.28	0.08
EAS-DS	2026-06-27 01:30:00	12.61	152.62	0.30	7.78	9.47	9.73	0.07
EAS-DS	2026-06-27 01:45:00	12.45	160.79	0.30	7.87	9.99	9.62	0.08
EAS-DS	2026-06-27 02:00:00	12.45	160.66	0.30	7.85	9.87	9.28	0.08
EAS-DS	2026-06-27 02:15:00	12.38	160.64	0.30	7.84	9.98	11.09	0.08
EAS-DS	2026-06-27 02:30:00	12.51	158.14	0.30	7.74	9.62	9.20	0.07
EAS-DS	2026-06-27 02:45:00	12.42	160.67	0.30	7.83	9.90	9.21	0.08
EAS-DS	2026-06-27 03:00:00	12.48	147.19	0.31	7.73	9.44	9.49	0.07
EAS-DS	2026-06-27 03:15:00	12.46	160.97	0.30	7.83	9.87	9.20	0.08
EAS-DS	2026-06-27 03:30:00	12.49	145.14	0.31	7.72	9.41	9.38	0.07

Woodfibre LNG (East Creek)								
Station	Date/Time	Temperature (C)	Specific Conductivity (µS/cm)	ORP (V)	pH (pH units)	Dissolved Oxygen (mg/L)	Turbidity (NTU)	Salinity (PSU)
EAS-DS	2026-06-27 03:45:00	12.42	160.99	0.31	7.85	10.00	11.02	0.08
EAS-DS	2026-06-27 04:00:00	12.32	160.98	0.30	7.87	10.05	13.69	0.08
EAS-DS	2026-06-27 04:15:00	12.28	160.86	0.30	7.86	10.05	9.54	0.08
EAS-DS	2026-06-27 04:30:00	12.31	160.81	0.30	7.87	10.02	9.60	0.08
EAS-DS	2026-06-27 04:45:00	12.32	160.37	0.30	7.85	9.95	9.28	0.08
EAS-DS	2026-06-27 05:00:00	12.48	158.87	0.30	7.82	9.89	9.27	0.08
EAS-DS	2026-06-27 05:15:00	12.56	160.54	0.30	7.74	9.46	9.27	0.08
EAS-DS	2026-06-27 05:30:00	12.27	160.97	0.30	7.86	10.04	9.84	0.08
EAS-DS	2026-06-27 05:45:00	12.21	157.80	0.30	7.85	10.00	9.24	0.07
EAS-DS	2026-06-27 06:00:00	12.09	156.56	0.30	7.86	10.02	9.30	0.07
EAS-DS	2026-06-27 06:15:00	12.21	161.32	0.31	7.86	10.07	10.01	0.08
EAS-DS	2026-06-27 06:30:00	12.26	157.77	0.31	7.72	9.58	9.23	0.07
EAS-DS	2026-06-27 06:45:00	12.20	160.99	0.30	7.86	10.09	12.40	0.08
EAS-DS	2026-06-27 07:00:00	12.19	160.99	0.30	7.86	10.08	10.01	0.08
EAS-DS	2026-06-27 07:15:00	12.27	160.87	0.30	7.82	9.95	9.64	0.08
EAS-DS	2026-06-27 07:30:00	12.18	156.30	0.30	7.85	9.97	9.67	0.07
EAS-DS	2026-06-27 07:45:00	12.28	160.98	0.30	7.86	10.04	9.60	0.08
EAS-DS	2026-06-27 08:00:00	12.40	154.42	0.31	7.82	9.89	9.29	0.07
EAS-DS	2026-06-27 08:15:00	12.42	152.41	0.31	7.74	9.56	9.55	0.07
EAS-DS	2026-06-27 08:30:00	12.37	155.37	0.31	7.83	9.87	9.20	0.07
EAS-DS	2026-06-27 08:45:00	12.37	160.58	0.31	7.85	10.04	9.79	0.08
EAS-DS	2026-06-27 09:00:00	12.42	160.25	0.30	7.85	10.01	9.30	0.08
EAS-DS	2026-06-27 09:15:00	12.46	161.36	0.30	7.85	10.01	9.78	0.08
EAS-DS	2026-06-27 09:30:00	12.46	158.97	0.30	7.71	9.57	9.88	0.08
EAS-DS	2026-06-27 09:45:00	12.55	163.19	0.31	7.83	9.91	9.42	0.08
EAS-DS	2026-06-27 10:00:00	12.60	172.30	0.30	7.85	9.92	9.24	0.08
EAS-DS	2026-06-27 10:15:00	12.62	175.88	0.31	7.85	9.98	11.18	0.08
EAS-DS	2026-06-27 10:30:00	12.72	173.74	0.31	7.85	9.92	9.33	0.08
EAS-DS	2026-06-27 10:45:00	12.84	171.93	0.31	7.85	9.92	36.26	0.08
EAS-DS	2026-06-27 11:00:00	12.95	167.96	0.31	7.85	9.85	9.23	0.08
EAS-DS	2026-06-27 11:15:00	13.00	171.82	0.31	7.85	9.84	9.39	0.08
EAS-DS	2026-06-27 11:30:00	13.03	169.47	0.31	7.86	9.76	9.45	0.08
EAS-DS	2026-06-27 11:45:00	13.12	167.59	0.31	7.86	9.85	9.82	0.08
EAS-DS	2026-06-27 12:00:00	13.23	166.52	0.31	7.86	9.81	10.45	0.08
EAS-DS	2026-06-27 12:15:00	13.23	166.82	0.31	7.85	9.79	16.90	0.08
EAS-DS	2026-06-27 12:30:00	13.44	166.39	0.31	7.87	9.77	11.13	0.08
EAS-DS	2026-06-27 12:45:00	13.40	164.70	0.31	7.88	9.79	9.53	0.08
EAS-DS	2026-06-27 13:00:00	13.50	164.92	0.31	7.89	9.76	9.54	0.08
EAS-DS	2026-06-27 13:15:00	13.52	162.56	0.31	7.87	9.73	9.60	0.08
EAS-DS	2026-06-27 13:30:00	13.71	164.16	0.31	7.88	9.66	9.84	0.08
EAS-DS	2026-06-27 13:45:00	13.81	160.74	0.31	7.83	9.57	9.30	0.08
EAS-DS	2026-06-27 14:00:00	13.78	158.18	0.31	7.87	9.56	10.07	0.07
EAS-DS	2026-06-27 14:15:00	13.82	163.66	0.31	7.88	9.63	9.75	0.08
EAS-DS	2026-06-27 14:30:00	13.76	164.72	0.30	7.88	9.69	9.63	0.08
EAS-DS	2026-06-27 14:45:00	13.85	159.70	0.30	7.88	9.60	9.96	0.08
EAS-DS	2026-06-27 15:00:00	13.93	159.54	0.31	7.90	9.67	9.90	0.08
EAS-DS	2026-06-27 15:15:00	13.85	160.66	0.31	7.74	9.24	11.64	0.08
EAS-DS	2026-06-27 15:30:00	13.93	163.37	0.30	7.88	9.67	10.76	0.08
EAS-DS	2026-06-27 15:45:00	13.95	158.75	0.31	7.84	9.43	9.38	0.08
EAS-DS	2026-06-27 16:00:00	13.87	162.44	0.30	7.87	9.70	10.73	0.08
EAS-DS	2026-06-27 16:15:00	13.71	156.43	0.31	7.86	9.60	9.50	0.07
EAS-DS	2026-06-27 16:30:00	13.85	152.50	0.31	7.71	9.20	9.65	0.07
EAS-DS	2026-06-27 16:45:00	13.97	154.35	0.31	7.86	9.57	10.78	0.07
EAS-DS	2026-06-27 17:00:00	13.76	161.33	0.30	7.88	9.70	11.01	0.08
EAS-DS	2026-06-27 17:15:00	13.78	157.31	0.30	7.88	9.70	9.91	0.07

Woodfibre LNG (East Creek)								
Station	Date/Time	Temperature (C)	Specific Conductivity (µS/cm)	ORP (V)	pH (pH units)	Dissolved Oxygen (mg/L)	Turbidity (NTU)	Salinity (PSU)
EAS-DS	2026-06-27 17:30:00	13.63	160.22	0.30	7.88	9.76	12.21	0.08
EAS-DS	2026-06-27 17:45:00	13.60	158.58	0.30	7.89	9.78	10.31	0.08
EAS-DS	2026-06-27 18:00:00	13.65	160.84	0.30	7.85	9.60	9.51	0.08
EAS-DS	2026-06-27 18:15:00	13.79	158.17	0.30	7.89	9.71	10.18	0.07
EAS-DS	2026-06-27 18:30:00	13.62	160.98	0.30	7.88	9.75	10.86	0.08
EAS-DS	2026-06-27 18:45:00	13.54	158.14	0.30	7.87	9.70	10.55	0.07
EAS-DS	2026-06-27 19:00:00	13.61	157.97	0.31	7.67	9.00	11.53	0.07
EAS-DS	2026-06-27 19:15:00	13.74	151.39	0.31	7.82	9.53	9.66	0.07
EAS-DS	2026-06-27 19:30:00	13.38	157.51	0.30	7.89	9.78	10.50	0.07
EAS-DS	2026-06-27 19:45:00	13.36	164.10	0.30	7.88	9.84	12.20	0.08
EAS-DS	2026-06-27 20:00:00	13.31	165.07	0.30	7.87	9.81	10.88	0.08
EAS-DS	2026-06-27 20:15:00	13.52	165.06	0.30	7.75	9.17	9.91	0.08
EAS-DS	2026-06-27 20:30:00	13.54	146.51	0.31	7.73	9.17	11.18	0.07
EAS-DS	2026-06-27 20:45:00	13.25	164.45	0.30	7.87	9.84	10.53	0.08
EAS-DS	2026-06-27 21:00:00	12.97	158.09	0.30	7.88	9.86	10.07	0.07
EAS-DS	2026-06-27 21:15:00	12.79	158.72	0.31	7.87	9.93	10.84	0.08
EAS-DS	2026-06-27 21:30:00	13.02	159.10	0.31	7.73	9.33	9.74	0.08
EAS-DS	2026-06-27 21:45:00	13.17	151.15	0.31	7.72	9.26	9.60	0.07
EAS-DS	2026-06-27 22:00:00	13.04	165.88	0.30	7.86	9.86	10.23	0.08
EAS-DS	2026-06-27 22:15:00	13.05	167.14	0.30	7.86	9.89	10.61	0.08
EAS-DS	2026-06-27 22:30:00	13.07	167.73	0.30	7.86	9.83	11.36	0.08
EAS-DS	2026-06-27 22:45:00	13.08	168.43	0.30	7.86	9.87	10.38	0.08
EAS-DS	2026-06-27 23:00:00	13.15	168.63	0.30	7.84	9.66	12.18	0.08
EAS-DS	2026-06-27 23:15:00	13.16	167.73	0.30	7.87	9.85	10.68	0.08
EAS-DS	2026-06-27 23:30:00	12.92	164.10	0.31	7.86	9.81	9.85	0.08
EAS-DS	2026-06-27 23:45:00	12.85	164.99	0.31	7.84	9.86	10.64	0.08
EAS-DS	2026-06-28 00:00:00	12.95	166.56	0.31	7.83	9.74	11.01	0.08
EAS-DS	2026-06-28 00:15:00	12.86	163.06	0.31	7.76	9.48	10.13	0.08
EAS-DS	2026-06-28 00:30:00	13.09	168.83	0.31	7.84	9.70	11.70	0.08
EAS-DS	2026-06-28 00:45:00	13.04	167.76	0.30	7.83	9.72	9.89	0.08
EAS-DS	2026-06-28 01:00:00	13.02	168.96	0.31	7.83	9.72	10.65	0.08
EAS-DS	2026-06-28 01:15:00	12.68	164.69	0.30	7.84	9.97	15.73	0.08
EAS-DS	2026-06-28 01:30:00	12.77	168.82	0.30	7.85	9.91	11.36	0.08
EAS-DS	2026-06-28 01:45:00	12.73	167.38	0.31	7.82	9.93	10.04	0.08
EAS-DS	2026-06-28 02:00:00	12.72	161.87	0.31	7.71	9.48	9.74	0.08
EAS-DS	2026-06-28 02:15:00	12.60	167.99	0.31	7.84	9.99	10.45	0.08
EAS-DS	2026-06-28 02:30:00	12.73	170.29	0.31	7.82	9.78	10.01	0.08
EAS-DS	2026-06-28 02:45:00	12.76	161.04	0.31	7.73	9.34	9.76	0.08
EAS-DS	2026-06-28 03:00:00	12.50	163.55	0.30	7.86	9.99	10.15	0.08
EAS-DS	2026-06-28 03:15:00	12.46	162.22	0.30	7.84	10.01	10.37	0.08
EAS-DS	2026-06-28 03:30:00	12.56	171.83	0.30	7.84	10.02	13.84	0.08
EAS-DS	2026-06-28 03:45:00	12.51	166.65	0.31	7.84	10.04	10.14	0.08
EAS-DS	2026-06-28 04:00:00	12.53	165.85	0.31	7.84	9.89	10.47	0.08
EAS-DS	2026-06-28 04:15:00	12.53	161.12	0.31	7.75	9.47	9.65	0.08
EAS-DS	2026-06-28 04:30:00	12.59	146.64	0.32	7.77	9.68	16.16	0.07
EAS-DS	2026-06-28 04:45:00	12.63	173.81	0.32	7.85	9.97	10.35	0.08
EAS-DS	2026-06-28 05:00:00	12.52	167.55	0.31	7.85	9.98	11.59	0.08
EAS-DS	2026-06-28 05:15:00	12.57	172.55	0.31	7.85	10.01	11.09	0.08
EAS-DS	2026-06-28 05:30:00	12.79	177.29	0.31	7.83	9.77	10.13	0.08
EAS-DS	2026-06-28 05:45:00	12.62	158.10	0.31	7.78	9.72	11.02	0.07
EAS-DS	2026-06-28 06:00:00	12.52	169.55	0.31	7.84	10.03	10.73	0.08
EAS-DS	2026-06-28 06:15:00	12.61	171.07	0.31	7.86	10.02	11.72	0.08
EAS-DS	2026-06-28 06:30:00	12.56	166.62	0.30	7.85	9.98	10.72	0.08
EAS-DS	2026-06-28 06:45:00	12.66	169.78	0.31	7.83	9.97	15.76	0.08
EAS-DS	2026-06-28 07:00:00	12.58	165.41	0.30	7.85	9.92	10.02	0.08

Woodfibre LNG (East Creek)								
Station	Date/Time	Temperature (C)	Specific Conductivity (µS/cm)	ORP (V)	pH (pH units)	Dissolved Oxygen (mg/L)	Turbidity (NTU)	Salinity (PSU)
EAS-DS	2026-06-28 07:15:00	12.84	173.69	0.30	7.85	9.82	10.16	0.08
EAS-DS	2026-06-28 07:30:00	12.76	171.11	0.30	7.83	9.91	10.26	0.08
EAS-DS	2026-06-28 07:45:00	12.76	168.13	0.30	7.78	9.64	10.11	0.08
EAS-DS	2026-06-28 08:00:00	12.63	163.18	0.30	7.83	9.95	14.06	0.08
EAS-DS	2026-06-28 08:15:00	12.72	167.68	0.30	7.83	9.95	10.12	0.08
EAS-DS	2026-06-28 08:30:00	12.74	163.37	0.30	7.84	9.89	10.25	0.08
EAS-DS	2026-06-28 08:45:00	12.83	166.17	0.30	7.79	9.77	10.96	0.08
EAS-DS	2026-06-28 09:00:00	12.97	166.70	0.30	7.83	9.85	11.51	0.08
EAS-DS	2026-06-28 09:15:00	13.02	164.34	0.30	7.85	9.89	10.33	0.08
EAS-DS	2026-06-28 09:30:00	13.09	167.63	0.30	7.83	9.83	10.30	0.08
EAS-DS	2026-06-28 09:45:00	13.07	163.99	0.30	7.85	9.91	11.64	0.08
EAS-DS	2026-06-28 10:00:00	13.05	162.24	0.30	7.79	9.74	10.05	0.08
EAS-DS	2026-06-28 10:15:00	13.18	164.58	0.30	7.86	9.88	12.10	0.08
EAS-DS	2026-06-28 10:30:00	13.23	162.79	0.30	7.82	9.71	12.59	0.08
EAS-DS	2026-06-28 10:45:00	13.32	170.01	0.30	7.83	9.79	11.70	0.08
EAS-DS	2026-06-28 11:00:00	13.31	171.34	0.30	7.87	9.86	16.24	0.08
EAS-DS	2026-06-28 11:15:00	13.35	171.55	0.30	7.75	9.43	10.73	0.08
EAS-DS	2026-06-28 11:30:00	13.40	170.86	0.29	7.87	9.83	13.67	0.08
EAS-DS	2026-06-28 11:45:00	13.46	172.56	0.30	7.88	9.86	13.27	0.08
EAS-DS	2026-06-28 12:00:00	13.51	175.05	0.29	7.88	9.81	11.74	0.08
EAS-DS	2026-06-28 12:15:00	13.65	174.68	0.30	7.83	9.66	12.11	0.08
EAS-DS	2026-06-28 12:30:00	13.73	174.25	0.29	7.78	9.21	11.45	0.08
EAS-DS	2026-06-28 12:45:00	13.78	178.10	0.29	7.85	9.60	11.98	0.08
EAS-DS	2026-06-28 13:00:00	13.78	165.52	0.30	7.77	9.12	11.07	0.08
EAS-DS	2026-06-28 13:15:00	14.00	172.45	0.30	7.83	9.61	17.02	0.08
EAS-DS	2026-06-28 13:30:00	13.99	166.56	0.29	7.89	9.67	14.26	0.08
EAS-DS	2026-06-28 13:45:00	13.87	172.51	0.29	7.88	9.74	17.59	0.08
EAS-DS	2026-06-28 14:00:00	13.94	177.86	0.29	7.87	9.66	16.47	0.08
EAS-DS	2026-06-28 14:15:00	14.04	181.13	0.29	7.79	9.31	12.87	0.09
EAS-DS	2026-06-28 14:30:00	14.04	163.67	0.29	7.69	8.89	11.82	0.08
EAS-DS	2026-06-28 14:45:00	14.16	176.30	0.29	7.88	9.68	16.34	0.08
EAS-DS	2026-06-28 15:00:00	13.88	164.93	0.29	7.87	9.70	12.35	0.08
EAS-DS	2026-06-28 15:15:00	13.96	170.95	0.29	7.87	9.68	12.48	0.08
EAS-DS	2026-06-28 15:30:00	14.12	174.48	0.29	7.88	9.63	12.25	0.08
EAS-DS	2026-06-28 15:45:00	14.06	169.84	0.29	7.84	9.46	13.14	0.08
EAS-DS	2026-06-28 16:00:00	14.26	180.25	0.29	7.87	9.49	13.79	0.09
EAS-DS	2026-06-28 16:15:00	14.40	181.18	0.29	7.87	9.49	11.86	0.09
EAS-DS	2026-06-28 16:30:00	14.36	180.12	0.29	7.72	9.11	12.31	0.09
EAS-DS	2026-06-28 16:45:00	14.29	175.25	0.30	7.64	8.45	11.59	0.08
EAS-DS	2026-06-28 17:00:00	14.25	174.00	0.29	7.88	9.63	19.71	0.08
EAS-DS	2026-06-28 17:15:00	14.28	175.31	0.29	7.88	9.65	15.94	0.08
EAS-DS	2026-06-28 17:30:00	14.39	179.98	0.29	7.85	9.42	13.13	0.09
EAS-DS	2026-06-28 17:45:00	14.41	180.12	0.30	7.69	8.76	12.78	0.09
EAS-DS	2026-06-28 18:00:00	14.66	183.63	0.29	7.89	9.48	13.11	0.09
EAS-DS	2026-06-28 18:15:00	14.47	175.97	0.29	7.88	9.60	12.44	0.08
EAS-DS	2026-06-28 18:30:00	14.43	178.88	0.29	7.85	9.44	12.00	0.08
EAS-DS	2026-06-28 18:45:00	14.31	173.82	0.29	7.88	9.61	12.01	0.08
EAS-DS	2026-06-28 19:00:00	14.29	176.14	0.29	7.88	9.58	17.00	0.08
EAS-DS	2026-06-28 19:15:00	14.42	180.82	0.29	7.78	9.26	11.42	0.09
EAS-DS	2026-06-28 19:30:00	14.19	171.94	0.29	7.86	9.59	11.61	0.08
EAS-DS	2026-06-28 19:45:00	14.06	173.42	0.29	7.87	9.68	12.26	0.08
EAS-DS	2026-06-28 20:00:00	14.00	173.57	0.29	7.86	9.63	11.43	0.08
EAS-DS	2026-06-28 20:15:00	13.99	173.16	0.29	7.83	9.49	19.59	0.08
EAS-DS	2026-06-28 20:30:00	13.74	169.60	0.29	7.85	9.75	13.27	0.08
EAS-DS	2026-06-28 20:45:00	14.04	174.88	0.29	7.79	9.40	12.06	0.08

Woodfibre LNG (East Creek)								
Station	Date/Time	Temperature (C)	Specific Conductivity (µS/cm)	ORP (V)	pH (pH units)	Dissolved Oxygen (mg/L)	Turbidity (NTU)	Salinity (PSU)
EAS-DS	2026-06-28 21:00:00	13.97	165.10	0.30	7.66	8.77	15.24	0.08
EAS-DS	2026-06-28 21:15:00	13.91	165.63	0.29	7.86	9.65	12.55	0.08
EAS-DS	2026-06-28 21:30:00	13.88	169.26	0.30	7.70	9.01	11.07	0.08
EAS-DS	2026-06-28 21:45:00	13.71	161.51	0.31	7.72	9.27	11.18	0.08
EAS-DS	2026-06-28 22:00:00	13.56	171.60	0.30	7.85	9.69	20.37	0.08
EAS-DS	2026-06-28 22:15:00	13.49	162.84	0.30	7.81	9.52	13.95	0.08
EAS-DS	2026-06-28 22:30:00	13.50	174.76	0.30	7.86	9.77	15.35	0.08
EAS-DS	2026-06-28 22:45:00	13.43	174.86	0.29	7.86	9.85	15.86	0.08
EAS-DS	2026-06-28 23:00:00	13.40	175.97	0.29	7.86	9.82	15.95	0.08
EAS-DS	2026-06-28 23:15:00	13.36	173.79	0.29	7.85	9.82	13.38	0.08
EAS-DS	2026-06-28 23:30:00	13.29	166.29	0.29	7.72	9.29	12.04	0.08
EAS-DS	2026-06-28 23:45:00	13.56	176.75	0.29	7.80	9.65	15.00	0.08
EAS-US	2026-06-22 00:00:00	14.46	32.50	0.14	6.75	9.27	2.92	0.02
EAS-US	2026-06-22 00:15:00	14.42	32.46	0.22	6.93	9.32	2.97	0.02
EAS-US	2026-06-22 00:30:00	14.37	32.40	0.22	6.95	9.33	2.83	0.02
EAS-US	2026-06-22 00:45:00	14.34	32.36	0.22	6.98	9.34	2.81	0.02
EAS-US	2026-06-22 01:00:00	14.30	32.36	0.14	6.74	9.34	3.23	0.02
EAS-US	2026-06-22 01:15:00	14.26	32.34	0.22	6.77	9.35	2.76	0.02
EAS-US	2026-06-22 01:30:00	14.23	32.29	0.22	6.86	9.37	2.78	0.02
EAS-US	2026-06-22 01:45:00	14.19	32.25	0.22	6.78	9.35	2.78	0.02
EAS-US	2026-06-22 02:00:00	14.15	32.26	0.14	6.79	9.34	2.91	0.02
EAS-US	2026-06-22 02:15:00	14.12	32.23	0.22	6.93	9.34	2.80	0.02
EAS-US	2026-06-22 02:30:00	14.08	32.19	0.22	6.96	9.40	2.78	0.02
EAS-US	2026-06-22 02:45:00	14.03	32.17	0.22	6.93	9.42	2.78	0.02
EAS-US	2026-06-22 03:00:00	14.00	32.18	0.14	6.76	9.44	2.88	0.02
EAS-US	2026-06-22 03:15:00	13.96	32.14	0.22	6.82	9.40	2.80	0.02
EAS-US	2026-06-22 03:30:00	13.93	32.12	0.22	6.78	9.40	2.84	0.02
EAS-US	2026-06-22 03:45:00	13.90	32.07	0.22	6.77	9.43	2.85	0.02
EAS-US	2026-06-22 04:00:00	13.86	32.08	0.13	6.77	9.47	2.90	0.02
EAS-US	2026-06-22 04:15:00	13.83	32.05	0.23	6.93	9.45	2.85	0.02
EAS-US	2026-06-22 04:30:00	13.80	32.06	0.22	6.93	9.48	3.05	0.02
EAS-US	2026-06-22 04:45:00	13.76	32.04	0.22	6.97	9.49	2.83	0.02
EAS-US	2026-06-22 05:00:00	13.72	32.05	0.13	6.76	9.49	2.90	0.02
EAS-US	2026-06-22 05:15:00	13.69	32.00	0.22	6.85	9.48	2.81	0.02
EAS-US	2026-06-22 05:30:00	13.65	32.00	0.21	6.83	9.51	2.86	0.02
EAS-US	2026-06-22 05:45:00	13.62	31.96	0.22	6.84	9.52	2.86	0.02
EAS-US	2026-06-22 06:00:00	13.59	31.94	0.13	6.79	9.54	2.83	0.02
EAS-US	2026-06-22 06:15:00	13.56	31.86	0.22	7.01	9.56	2.77	0.02
EAS-US	2026-06-22 06:30:00	13.53	31.86	0.22	7.00	9.58	2.83	0.02
EAS-US	2026-06-22 06:45:00	13.51	31.82	0.22	6.98	9.61	2.84	0.02
EAS-US	2026-06-22 07:00:00	13.49	31.77	0.14	6.77	9.60	3.69	0.02
EAS-US	2026-06-22 07:15:00	13.48	31.75	0.22	6.86	9.61	2.75	0.02
EAS-US	2026-06-22 07:30:00	13.47	31.72	0.22	6.84	9.63	2.85	0.02
EAS-US	2026-06-22 07:45:00	13.47	31.72	0.22	6.84	9.60	2.81	0.02
EAS-US	2026-06-22 08:00:00	13.47	31.69	0.13	6.80	9.59	2.81	0.02
EAS-US	2026-06-22 08:15:00	13.47	31.64	0.22	6.95	9.66	2.84	0.02
EAS-US	2026-06-22 08:30:00	13.49	31.66	0.22	7.00	9.65	2.87	0.02
EAS-US	2026-06-22 08:45:00	13.52	31.64	0.22	6.99	9.68	2.87	0.02
EAS-US	2026-06-22 09:00:00	13.57	31.61	0.14	6.77	9.69	2.90	0.02
EAS-US	2026-06-22 09:15:00	13.64	31.52	0.21	6.85	9.70	2.81	0.02
EAS-US	2026-06-22 09:30:00	13.71	31.44	0.22	6.85	9.70	2.86	0.02
EAS-US	2026-06-22 09:45:00	13.78	31.47	0.22	6.86	9.71	2.84	0.02
EAS-US	2026-06-22 10:00:00	13.82	31.57	0.13	6.83	9.68	2.87	0.02
EAS-US	2026-06-22 10:15:00	13.86	31.59	0.22	7.01	9.70	2.84	0.02
EAS-US	2026-06-22 10:30:00	13.95	31.56	0.22	7.05	9.74	2.93	0.02

Woodfibre LNG (East Creek)								
Station	Date/Time	Temperature (C)	Specific Conductivity (µS/cm)	ORP (V)	pH (pH units)	Dissolved Oxygen (mg/L)	Turbidity (NTU)	Salinity (PSU)
EAS-US	2026-06-22 10:45:00	14.11	31.55	0.22	7.08	9.76	3.05	0.02
EAS-US	2026-06-22 11:00:00	14.36	31.57	0.15	6.83	9.77	2.82	0.02
EAS-US	2026-06-22 11:15:00	14.59	31.48	0.22	6.91	9.80	2.83	0.02
EAS-US	2026-06-22 11:30:00	14.85	31.38	0.22	6.96	9.78	2.84	0.02
EAS-US	2026-06-22 11:45:00	15.14	31.42	0.22	6.95	9.76	2.96	0.02
EAS-US	2026-06-22 12:00:00	15.49	31.31	0.14	6.94	9.74	2.98	0.02
EAS-US	2026-06-22 12:15:00	15.70	31.26	0.21	7.14	9.68	3.02	0.02
EAS-US	2026-06-22 12:30:00	15.72	31.26	0.22	7.11	9.61	2.99	0.02
EAS-US	2026-06-22 12:45:00	15.70	31.29	0.21	7.11	9.58	2.95	0.02
EAS-US	2026-06-22 13:00:00	15.74	31.42	0.14	6.90	9.52	2.97	0.02
EAS-US	2026-06-22 13:15:00	15.75	31.41	0.22	6.94	9.43	2.89	0.02
EAS-US	2026-06-22 13:30:00	15.81	31.34	0.22	6.95	9.33	2.94	0.02
EAS-US	2026-06-22 13:45:00	15.96	31.36	0.22	6.90	9.30	2.94	0.02
EAS-US	2026-06-22 14:00:00	16.09	31.44	0.14	6.90	9.27	2.92	0.02
EAS-US	2026-06-22 14:15:00	16.20	31.39	0.22	7.10	9.24	3.00	0.02
EAS-US	2026-06-22 14:30:00	16.38	31.36	0.22	7.11	9.22	2.99	0.02
EAS-US	2026-06-22 14:45:00	16.46	30.37	0.23	7.16	9.21	2.95	0.01
EAS-US	2026-06-22 15:00:00	16.59	31.33	0.10	6.95	9.15	10.20	0.02
EAS-US	2026-06-22 15:15:00	16.67	31.31	0.23	7.11	9.15	2.95	0.02
EAS-US	2026-06-22 15:30:00	16.76	31.26	0.23	7.14	9.15	2.93	0.02
EAS-US	2026-06-22 15:45:00	16.80	31.33	0.24	7.12	9.12	2.94	0.02
EAS-US	2026-06-22 16:00:00	16.84	31.60	0.15	6.84	9.10	3.09	0.02
EAS-US	2026-06-22 16:15:00	16.84	31.52	0.22	7.07	9.10	2.92	0.02
EAS-US	2026-06-22 16:30:00	16.87	31.57	0.22	7.06	9.09	2.93	0.02
EAS-US	2026-06-22 16:45:00	16.90	31.68	0.22	7.02	9.07	3.33	0.02
EAS-US	2026-06-22 17:00:00	16.89	31.81	0.15	6.81	9.01	3.33	0.02
EAS-US	2026-06-22 17:15:00	16.87	31.94	0.22	6.89	8.98	3.07	0.02
EAS-US	2026-06-22 17:30:00	16.81	32.09	0.22	6.86	8.98	2.97	0.02
EAS-US	2026-06-22 17:45:00	16.71	32.30	0.22	6.85	8.93	2.96	0.02
EAS-US	2026-06-22 18:00:00	16.62	32.40	0.15	6.80	8.93	3.07	0.02
EAS-US	2026-06-22 18:15:00	16.54	32.52	0.22	7.00	8.92	3.01	0.02
EAS-US	2026-06-22 18:30:00	16.46	32.60	0.22	6.97	8.91	3.04	0.02
EAS-US	2026-06-22 18:45:00	16.38	32.70	0.22	6.96	8.91	3.04	0.02
EAS-US	2026-06-22 19:00:00	16.31	32.74	0.15	6.75	8.92	4.58	0.02
EAS-US	2026-06-22 19:15:00	16.24	32.81	0.22	6.83	8.94	3.26	0.02
EAS-US	2026-06-22 19:30:00	16.17	32.82	0.22	6.84	8.94	3.03	0.02
EAS-US	2026-06-22 19:45:00	16.10	32.86	0.23	6.79	8.95	3.13	0.02
EAS-US	2026-06-22 20:00:00	16.03	32.88	0.15	6.78	8.96	19.90	0.02
EAS-US	2026-06-22 20:15:00	15.98	32.88	0.23	6.95	8.97	3.02	0.02
EAS-US	2026-06-22 20:30:00	15.92	32.92	0.22	7.00	8.97	3.03	0.02
EAS-US	2026-06-22 20:45:00	15.86	32.96	0.22	6.96	8.98	3.08	0.02
EAS-US	2026-06-22 21:00:00	15.80	33.02	0.15	6.76	9.00	8.72	0.02
EAS-US	2026-06-22 21:15:00	15.74	33.00	0.23	6.84	8.99	2.95	0.02
EAS-US	2026-06-22 21:30:00	15.69	33.01	0.23	6.82	8.99	2.86	0.02
EAS-US	2026-06-22 21:45:00	15.63	33.09	0.23	6.81	9.00	2.77	0.02
EAS-US	2026-06-22 22:00:00	15.58	33.23	0.15	6.75	8.99	2.97	0.02
EAS-US	2026-06-22 22:15:00	15.52	33.00	0.23	6.94	9.02	3.07	0.02
EAS-US	2026-06-22 22:30:00	15.47	32.94	0.22	6.99	9.01	3.55	0.02
EAS-US	2026-06-22 22:45:00	15.42	32.95	0.23	7.04	9.06	51.62	0.02
EAS-US	2026-06-22 23:00:00	15.37	32.15	0.16	6.89	9.06	3.62	0.02
EAS-US	2026-06-22 23:15:00	15.34	32.09	0.20	7.06	9.07	3.11	0.02
EAS-US	2026-06-22 23:30:00	15.29	32.10	0.20	7.04	9.10	3.21	0.02
EAS-US	2026-06-22 23:45:00	15.24	32.10	0.21	7.03	9.10	3.15	0.02
EAS-US	2026-06-23 00:00:00	15.19	32.80	0.17	6.89	9.12	3.30	0.02
EAS-US	2026-06-23 00:15:00	15.14	32.70	0.21	7.05	9.12	3.20	0.02

Woodfibre LNG (East Creek)								
Station	Date/Time	Temperature (C)	Specific Conductivity (µS/cm)	ORP (V)	pH (pH units)	Dissolved Oxygen (mg/L)	Turbidity (NTU)	Salinity (PSU)
EAS-US	2026-06-23 00:30:00	15.09	32.69	0.21	7.05	9.15	3.19	0.02
EAS-US	2026-06-23 00:45:00	15.04	32.71	0.21	7.06	9.16	3.11	0.02
EAS-US	2026-06-23 01:00:00	14.98	33.01	0.14	6.84	9.16	3.10	0.02
EAS-US	2026-06-23 01:15:00	14.94	33.15	0.23	7.02	9.17	2.97	0.02
EAS-US	2026-06-23 01:30:00	14.89	33.07	0.24	7.00	9.18	2.99	0.02
EAS-US	2026-06-23 01:45:00	14.85	33.03	0.24	7.01	9.21	3.02	0.02
EAS-US	2026-06-23 02:00:00	14.80	32.60	0.08	6.86	9.20	3.11	0.02
EAS-US	2026-06-23 02:15:00	14.76	32.57	0.22	7.05	9.23	3.18	0.02
EAS-US	2026-06-23 02:30:00	14.72	32.53	0.22	7.05	9.24	3.09	0.02
EAS-US	2026-06-23 02:45:00	14.68	32.49	0.22	7.06	9.26	3.46	0.02
EAS-US	2026-06-23 03:00:00	14.63	32.69	0.16	6.77	9.24	7.34	0.02
EAS-US	2026-06-23 03:15:00	14.59	32.59	0.22	6.80	9.26	2.94	0.02
EAS-US	2026-06-23 03:30:00	14.55	32.55	0.22	6.83	9.26	2.96	0.02
EAS-US	2026-06-23 03:45:00	14.51	32.53	0.22	6.84	9.29	9.19	0.02
EAS-US	2026-06-23 04:00:00	14.47	32.54	0.15	6.89	9.27	12.91	0.02
EAS-US	2026-06-23 04:15:00	14.43	32.50	0.21	7.04	9.32	3.24	0.02
EAS-US	2026-06-23 04:30:00	14.40	32.46	0.21	7.00	9.32	3.25	0.02
EAS-US	2026-06-23 04:45:00	14.37	32.43	0.21	7.03	9.34	3.31	0.02
EAS-US	2026-06-23 05:00:00	14.33	32.47	0.15	6.78	9.34	5.92	0.02
EAS-US	2026-06-23 05:15:00	14.30	32.40	0.21	6.81	9.33	2.88	0.02
EAS-US	2026-06-23 05:30:00	14.27	32.40	0.21	6.81	9.33	2.97	0.02
EAS-US	2026-06-23 05:45:00	14.25	32.52	0.21	6.82	9.34	3.09	0.02
EAS-US	2026-06-23 06:00:00	14.24	32.11	0.10	6.85	9.40	5.59	0.02
EAS-US	2026-06-23 06:15:00	14.23	32.17	0.23	7.05	9.42	14.39	0.02
EAS-US	2026-06-23 06:30:00	14.23	32.14	0.24	7.03	9.40	3.98	0.02
EAS-US	2026-06-23 06:45:00	14.22	32.06	0.21	7.03	9.43	3.30	0.02
EAS-US	2026-06-23 07:00:00	14.20	32.16	0.11	6.83	9.42	7.31	0.02
EAS-US	2026-06-23 07:15:00	14.19	31.99	0.21	7.05	9.44	3.04	0.02
EAS-US	2026-06-23 07:30:00	14.17	32.25	0.23	6.99	9.46	3.02	0.02
EAS-US	2026-06-23 07:45:00	14.17	31.94	0.23	6.92	9.45	3.05	0.02
EAS-US	2026-06-23 08:00:00	14.16	32.42	0.14	6.73	9.46	32.71	0.01
EAS-US	2026-06-23 08:15:00	14.17	30.45	0.24	7.03	9.49	3.56	0.01
EAS-US	2026-06-23 08:30:00	14.18	30.46	0.25	7.02	9.49	3.44	0.01
EAS-US	2026-06-23 08:45:00	14.20	30.55	0.25	7.02	9.51	3.37	0.01
EAS-US	2026-06-23 09:00:00	14.24	30.88	0.12	6.89	9.51	5.14	0.02
EAS-US	2026-06-23 09:15:00	14.29	30.69	0.22	7.07	9.56	2.98	0.01
EAS-US	2026-06-23 09:30:00	14.35	30.60	0.23	7.08	9.58	3.00	0.01
EAS-US	2026-06-23 09:45:00	14.45	30.47	0.24	7.10	9.62	2.96	0.01
EAS-US	2026-06-23 10:00:00	14.52	32.12	0.09	6.87	9.56	4.23	0.02
EAS-US	2026-06-23 10:15:00	14.56	32.14	0.21	7.03	9.57	3.45	0.02
EAS-US	2026-06-23 10:30:00	14.62	34.41	0.21	7.08	9.59	3.47	0.02
EAS-US	2026-06-23 10:45:00	14.75	31.97	0.21	7.10	9.68	3.45	0.02
EAS-US	2026-06-23 11:00:00	14.97	32.41	0.15	6.82	9.67	3.95	0.02
EAS-US	2026-06-23 11:15:00	15.16	31.87	0.21	6.88	9.74	3.14	0.02
EAS-US	2026-06-23 11:30:00	15.38	31.88	0.22	6.88	9.81	3.24	0.02
EAS-US	2026-06-23 11:45:00	15.70	31.74	0.22	6.90	9.82	3.13	0.02
EAS-US	2026-06-23 12:00:00	16.01	31.65	0.14	6.92	9.77	3.78	0.02
EAS-US	2026-06-23 12:15:00	16.14	31.99	0.21	7.15	9.61	4.22	0.02
EAS-US	2026-06-23 12:30:00	16.26	32.27	0.21	7.15	9.69	3.24	0.02
EAS-US	2026-06-23 12:45:00	16.31	32.15	0.21	6.92	9.55	3.21	0.02
EAS-US	2026-06-23 13:00:00	16.41	32.22	0.14	6.73	9.53	3.90	0.02
EAS-US	2026-06-23 13:15:00	16.44	33.12	0.21	6.64	9.22	3.18	0.02
EAS-US	2026-06-23 13:30:00	16.42	31.82	0.21	6.59	9.44	3.25	0.02
EAS-US	2026-06-23 13:45:00	16.46	31.89	0.21	6.75	9.30	3.19	0.02
EAS-US	2026-06-23 14:00:00	16.62	31.99	0.14	6.86	9.22	3.25	0.02

Woodfibre LNG (East Creek)								
Station	Date/Time	Temperature (C)	Specific Conductivity (µS/cm)	ORP (V)	pH (pH units)	Dissolved Oxygen (mg/L)	Turbidity (NTU)	Salinity (PSU)
EAS-US	2026-06-23 14:15:00	16.73	31.96	0.21	7.00	9.22	3.16	0.02
EAS-US	2026-06-23 14:30:00	16.83	32.23	0.21	6.91	9.17	3.19	0.02
EAS-US	2026-06-23 14:45:00	16.92	32.18	0.21	7.02	9.15	3.25	0.02
EAS-US	2026-06-23 15:00:00	17.02	32.22	0.14	6.84	9.08	8.35	0.02
EAS-US	2026-06-23 15:15:00	17.10	32.02	0.21	6.91	9.08	3.20	0.02
EAS-US	2026-06-23 15:30:00	17.20	32.09	0.21	6.83	9.13	3.23	0.02
EAS-US	2026-06-23 15:45:00	17.23	32.13	0.21	6.83	9.05	3.09	0.02
EAS-US	2026-06-23 16:00:00	17.29	32.18	0.14	6.75	9.22	3.28	0.02
EAS-US	2026-06-23 16:15:00	17.31	32.25	0.21	6.92	9.27	3.31	0.02
EAS-US	2026-06-23 16:30:00	17.31	32.59	0.21	6.78	9.03	3.30	0.02
EAS-US	2026-06-23 16:45:00	17.32	32.69	0.21	6.75	8.80	3.26	0.02
EAS-US	2026-06-23 17:00:00	17.33	32.64	0.14	6.61	8.71	3.28	0.02
EAS-US	2026-06-23 17:15:00	17.31	32.84	0.21	6.59	8.68	3.23	0.02
EAS-US	2026-06-23 17:30:00	17.29	33.11	0.21	6.68	8.70	3.40	0.02
EAS-US	2026-06-23 17:45:00	17.23	33.58	0.22	6.77	8.17	3.45	0.02
EAS-US	2026-06-23 18:00:00	17.15	33.07	0.14	6.70	8.58	3.46	0.02
EAS-US	2026-06-23 18:15:00	17.10	33.63	0.22	6.95	8.60	3.32	0.02
EAS-US	2026-06-23 18:30:00	17.03	33.77	0.21	6.97	8.66	3.29	0.02
EAS-US	2026-06-23 18:45:00	16.96	33.62	0.21	6.98	8.67	3.27	0.02
EAS-US	2026-06-23 19:00:00	16.88	33.46	0.14	6.72	8.62	3.22	0.02
EAS-US	2026-06-23 19:15:00	16.82	33.66	0.22	6.81	8.68	3.25	0.02
EAS-US	2026-06-23 19:30:00	16.75	33.41	0.22	6.77	8.76	3.25	0.02
EAS-US	2026-06-23 19:45:00	16.68	33.65	0.22	6.71	8.76	3.21	0.02
EAS-US	2026-06-23 20:00:00	16.59	33.50	0.14	6.69	8.81	3.90	0.02
EAS-US	2026-06-23 20:15:00	16.54	33.52	0.22	6.94	8.83	3.17	0.02
EAS-US	2026-06-23 20:30:00	16.47	33.56	0.21	6.94	8.83	3.19	0.02
EAS-US	2026-06-23 20:45:00	16.42	33.52	0.21	7.00	8.82	3.18	0.02
EAS-US	2026-06-23 21:00:00	16.36	33.68	0.14	6.69	8.82	3.26	0.02
EAS-US	2026-06-23 21:15:00	16.31	33.65	0.22	6.70	8.83	3.20	0.02
EAS-US	2026-06-23 21:30:00	16.25	33.61	0.22	6.69	8.82	3.29	0.02
EAS-US	2026-06-23 21:45:00	16.20	33.66	0.22	6.61	8.78	3.20	0.02
EAS-US	2026-06-23 22:00:00	16.14	33.57	0.14	6.70	8.85	3.31	0.02
EAS-US	2026-06-23 22:15:00	16.10	33.59	0.21	6.92	8.85	3.21	0.02
EAS-US	2026-06-23 22:30:00	16.04	33.58	0.21	6.95	8.88	3.19	0.02
EAS-US	2026-06-23 22:45:00	15.99	33.48	0.21	6.96	8.87	3.22	0.02
EAS-US	2026-06-23 23:00:00	15.94	33.58	0.15	6.68	8.89	3.35	0.02
EAS-US	2026-06-23 23:15:00	15.91	33.57	0.21	6.68	8.83	3.27	0.02
EAS-US	2026-06-23 23:30:00	15.85	33.65	0.22	6.64	8.88	3.23	0.02
EAS-US	2026-06-23 23:45:00	15.80	33.34	0.21	6.72	8.91	3.50	0.02
EAS-US	2026-06-24 00:00:00	15.74	33.37	0.14	6.70	8.93	5.20	0.02
EAS-US	2026-06-24 00:15:00	15.70	33.25	0.22	6.93	8.92	3.27	0.02
EAS-US	2026-06-24 00:30:00	15.66	33.25	0.21	6.95	8.94	3.28	0.02
EAS-US	2026-06-24 00:45:00	15.60	33.25	0.21	6.98	8.95	3.31	0.02
EAS-US	2026-06-24 01:00:00	15.55	33.37	0.14	6.70	8.92	3.65	0.02
EAS-US	2026-06-24 01:15:00	15.51	33.23	0.22	6.65	8.98	3.28	0.02
EAS-US	2026-06-24 01:30:00	15.46	33.18	0.22	6.77	9.02	3.26	0.02
EAS-US	2026-06-24 01:45:00	15.42	33.16	0.22	6.71	9.03	3.26	0.02
EAS-US	2026-06-24 02:00:00	15.37	33.19	0.14	6.71	9.02	4.89	0.02
EAS-US	2026-06-24 02:15:00	15.33	33.07	0.22	7.00	9.04	3.22	0.02
EAS-US	2026-06-24 02:30:00	15.29	33.03	0.21	6.98	9.06	3.24	0.02
EAS-US	2026-06-24 02:45:00	15.24	33.00	0.21	6.98	9.06	3.28	0.02
EAS-US	2026-06-24 03:00:00	15.19	33.09	0.14	6.71	9.08	4.04	0.02
EAS-US	2026-06-24 03:15:00	15.15	32.98	0.21	6.74	9.09	3.13	0.02
EAS-US	2026-06-24 03:30:00	15.11	32.96	0.22	6.72	9.11	3.17	0.02
EAS-US	2026-06-24 03:45:00	15.06	32.97	0.22	6.77	9.12	3.23	0.02

Woodfibre LNG (East Creek)								
Station	Date/Time	Temperature (C)	Specific Conductivity (µS/cm)	ORP (V)	pH (pH units)	Dissolved Oxygen (mg/L)	Turbidity (NTU)	Salinity (PSU)
EAS-US	2026-06-24 04:00:00	15.02	33.03	0.13	6.71	9.13	9.10	0.02
EAS-US	2026-06-24 04:15:00	14.98	32.90	0.22	6.99	9.13	3.16	0.02
EAS-US	2026-06-24 04:30:00	14.94	32.95	0.22	6.94	9.12	126.29	0.02
EAS-US	2026-06-24 04:45:00	14.93	33.05	0.22	6.96	9.08	5.86	0.02
EAS-US	2026-06-24 05:00:00	14.90	33.07	0.14	6.68	9.11	4.41	0.02
EAS-US	2026-06-24 05:15:00	14.87	33.09	0.22	6.66	9.00	3.24	0.02
EAS-US	2026-06-24 05:30:00	14.83	32.95	0.22	6.67	9.16	3.15	0.02
EAS-US	2026-06-24 05:45:00	14.80	32.93	0.22	6.69	9.16	3.16	0.02
EAS-US	2026-06-24 06:00:00	14.77	32.85	0.13	6.68	9.18	4.14	0.02
EAS-US	2026-06-24 06:15:00	14.75	32.79	0.22	6.92	9.20	3.08	0.02
EAS-US	2026-06-24 06:30:00	14.73	32.74	0.22	6.92	9.27	3.10	0.02
EAS-US	2026-06-24 06:45:00	14.72	32.72	0.22	6.93	9.26	3.05	0.02
EAS-US	2026-06-24 07:00:00	14.71	32.54	0.08	6.78	9.26	3.47	0.02
EAS-US	2026-06-24 07:15:00	14.71	32.68	0.21	6.91	9.29	3.22	0.02
EAS-US	2026-06-24 07:30:00	14.70	32.71	0.21	6.88	9.30	3.27	0.02
EAS-US	2026-06-24 07:45:00	14.70	32.65	0.21	6.95	9.32	3.38	0.02
EAS-US	2026-06-24 08:00:00	14.71	32.56	0.14	6.70	9.33	5.69	0.02
EAS-US	2026-06-24 08:15:00	14.74	32.50	0.22	6.90	9.30	3.08	0.02
EAS-US	2026-06-24 08:30:00	14.77	32.50	0.22	6.88	9.29	3.05	0.02
EAS-US	2026-06-24 08:45:00	14.80	32.49	0.22	6.89	9.32	3.11	0.02
EAS-US	2026-06-24 09:00:00	14.83	32.43	0.14	6.65	9.38	6.20	0.02
EAS-US	2026-06-24 09:15:00	14.86	32.47	0.22	6.66	9.39	3.07	0.02
EAS-US	2026-06-24 09:30:00	14.91	32.71	0.22	6.71	9.34	6.98	0.02
EAS-US	2026-06-24 09:45:00	14.99	32.84	0.22	6.72	9.28	27.11	0.02
EAS-US	2026-06-24 10:00:00	15.04	32.67	0.14	6.73	9.13	14.17	0.02
EAS-US	2026-06-24 10:15:00	15.07	32.67	0.22	6.79	9.25	5.90	0.02
EAS-US	2026-06-24 10:30:00	15.11	32.85	0.21	6.84	9.12	3.80	0.02
EAS-US	2026-06-24 10:45:00	15.23	33.00	0.21	6.88	9.17	3.31	0.02
EAS-US	2026-06-24 11:00:00	15.40	32.73	0.14	6.67	9.25	6.25	0.02
EAS-US	2026-06-24 11:15:00	15.57	32.65	0.21	6.74	9.41	3.38	0.02
EAS-US	2026-06-24 11:30:00	15.70	32.65	0.22	6.86	9.29	3.47	0.02
EAS-US	2026-06-24 11:45:00	15.90	32.34	0.22	6.85	9.54	3.37	0.02
EAS-US	2026-06-24 12:00:00	16.14	32.33	0.14	6.92	9.60	3.40	0.02
EAS-US	2026-06-24 12:15:00	16.36	32.30	0.21	7.07	9.76	3.35	0.02
EAS-US	2026-06-24 12:30:00	16.38	32.40	0.21	6.98	9.11	3.36	0.02
EAS-US	2026-06-24 12:45:00	16.30	31.92	0.21	7.13	9.27	3.41	0.02
EAS-US	2026-06-24 13:00:00	16.33	32.28	0.14	6.70	9.02	3.68	0.02
EAS-US	2026-06-24 13:15:00	16.39	32.15	0.21	6.86	9.19	3.30	0.02
EAS-US	2026-06-24 13:30:00	16.44	32.11	0.22	6.84	9.04	3.23	0.02
EAS-US	2026-06-24 13:45:00	16.52	32.06	0.22	6.89	9.12	3.26	0.02
EAS-US	2026-06-24 14:00:00	16.60	32.13	0.14	6.85	9.11	3.66	0.02
EAS-US	2026-06-24 14:15:00	16.66	32.18	0.21	7.11	9.02	3.33	0.02
EAS-US	2026-06-24 14:30:00	16.75	32.28	0.21	6.92	8.97	3.28	0.02
EAS-US	2026-06-24 14:45:00	16.90	32.36	0.21	6.96	8.95	3.38	0.02
EAS-US	2026-06-24 15:00:00	17.04	32.57	0.14	6.65	8.86	3.83	0.02
EAS-US	2026-06-24 15:15:00	17.16	32.56	0.22	6.70	8.86	3.33	0.02
EAS-US	2026-06-24 15:30:00	17.29	32.67	0.22	6.65	8.90	3.29	0.02
EAS-US	2026-06-24 15:45:00	17.40	32.59	0.22	6.67	8.86	3.35	0.02
EAS-US	2026-06-24 16:00:00	17.49	32.46	0.14	6.77	8.82	4.05	0.02
EAS-US	2026-06-24 16:15:00	17.54	32.49	0.21	7.09	8.82	3.37	0.02
EAS-US	2026-06-24 16:30:00	17.55	32.57	0.21	7.09	8.83	3.38	0.02
EAS-US	2026-06-24 16:45:00	17.58	32.56	0.21	7.10	8.83	3.34	0.02
EAS-US	2026-06-24 17:00:00	17.61	32.63	0.14	6.80	8.76	33.46	0.02
EAS-US	2026-06-24 17:15:00	17.62	32.59	0.22	6.82	8.75	3.34	0.02
EAS-US	2026-06-24 17:30:00	17.56	32.68	0.21	6.79	8.53	3.27	0.02

Woodfibre LNG (East Creek)								
Station	Date/Time	Temperature (C)	Specific Conductivity (µS/cm)	ORP (V)	pH (pH units)	Dissolved Oxygen (mg/L)	Turbidity (NTU)	Salinity (PSU)
EAS-US	2026-06-24 17:45:00	17.47	32.81	0.21	6.88	8.66	3.29	0.02
EAS-US	2026-06-24 18:00:00	17.38	33.07	0.14	6.80	8.64	3.47	0.02
EAS-US	2026-06-24 18:15:00	17.31	33.16	0.21	7.04	8.60	3.33	0.02
EAS-US	2026-06-24 18:30:00	17.23	33.25	0.21	7.04	8.60	3.32	0.02
EAS-US	2026-06-24 18:45:00	17.15	33.32	0.21	7.04	8.61	3.40	0.02
EAS-US	2026-06-24 19:00:00	17.07	33.50	0.13	6.76	8.61	3.34	0.02
EAS-US	2026-06-24 19:15:00	16.99	33.41	0.21	6.83	8.62	3.25	0.02
EAS-US	2026-06-24 19:30:00	16.91	33.49	0.22	6.78	8.65	3.28	0.02
EAS-US	2026-06-24 19:45:00	16.83	33.53	0.22	6.85	8.66	3.25	0.02
EAS-US	2026-06-24 20:00:00	16.76	33.65	0.14	6.75	8.67	3.45	0.02
EAS-US	2026-06-24 20:15:00	16.70	33.60	0.21	7.01	8.67	3.32	0.02
EAS-US	2026-06-24 20:30:00	16.63	33.64	0.21	7.00	8.68	3.30	0.02
EAS-US	2026-06-24 20:45:00	16.56	33.68	0.21	7.00	8.69	3.28	0.02
EAS-US	2026-06-24 21:00:00	16.50	33.82	0.14	6.73	8.68	4.97	0.02
EAS-US	2026-06-24 21:15:00	16.44	33.73	0.22	6.82	8.72	3.28	0.02
EAS-US	2026-06-24 21:30:00	16.37	33.74	0.22	6.81	8.72	3.20	0.02
EAS-US	2026-06-24 21:45:00	16.31	33.73	0.22	6.81	8.73	40.56	0.02
EAS-US	2026-06-24 22:00:00	16.25	33.76	0.13	6.73	8.76	3.64	0.02
EAS-US	2026-06-24 22:15:00	16.20	33.69	0.21	7.00	8.75	3.28	0.02
EAS-US	2026-06-24 22:30:00	16.14	33.70	0.21	7.00	8.76	3.30	0.02
EAS-US	2026-06-24 22:45:00	16.08	33.67	0.21	7.00	8.76	3.19	0.02
EAS-US	2026-06-24 23:00:00	16.03	33.76	0.14	6.72	8.78	3.87	0.02
EAS-US	2026-06-24 23:15:00	15.98	33.62	0.22	6.77	8.81	3.19	0.02
EAS-US	2026-06-24 23:30:00	15.93	33.56	0.22	6.79	8.81	3.23	0.02
EAS-US	2026-06-24 23:45:00	15.88	33.52	0.22	6.85	8.83	3.65	0.02
EAS-US	2026-06-25 00:00:00	15.82	33.53	0.14	6.74	8.86	10.23	0.02
EAS-US	2026-06-25 00:15:00	15.77	33.42	0.22	7.00	8.86	3.35	0.02
EAS-US	2026-06-25 00:30:00	15.73	33.40	0.21	7.01	8.86	3.23	0.02
EAS-US	2026-06-25 00:45:00	15.68	33.37	0.21	7.00	8.85	3.31	0.02
EAS-US	2026-06-25 01:00:00	15.63	33.40	0.14	6.73	8.87	8.29	0.02
EAS-US	2026-06-25 01:15:00	15.59	33.26	0.22	6.79	8.90	3.21	0.02
EAS-US	2026-06-25 01:30:00	15.54	33.22	0.22	6.80	8.93	3.17	0.02
EAS-US	2026-06-25 01:45:00	15.50	33.22	0.22	6.78	8.94	3.17	0.02
EAS-US	2026-06-25 02:00:00	15.46	33.21	0.13	6.75	8.95	3.90	0.02
EAS-US	2026-06-25 02:15:00	15.41	33.17	0.21	7.01	8.92	3.26	0.02
EAS-US	2026-06-25 02:30:00	15.36	33.18	0.21	6.99	8.89	3.27	0.02
EAS-US	2026-06-25 02:45:00	15.32	34.09	0.21	6.95	8.62	3.24	0.02
EAS-US	2026-06-25 03:00:00	15.28	33.34	0.13	6.71	7.95	11.70	0.02
EAS-US	2026-06-25 03:15:00	15.24	33.08	0.22	6.77	8.90	3.69	0.02
EAS-US	2026-06-25 03:30:00	15.21	33.00	0.22	6.83	8.96	3.26	0.02
EAS-US	2026-06-25 03:45:00	15.17	33.15	0.22	6.79	8.85	3.18	0.02
EAS-US	2026-06-25 04:00:00	15.13	33.01	0.13	6.76	8.94	3.57	0.02
EAS-US	2026-06-25 04:15:00	15.09	32.95	0.22	7.00	9.02	3.35	0.02
EAS-US	2026-06-25 04:30:00	15.05	32.92	0.22	7.01	9.02	3.24	0.02
EAS-US	2026-06-25 04:45:00	15.02	33.30	0.21	7.00	8.97	3.25	0.02
EAS-US	2026-06-25 05:00:00	14.99	33.02	0.14	6.71	8.93	3.83	0.02
EAS-US	2026-06-25 05:15:00	14.96	33.19	0.22	6.74	8.76	3.30	0.02
EAS-US	2026-06-25 05:30:00	14.93	33.08	0.22	6.79	8.82	3.21	0.02
EAS-US	2026-06-25 05:45:00	14.90	33.00	0.22	6.77	8.31	3.23	0.02
EAS-US	2026-06-25 06:00:00	14.88	32.81	0.13	6.75	8.59	3.65	0.02
EAS-US	2026-06-25 06:15:00	14.86	33.03	0.22	7.01	8.17	4.07	0.02
EAS-US	2026-06-25 06:30:00	14.84	32.72	0.21	7.02	8.10	3.18	0.02
EAS-US	2026-06-25 06:45:00	14.83	32.72	0.21	7.03	8.43	3.70	0.02
EAS-US	2026-06-25 07:00:00	14.83	32.72	0.14	6.76	8.38	3.59	0.02
EAS-US	2026-06-25 07:15:00	14.84	32.59	0.22	6.73	8.34	3.21	0.02

Woodfibre LNG (East Creek)								
Station	Date/Time	Temperature (C)	Specific Conductivity (µS/cm)	ORP (V)	pH (pH units)	Dissolved Oxygen (mg/L)	Turbidity (NTU)	Salinity (PSU)
EAS-US	2026-06-25 07:30:00	14.85	32.63	0.22	6.86	8.40	3.12	0.02
EAS-US	2026-06-25 07:45:00	14.86	32.48	0.22	6.86	7.78	3.21	0.02
EAS-US	2026-06-25 08:00:00	14.87	32.46	0.14	6.79	7.91	3.28	0.02
EAS-US	2026-06-25 08:15:00	14.89	32.78	0.21	7.04	8.12	3.28	0.02
EAS-US	2026-06-25 08:30:00	14.91	33.15	0.21	7.05	8.09	3.27	0.02
EAS-US	2026-06-25 08:45:00	14.92	32.71	0.21	7.05	7.83	3.28	0.02
EAS-US	2026-06-25 09:00:00	14.94	32.35	0.14	6.80	7.39	3.33	0.02
EAS-US	2026-06-25 09:15:00	14.97	32.53	0.22	6.90	7.62	3.12	0.02
EAS-US	2026-06-25 09:30:00	15.00	33.03	0.21	6.81	7.88	3.22	0.02
EAS-US	2026-06-25 09:45:00	15.03	33.04	0.22	6.77	9.04	3.23	0.02
EAS-US	2026-06-25 10:00:00	15.08	32.25	0.13	6.74	7.80	3.45	0.02
EAS-US	2026-06-25 10:15:00	15.10	32.73	0.21	6.98	7.32	3.30	0.02
EAS-US	2026-06-25 10:30:00	15.13	32.75	0.21	7.01	7.28	3.30	0.02
EAS-US	2026-06-25 10:45:00	15.18	32.45	0.21	7.04	8.33	3.32	0.02
EAS-US	2026-06-25 11:00:00	15.25	32.19	0.14	6.75	8.95	3.44	0.02
EAS-US	2026-06-25 11:15:00	15.36	32.39	0.22	6.75	9.32	3.29	0.02
EAS-US	2026-06-25 11:30:00	15.41	31.78	0.22	6.89	9.52	3.23	0.02
EAS-US	2026-06-25 11:45:00	15.40	31.57	0.22	6.87	9.47	3.25	0.02
EAS-US	2026-06-25 12:00:00	15.40	31.78	0.13	6.83	9.42	3.28	0.02
EAS-US	2026-06-25 12:15:00	15.40	32.47	0.22	7.00	9.34	3.39	0.02
EAS-US	2026-06-25 12:30:00	15.39	32.61	0.21	6.80	8.55	83.78	0.02
EAS-US	2026-06-25 12:45:00	15.41	31.79	0.21	6.99	9.16	26.00	0.02
EAS-US	2026-06-25 13:00:00	15.43	31.92	0.14	6.81	9.28	368.44	0.02
EAS-US	2026-06-25 13:15:00	15.45	31.72	0.21	6.87	9.36	932.84	0.02
EAS-US	2026-06-25 13:30:00	15.46	31.74	0.21	6.95	9.39	85.94	0.02
EAS-US	2026-06-25 13:45:00	15.45	31.81	0.21	6.88	9.35	6.43	0.02
EAS-US	2026-06-25 14:00:00	15.43	31.79	0.13	6.89	9.33	37.42	0.02
EAS-US	2026-06-25 14:15:00	15.45	31.75	0.21	7.11	9.37	7.50	0.02
EAS-US	2026-06-25 14:30:00	15.47	31.67	0.22	7.18	9.40	8.92	0.02
EAS-US	2026-06-25 14:45:00	15.47	31.68	0.22	7.14	9.41	5.59	0.02
EAS-US	2026-06-25 15:00:00	15.45	31.88	0.15	6.86	9.35	17.22	0.02
EAS-US	2026-06-25 15:15:00	15.45	31.77	0.22	6.93	9.34	28.83	0.02
EAS-US	2026-06-25 15:30:00	15.48	31.79	0.22	6.92	9.38	33.07	0.02
EAS-US	2026-06-25 15:45:00	15.50	31.76	0.22	6.89	9.40	19.95	0.02
EAS-US	2026-06-25 16:00:00	15.51	31.84	0.14	6.91	9.38	18.35	0.02
EAS-US	2026-06-25 16:15:00	15.50	31.73	0.21	7.15	9.35	4.98	0.02
EAS-US	2026-06-25 16:30:00	15.50	31.79	0.21	7.14	9.34	5.20	0.02
EAS-US	2026-06-25 16:45:00	15.51	31.82	0.21	7.15	9.33	5.23	0.02
EAS-US	2026-06-25 17:00:00	15.53	32.11	0.14	6.85	9.33	15.28	0.02
EAS-US	2026-06-25 17:15:00	15.54	31.86	0.22	6.89	9.32	9.96	0.02
EAS-US	2026-06-25 17:30:00	15.53	31.93	0.22	6.89	9.28	4.32	0.02
EAS-US	2026-06-25 17:45:00	15.51	32.05	0.22	6.87	9.21	4.84	0.02
EAS-US	2026-06-25 18:00:00	15.48	32.45	0.14	6.87	9.17	14.02	0.02
EAS-US	2026-06-25 18:15:00	15.45	32.37	0.21	7.09	9.14	4.70	0.02
EAS-US	2026-06-25 18:30:00	15.41	32.49	0.21	7.09	9.11	4.55	0.02
EAS-US	2026-06-25 18:45:00	15.38	32.55	0.21	7.09	9.11	4.47	0.02
EAS-US	2026-06-25 19:00:00	15.35	32.87	0.14	6.79	9.10	5.64	0.02
EAS-US	2026-06-25 19:15:00	15.32	32.69	0.22	6.84	9.10	5.73	0.02
EAS-US	2026-06-25 19:30:00	15.29	32.73	0.22	6.75	9.08	4.57	0.02
EAS-US	2026-06-25 19:45:00	15.26	32.83	0.22	6.82	9.06	4.54	0.02
EAS-US	2026-06-25 20:00:00	15.22	33.05	0.14	6.83	9.07	7.77	0.02
EAS-US	2026-06-25 20:15:00	15.20	32.97	0.22	7.06	9.04	4.32	0.02
EAS-US	2026-06-25 20:30:00	15.17	33.00	0.22	7.05	9.05	4.52	0.02
EAS-US	2026-06-25 20:45:00	15.14	33.05	0.21	7.05	9.05	4.30	0.02
EAS-US	2026-06-25 21:00:00	15.11	33.27	0.14	6.77	9.05	5.84	0.02

Woodfibre LNG (East Creek)								
Station	Date/Time	Temperature (C)	Specific Conductivity (µS/cm)	ORP (V)	pH (pH units)	Dissolved Oxygen (mg/L)	Turbidity (NTU)	Salinity (PSU)
EAS-US	2026-06-25 21:15:00	15.08	33.12	0.22	6.80	9.02	5.61	0.02
EAS-US	2026-06-25 21:30:00	15.05	33.12	0.22	6.82	9.03	4.72	0.02
EAS-US	2026-06-25 21:45:00	15.02	33.13	0.22	6.75	9.02	4.47	0.02
EAS-US	2026-06-25 22:00:00	14.98	33.20	0.14	6.79	9.06	11.85	0.02
EAS-US	2026-06-25 22:15:00	14.95	33.08	0.22	7.05	9.04	8.52	0.02
EAS-US	2026-06-25 22:30:00	14.92	33.05	0.22	7.05	9.05	5.74	0.02
EAS-US	2026-06-25 22:45:00	14.90	33.04	0.22	7.05	9.06	5.43	0.02
EAS-US	2026-06-25 23:00:00	14.87	33.26	0.14	6.75	9.07	8.08	0.02
EAS-US	2026-06-25 23:15:00	14.85	33.07	0.22	6.77	9.05	5.05	0.02
EAS-US	2026-06-25 23:30:00	14.83	33.06	0.22	6.74	9.10	4.02	0.02
EAS-US	2026-06-25 23:45:00	14.81	33.04	0.22	6.80	9.08	3.71	0.02
EAS-US	2026-06-26 00:00:00	14.78	33.27	0.13	6.80	9.07	9.21	0.02
EAS-US	2026-06-26 00:15:00	14.76	32.99	0.22	7.03	9.07	3.82	0.02
EAS-US	2026-06-26 00:30:00	14.73	32.95	0.22	7.04	9.09	3.85	0.02
EAS-US	2026-06-26 00:45:00	14.71	32.88	0.22	7.04	9.09	3.78	0.02
EAS-US	2026-06-26 01:00:00	14.69	32.95	0.13	6.77	9.11	4.01	0.02
EAS-US	2026-06-26 01:15:00	14.67	32.88	0.22	6.80	9.10	3.83	0.02
EAS-US	2026-06-26 01:30:00	14.64	33.39	0.23	6.83	9.09	5.30	0.02
EAS-US	2026-06-26 01:45:00	14.61	33.67	0.22	6.76	8.97	4.88	0.02
EAS-US	2026-06-26 02:00:00	14.58	34.67	0.13	6.77	8.91	6.19	0.02
EAS-US	2026-06-26 02:15:00	14.56	34.93	0.22	7.02	9.00	4.94	0.02
EAS-US	2026-06-26 02:30:00	14.53	35.28	0.22	7.02	9.00	4.76	0.02
EAS-US	2026-06-26 02:45:00	14.51	35.52	0.21	7.02	9.01	4.62	0.02
EAS-US	2026-06-26 03:00:00	14.48	35.79	0.13	6.75	9.02	4.65	0.02
EAS-US	2026-06-26 03:15:00	14.45	35.60	0.22	6.81	9.01	4.20	0.02
EAS-US	2026-06-26 03:30:00	14.42	35.52	0.22	6.75	9.01	4.01	0.02
EAS-US	2026-06-26 03:45:00	14.39	35.23	0.22	6.80	9.07	3.94	0.02
EAS-US	2026-06-26 04:00:00	14.36	35.13	0.13	6.78	9.07	5.46	0.02
EAS-US	2026-06-26 04:15:00	14.33	34.77	0.22	7.03	9.09	4.11	0.02
EAS-US	2026-06-26 04:30:00	14.30	34.53	0.22	7.03	9.13	3.96	0.02
EAS-US	2026-06-26 04:45:00	14.27	34.32	0.22	7.03	9.15	3.94	0.02
EAS-US	2026-06-26 05:00:00	14.24	34.28	0.13	6.75	9.17	4.10	0.02
EAS-US	2026-06-26 05:15:00	14.23	34.01	0.22	6.82	9.19	3.71	0.02
EAS-US	2026-06-26 05:30:00	14.20	33.91	0.22	6.82	9.18	3.78	0.02
EAS-US	2026-06-26 05:45:00	14.18	33.85	0.22	6.78	9.19	3.74	0.02
EAS-US	2026-06-26 06:00:00	14.15	33.98	0.14	6.80	9.20	6.74	0.02
EAS-US	2026-06-26 06:15:00	14.13	33.77	0.22	7.04	9.21	3.91	0.02
EAS-US	2026-06-26 06:30:00	14.11	33.69	0.22	7.03	9.19	3.87	0.02
EAS-US	2026-06-26 06:45:00	14.09	33.60	0.22	7.05	9.23	3.83	0.02
EAS-US	2026-06-26 07:00:00	14.08	33.77	0.14	6.78	9.25	5.39	0.02
EAS-US	2026-06-26 07:15:00	14.08	33.46	0.23	6.83	9.27	3.88	0.02
EAS-US	2026-06-26 07:30:00	14.07	33.43	0.23	6.86	9.33	4.61	0.02
EAS-US	2026-06-26 07:45:00	14.07	33.44	0.23	6.79	9.34	3.95	0.02
EAS-US	2026-06-26 08:00:00	14.07	33.64	0.13	6.82	9.36	4.13	0.02
EAS-US	2026-06-26 08:15:00	14.07	33.52	0.22	7.05	9.27	4.09	0.02
EAS-US	2026-06-26 08:30:00	14.04	33.83	0.22	7.09	9.35	4.26	0.02
EAS-US	2026-06-26 08:45:00	14.04	33.99	0.22	7.09	9.36	4.45	0.02
EAS-US	2026-06-26 09:00:00	14.03	34.41	0.13	6.80	9.34	8.88	0.02
EAS-US	2026-06-26 09:15:00	14.03	34.40	0.22	6.87	9.38	4.79	0.02
EAS-US	2026-06-26 09:30:00	14.03	34.55	0.22	6.86	9.40	5.08	0.02
EAS-US	2026-06-26 09:45:00	14.03	34.74	0.22	6.88	9.41	4.41	0.02
EAS-US	2026-06-26 10:00:00	14.02	35.07	0.13	6.87	9.43	4.86	0.02
EAS-US	2026-06-26 10:15:00	14.02	35.11	0.22	7.11	9.40	4.66	0.02
EAS-US	2026-06-26 10:30:00	14.01	35.27	0.22	7.11	9.45	4.81	0.02
EAS-US	2026-06-26 10:45:00	14.01	35.46	0.22	7.12	9.45	5.22	0.02


Woodfibre LNG (East Creek)								
Station	Date/Time	Temperature (C)	Specific Conductivity (µS/cm)	ORP (V)	pH (pH units)	Dissolved Oxygen (mg/L)	Turbidity (NTU)	Salinity (PSU)
EAS-US	2026-06-26 11:00:00	14.02	35.76	0.14	6.79	9.23	5.19	0.02
EAS-US	2026-06-26 11:15:00	14.03	35.75	0.22	6.94	9.54	4.76	0.02
EAS-US	2026-06-26 11:30:00	14.07	35.77	0.22	6.94	9.55	5.08	0.02
EAS-US	2026-06-26 11:45:00	14.10	35.79	0.22	6.90	9.57	4.33	0.02
EAS-US	2026-06-26 12:00:00	14.13	35.82	0.13	6.91	9.57	4.43	0.02
EAS-US	2026-06-26 12:15:00	14.17	35.49	0.22	7.16	9.59	4.17	0.02
EAS-US	2026-06-26 12:30:00	14.20	35.20	0.22	7.18	9.60	4.22	0.02
EAS-US	2026-06-26 12:45:00	14.22	35.16	0.21	7.14	9.56	3.92	0.02
EAS-US	2026-06-26 13:00:00	14.24	34.86	0.13	6.89	9.58	5.31	0.02
EAS-US	2026-06-26 13:15:00	14.26	34.79	0.22	6.89	9.58	3.93	0.02
EAS-US	2026-06-26 13:30:00	14.28	35.00	0.22	6.92	9.56	3.88	0.02
EAS-US	2026-06-26 13:45:00	14.29	35.19	0.21	6.89	9.56	3.88	0.02
EAS-US	2026-06-26 14:00:00	14.31	35.70	0.13	6.90	9.51	5.29	0.02
EAS-US	2026-06-26 14:15:00	14.31	35.50	0.21	7.10	9.49	4.01	0.02
EAS-US	2026-06-26 14:30:00	14.32	35.49	0.21	7.10	9.49	4.03	0.02
EAS-US	2026-06-26 14:45:00	14.32	35.61	0.21	7.10	9.49	4.00	0.02
EAS-US	2026-06-26 15:00:00	14.31	36.59	0.13	6.82	9.48	4.46	0.02
EAS-US	2026-06-26 15:15:00	14.31	36.52	0.22	6.86	9.42	4.16	0.02
EAS-US	2026-06-26 15:30:00	14.29	37.54	0.22	6.82	9.46	4.32	0.02
EAS-US	2026-06-26 15:45:00	14.27	38.81	0.22	6.85	9.46	4.26	0.02
EAS-US	2026-06-26 16:00:00	14.26	43.70	0.13	6.83	9.36	6.32	0.02
EAS-US	2026-06-26 16:15:00	14.25	44.81	0.21	7.06	9.35	4.23	0.02
EAS-US	2026-06-26 16:30:00	14.25	46.81	0.21	6.98	9.35	4.34	0.03
EAS-US	2026-06-26 16:45:00	14.26	48.15	0.21	7.00	9.49	4.20	0.03
EAS-US	2026-06-26 17:00:00	14.26	47.89	0.12	6.79	9.46	5.97	0.02
EAS-US	2026-06-26 17:15:00	14.27	45.99	0.22	6.92	9.50	4.05	0.02
EAS-US	2026-06-26 17:30:00	14.26	44.46	0.21	6.88	9.48	4.00	0.02
EAS-US	2026-06-26 17:45:00	14.25	43.00	0.21	6.84	9.45	3.87	0.02
EAS-US	2026-06-26 18:00:00	14.23	40.22	0.12	6.90	9.42	4.05	0.02
EAS-US	2026-06-26 18:15:00	14.21	39.93	0.21	7.09	9.40	3.84	0.02
EAS-US	2026-06-26 18:30:00	14.20	39.09	0.20	7.10	9.41	3.80	0.02
EAS-US	2026-06-26 18:45:00	14.19	38.15	0.21	7.10	9.35	3.74	0.02
EAS-US	2026-06-26 19:00:00	14.18	36.60	0.12	6.84	9.35	3.74	0.02
EAS-US	2026-06-26 19:15:00	14.17	36.42	0.22	6.85	9.35	3.76	0.02
EAS-US	2026-06-26 19:30:00	14.16	35.79	0.22	6.90	9.38	3.67	0.02
EAS-US	2026-06-26 19:45:00	14.15	35.32	0.22	6.89	9.36	3.66	0.02
EAS-US	2026-06-26 20:00:00	14.13	34.89	0.13	6.85	9.36	3.86	0.02
EAS-US	2026-06-26 20:15:00	14.12	34.74	0.21	7.06	9.33	3.70	0.02
EAS-US	2026-06-26 20:30:00	14.10	34.58	0.21	7.04	9.31	3.73	0.02
EAS-US	2026-06-26 20:45:00	14.08	34.42	0.21	7.03	9.29	3.72	0.02
EAS-US	2026-06-26 21:00:00	14.05	34.39	0.12	6.75	9.23	4.01	0.02
EAS-US	2026-06-26 21:15:00	14.04	34.17	0.22	6.79	9.24	3.70	0.02
EAS-US	2026-06-26 21:30:00	14.02	34.06	0.22	6.81	9.25	3.78	0.02
EAS-US	2026-06-26 21:45:00	14.00	34.00	0.23	6.82	9.21	3.76	0.02
EAS-US	2026-06-26 22:00:00	13.98	33.85	0.13	6.79	9.18	3.85	0.02
EAS-US	2026-06-26 22:15:00	13.96	33.88	0.20	6.99	9.23	4.47	0.02
EAS-US	2026-06-26 22:30:00	13.95	33.81	0.21	7.00	9.26	3.74	0.02
EAS-US	2026-06-26 22:45:00	13.93	33.72	0.21	6.99	9.24	3.72	0.02
EAS-US	2026-06-26 23:00:00	13.92	33.74	0.13	6.72	9.20	4.07	0.02
EAS-US	2026-06-26 23:15:00	13.90	33.59	0.23	6.71	9.25	3.77	0.02
EAS-US	2026-06-26 23:30:00	13.88	33.55	0.23	6.79	9.23	3.81	0.02
EAS-US	2026-06-26 23:45:00	13.86	33.57	0.22	6.75	9.11	3.79	0.02
EAS-US	2026-06-27 00:00:00	13.83	33.45	0.13	6.72	9.11	4.17	0.02
EAS-US	2026-06-27 00:15:00	13.81	33.41	0.21	6.99	9.14	3.80	0.02
EAS-US	2026-06-27 00:30:00	13.79	33.37	0.22	6.97	9.12	3.80	0.02

Woodfibre LNG (East Creek)								
Station	Date/Time	Temperature (C)	Specific Conductivity (µS/cm)	ORP (V)	pH (pH units)	Dissolved Oxygen (mg/L)	Turbidity (NTU)	Salinity (PSU)
EAS-US	2026-06-27 00:45:00	13.76	33.35	0.22	6.95	9.11	3.76	0.02
EAS-US	2026-06-27 01:00:00	13.73	33.30	0.14	6.70	9.15	4.93	0.02
EAS-US	2026-06-27 01:15:00	13.70	33.23	0.22	6.79	9.18	3.79	0.02
EAS-US	2026-06-27 01:30:00	13.67	33.17	0.22	6.77	9.16	3.89	0.02
EAS-US	2026-06-27 01:45:00	13.64	33.16	0.22	6.71	9.18	3.75	0.02
EAS-US	2026-06-27 02:00:00	13.60	33.04	0.13	6.62	9.15	3.95	0.02
EAS-US	2026-06-27 02:15:00	13.57	33.02	0.22	6.95	9.19	3.75	0.02
EAS-US	2026-06-27 02:30:00	13.53	33.01	0.22	6.86	9.22	3.80	0.02
EAS-US	2026-06-27 02:45:00	13.49	32.93	0.22	6.93	9.17	3.76	0.02
EAS-US	2026-06-27 03:00:00	13.45	33.01	0.13	6.66	9.19	3.91	0.02
EAS-US	2026-06-27 03:15:00	13.42	32.92	0.23	6.71	9.20	3.84	0.02
EAS-US	2026-06-27 03:30:00	13.39	32.87	0.23	6.69	9.24	3.96	0.02
EAS-US	2026-06-27 03:45:00	13.35	32.88	0.23	6.71	9.27	3.81	0.02
EAS-US	2026-06-27 04:00:00	13.31	32.94	0.13	6.73	9.24	3.88	0.02
EAS-US	2026-06-27 04:15:00	13.28	32.76	0.22	6.94	9.30	3.93	0.02
EAS-US	2026-06-27 04:30:00	13.25	32.75	0.22	6.93	9.27	3.92	0.02
EAS-US	2026-06-27 04:45:00	13.22	32.69	0.22	6.95	9.26	3.92	0.02
EAS-US	2026-06-27 05:00:00	13.19	32.69	0.14	6.68	9.26	3.87	0.02
EAS-US	2026-06-27 05:15:00	13.17	32.57	0.23	6.79	9.32	3.87	0.02
EAS-US	2026-06-27 05:30:00	13.15	32.55	0.23	6.71	9.40	3.81	0.02
EAS-US	2026-06-27 05:45:00	13.13	32.52	0.23	6.74	9.37	3.84	0.02
EAS-US	2026-06-27 06:00:00	13.10	32.66	0.12	6.75	9.33	4.01	0.02
EAS-US	2026-06-27 06:15:00	13.08	32.48	0.22	6.98	9.41	3.89	0.02
EAS-US	2026-06-27 06:30:00	13.06	32.40	0.22	6.99	9.48	3.81	0.02
EAS-US	2026-06-27 06:45:00	13.05	32.33	0.22	7.01	9.52	3.86	0.02
EAS-US	2026-06-27 07:00:00	13.04	32.33	0.14	6.74	9.55	3.89	0.02
EAS-US	2026-06-27 07:15:00	13.04	32.21	0.23	6.86	9.60	3.84	0.02
EAS-US	2026-06-27 07:30:00	13.06	32.12	0.22	6.87	9.70	3.79	0.02
EAS-US	2026-06-27 07:45:00	13.08	32.05	0.23	6.85	9.73	3.83	0.02
EAS-US	2026-06-27 08:00:00	13.10	32.11	0.13	6.82	9.78	3.94	0.02
EAS-US	2026-06-27 08:15:00	13.13	31.87	0.21	7.06	9.81	3.82	0.02
EAS-US	2026-06-27 08:30:00	13.17	31.77	0.21	7.07	9.83	3.81	0.02
EAS-US	2026-06-27 08:45:00	13.20	31.70	0.21	7.04	9.84	3.81	0.02
EAS-US	2026-06-27 09:00:00	13.25	31.80	0.13	6.80	9.87	3.87	0.02
EAS-US	2026-06-27 09:15:00	13.29	31.56	0.22	6.90	9.90	3.80	0.02
EAS-US	2026-06-27 09:30:00	13.32	31.54	0.22	6.86	9.90	3.84	0.02
EAS-US	2026-06-27 09:45:00	13.35	31.46	0.22	6.92	9.89	3.81	0.02
EAS-US	2026-06-27 10:00:00	13.40	31.54	0.13	6.87	9.85	4.18	0.02
EAS-US	2026-06-27 10:15:00	13.45	31.42	0.22	7.09	9.92	3.88	0.02
EAS-US	2026-06-27 10:30:00	13.51	31.33	0.22	7.12	10.00	3.93	0.02
EAS-US	2026-06-27 10:45:00	13.66	31.22	0.22	7.12	10.10	3.94	0.02
EAS-US	2026-06-27 11:00:00	13.81	31.06	0.13	6.94	9.97	11.01	0.02
EAS-US	2026-06-27 11:15:00	13.77	31.07	0.22	7.03	9.88	4.28	0.02
EAS-US	2026-06-27 11:30:00	13.93	31.01	0.22	7.04	9.93	4.36	0.02
EAS-US	2026-06-27 11:45:00	14.11	31.02	0.22	7.04	9.92	4.06	0.02
EAS-US	2026-06-27 12:00:00	14.41	31.01	0.13	7.06	9.94	4.01	0.02
EAS-US	2026-06-27 12:15:00	14.57	30.99	0.20	7.23	9.90	4.10	0.02
EAS-US	2026-06-27 12:30:00	14.56	31.05	0.20	7.22	9.84	4.18	0.02
EAS-US	2026-06-27 12:45:00	14.50	31.06	0.20	7.21	9.82	4.06	0.02
EAS-US	2026-06-27 13:00:00	14.79	31.08	0.12	6.99	9.81	3.84	0.02
EAS-US	2026-06-27 13:15:00	14.72	31.10	0.21	7.03	9.75	3.89	0.02
EAS-US	2026-06-27 13:30:00	14.74	31.09	0.21	7.05	9.73	3.96	0.02
EAS-US	2026-06-27 13:45:00	14.79	31.07	0.21	7.06	9.70	3.94	0.02
EAS-US	2026-06-27 14:00:00	14.93	31.14	0.12	7.05	9.68	4.00	0.02
EAS-US	2026-06-27 14:15:00	14.97	31.15	0.21	7.21	9.64	3.93	0.02

Woodfibre LNG (East Creek)								
Station	Date/Time	Temperature (C)	Specific Conductivity (µS/cm)	ORP (V)	pH (pH units)	Dissolved Oxygen (mg/L)	Turbidity (NTU)	Salinity (PSU)
EAS-US	2026-06-27 14:30:00	14.94	31.29	0.21	7.19	9.57	3.89	0.02
EAS-US	2026-06-27 14:45:00	15.05	31.41	0.21	7.18	9.51	3.98	0.02
EAS-US	2026-06-27 15:00:00	15.10	31.56	0.13	6.96	9.49	3.82	0.02
EAS-US	2026-06-27 15:15:00	15.17	31.50	0.21	7.01	9.51	3.89	0.02
EAS-US	2026-06-27 15:30:00	15.29	31.53	0.21	7.02	9.49	3.77	0.02
EAS-US	2026-06-27 15:45:00	15.38	31.61	0.21	7.01	9.46	3.93	0.02
EAS-US	2026-06-27 16:00:00	15.36	31.71	0.13	7.01	9.42	3.95	0.02
EAS-US	2026-06-27 16:15:00	15.30	31.75	0.21	7.15	9.36	4.03	0.02
EAS-US	2026-06-27 16:30:00	15.28	31.90	0.21	7.14	9.32	4.00	0.02
EAS-US	2026-06-27 16:45:00	15.32	31.93	0.21	7.14	9.36	3.99	0.02
EAS-US	2026-06-27 17:00:00	15.31	32.05	0.13	6.93	9.37	4.46	0.02
EAS-US	2026-06-27 17:15:00	15.29	32.01	0.21	6.99	9.38	4.09	0.02
EAS-US	2026-06-27 17:30:00	15.25	32.07	0.21	6.97	9.35	3.60	0.02
EAS-US	2026-06-27 17:45:00	15.21	32.15	0.21	6.96	9.35	3.51	0.02
EAS-US	2026-06-27 18:00:00	15.17	32.23	0.12	6.94	9.33	3.80	0.02
EAS-US	2026-06-27 18:15:00	15.14	32.27	0.20	7.12	9.33	3.57	0.02
EAS-US	2026-06-27 18:30:00	15.08	32.30	0.21	7.11	9.30	3.57	0.02
EAS-US	2026-06-27 18:45:00	15.02	32.39	0.21	7.09	9.28	3.47	0.02
EAS-US	2026-06-27 19:00:00	14.97	32.50	0.13	6.86	9.25	3.40	0.02
EAS-US	2026-06-27 19:15:00	14.92	32.55	0.22	6.90	9.25	3.56	0.02
EAS-US	2026-06-27 19:30:00	14.86	32.61	0.21	6.95	9.26	3.50	0.02
EAS-US	2026-06-27 19:45:00	14.81	32.68	0.21	6.89	9.25	3.45	0.02
EAS-US	2026-06-27 20:00:00	14.75	32.76	0.13	6.89	9.25	3.53	0.02
EAS-US	2026-06-27 20:15:00	14.71	32.76	0.21	7.06	9.25	3.48	0.02
EAS-US	2026-06-27 20:30:00	14.66	32.80	0.21	7.07	9.26	3.75	0.02
EAS-US	2026-06-27 20:45:00	14.62	32.84	0.22	7.06	9.26	3.49	0.02
EAS-US	2026-06-27 21:00:00	14.57	32.91	0.13	6.84	9.27	2.66	0.02
EAS-US	2026-06-27 21:15:00	14.52	32.92	0.22	6.88	9.26	2.79	0.02
EAS-US	2026-06-27 21:30:00	14.48	32.93	0.21	6.93	9.26	2.79	0.02
EAS-US	2026-06-27 21:45:00	14.43	32.94	0.22	6.88	9.27	2.57	0.02
EAS-US	2026-06-27 22:00:00	14.39	32.99	0.13	6.86	9.28	2.77	0.02
EAS-US	2026-06-27 22:15:00	14.34	32.98	0.21	7.06	9.29	2.58	0.02
EAS-US	2026-06-27 22:30:00	14.30	32.99	0.22	7.05	9.29	2.50	0.02
EAS-US	2026-06-27 22:45:00	14.25	32.94	0.22	7.04	9.30	2.55	0.02
EAS-US	2026-06-27 23:00:00	14.20	32.95	0.14	6.80	9.32	2.45	0.02
EAS-US	2026-06-27 23:15:00	14.16	32.88	0.22	6.90	9.34	2.45	0.02
EAS-US	2026-06-27 23:30:00	14.12	32.86	0.23	6.87	9.36	2.44	0.02
EAS-US	2026-06-27 23:45:00	14.07	32.82	0.23	6.87	9.36	2.45	0.02
EAS-US	2026-06-28 00:00:00	14.03	32.82	0.14	6.84	9.37	2.48	0.02
EAS-US	2026-06-28 00:15:00	13.99	32.76	0.22	7.06	9.38	2.50	0.02
EAS-US	2026-06-28 00:30:00	13.95	32.76	0.22	7.05	9.39	2.52	0.02
EAS-US	2026-06-28 00:45:00	13.91	32.71	0.22	7.04	9.40	2.49	0.02
EAS-US	2026-06-28 01:00:00	13.88	32.70	0.14	6.80	9.42	2.59	0.02
EAS-US	2026-06-28 01:15:00	13.84	32.66	0.22	6.90	9.42	2.46	0.02
EAS-US	2026-06-28 01:30:00	13.81	32.66	0.22	6.86	9.42	2.43	0.02
EAS-US	2026-06-28 01:45:00	13.77	32.61	0.23	6.85	9.43	2.46	0.02
EAS-US	2026-06-28 02:00:00	13.74	32.64	0.13	6.83	9.45	2.49	0.02
EAS-US	2026-06-28 02:15:00	13.71	32.57	0.22	7.05	9.45	2.48	0.02
EAS-US	2026-06-28 02:30:00	13.68	32.56	0.23	7.05	9.47	2.46	0.02
EAS-US	2026-06-28 02:45:00	13.64	32.56	0.23	7.04	9.47	2.50	0.02
EAS-US	2026-06-28 03:00:00	13.61	32.55	0.15	6.78	9.50	2.46	0.02
EAS-US	2026-06-28 03:15:00	13.58	32.51	0.23	6.83	9.50	2.44	0.02
EAS-US	2026-06-28 03:30:00	13.55	32.49	0.23	6.90	9.50	2.49	0.02
EAS-US	2026-06-28 03:45:00	13.51	32.45	0.23	6.84	9.51	2.44	0.02
EAS-US	2026-06-28 04:00:00	13.48	32.47	0.14	6.84	9.52	2.40	0.02

Woodfibre LNG (East Creek)								
Station	Date/Time	Temperature (C)	Specific Conductivity (µS/cm)	ORP (V)	pH (pH units)	Dissolved Oxygen (mg/L)	Turbidity (NTU)	Salinity (PSU)
EAS-US	2026-06-28 04:15:00	13.45	32.43	0.23	7.04	9.53	2.51	0.02
EAS-US	2026-06-28 04:30:00	13.41	32.39	0.22	7.05	9.55	2.45	0.02
EAS-US	2026-06-28 04:45:00	13.38	32.40	0.22	7.04	9.55	2.56	0.02
EAS-US	2026-06-28 05:00:00	13.35	32.38	0.15	6.80	9.56	2.51	0.02
EAS-US	2026-06-28 05:15:00	13.32	32.37	0.23	6.86	9.57	2.46	0.02
EAS-US	2026-06-28 05:30:00	13.29	32.39	0.23	6.85	9.57	2.50	0.02
EAS-US	2026-06-28 05:45:00	13.26	32.39	0.22	6.90	9.59	2.48	0.02
EAS-US	2026-06-28 06:00:00	13.23	32.36	0.13	6.85	9.60	2.52	0.02
EAS-US	2026-06-28 06:15:00	13.21	32.29	0.22	7.05	9.62	2.50	0.02
EAS-US	2026-06-28 06:30:00	13.18	32.22	0.22	7.05	9.64	2.43	0.02
EAS-US	2026-06-28 06:45:00	13.15	32.16	0.22	7.05	9.64	2.63	0.02
EAS-US	2026-06-28 07:00:00	13.13	32.13	0.14	6.82	9.68	2.43	0.02
EAS-US	2026-06-28 07:15:00	13.13	32.03	0.23	6.89	9.70	2.46	0.02
EAS-US	2026-06-28 07:30:00	13.12	31.98	0.23	6.87	9.72	2.49	0.02
EAS-US	2026-06-28 07:45:00	13.14	31.88	0.23	6.90	9.78	2.46	0.02
EAS-US	2026-06-28 08:00:00	13.16	31.82	0.14	6.90	9.80	2.46	0.02
EAS-US	2026-06-28 08:15:00	13.19	31.70	0.23	7.09	9.82	2.46	0.02
EAS-US	2026-06-28 08:30:00	13.22	31.60	0.23	7.11	9.83	2.41	0.02
EAS-US	2026-06-28 08:45:00	13.28	31.50	0.23	7.12	9.90	2.46	0.02
EAS-US	2026-06-28 09:00:00	13.33	31.43	0.15	6.89	9.92	2.45	0.02
EAS-US	2026-06-28 09:15:00	13.40	31.29	0.23	6.96	9.95	2.48	0.02
EAS-US	2026-06-28 09:30:00	13.46	31.21	0.23	6.98	9.95	2.40	0.02
EAS-US	2026-06-28 09:45:00	13.51	31.19	0.23	7.00	9.92	2.46	0.02
EAS-US	2026-06-28 10:00:00	13.57	31.17	0.14	6.99	9.92	2.43	0.02
EAS-US	2026-06-28 10:15:00	13.61	31.14	0.22	7.18	9.92	2.50	0.02
EAS-US	2026-06-28 10:30:00	13.67	31.12	0.22	7.18	9.94	2.45	0.02
EAS-US	2026-06-28 10:45:00	13.75	31.08	0.22	7.19	9.95	2.49	0.02
EAS-US	2026-06-28 11:00:00	13.81	31.05	0.15	6.97	9.94	2.45	0.02
EAS-US	2026-06-28 11:15:00	13.88	31.02	0.22	7.05	9.93	2.41	0.02
EAS-US	2026-06-28 11:30:00	13.93	31.01	0.23	7.03	9.92	2.47	0.02
EAS-US	2026-06-28 11:45:00	14.01	30.98	0.22	7.06	9.92	2.54	0.02
EAS-US	2026-06-28 12:00:00	14.04	31.09	0.14	7.02	9.87	2.54	0.02
EAS-US	2026-06-28 12:15:00	14.09	31.04	0.22	7.20	9.86	2.51	0.02
EAS-US	2026-06-28 12:30:00	14.13	31.11	0.22	7.21	9.83	2.52	0.02
EAS-US	2026-06-28 12:45:00	14.16	31.12	0.22	7.20	9.82	2.49	0.02
EAS-US	2026-06-28 13:00:00	14.21	31.15	0.14	6.96	9.83	2.45	0.02
EAS-US	2026-06-28 13:15:00	14.29	31.15	0.22	7.03	9.83	2.46	0.02
EAS-US	2026-06-28 13:30:00	14.41	31.06	0.23	7.07	9.86	2.50	0.02
EAS-US	2026-06-28 13:45:00	14.45	31.04	0.23	7.05	9.83	2.46	0.02
EAS-US	2026-06-28 14:00:00	14.51	31.07	0.14	7.03	9.82	2.56	0.02
EAS-US	2026-06-28 14:15:00	14.58	31.07	0.22	7.21	9.79	2.56	0.02
EAS-US	2026-06-28 14:30:00	14.61	31.17	0.21	7.20	9.70	2.53	0.02
EAS-US	2026-06-28 14:45:00	14.63	31.28	0.22	7.18	9.67	2.53	0.02
EAS-US	2026-06-28 15:00:00	14.63	31.46	0.14	6.94	9.62	2.48	0.02
EAS-US	2026-06-28 15:15:00	14.66	31.49	0.23	7.00	9.66	2.51	0.02
EAS-US	2026-06-28 15:30:00	14.69	31.47	0.23	7.04	9.67	2.46	0.02
EAS-US	2026-06-28 15:45:00	14.71	31.48	0.22	7.00	9.66	2.53	0.02
EAS-US	2026-06-28 16:00:00	14.75	31.51	0.14	7.01	9.66	2.50	0.02
EAS-US	2026-06-28 16:15:00	14.83	31.49	0.22	7.19	9.66	2.51	0.02
EAS-US	2026-06-28 16:30:00	14.87	31.58	0.22	7.18	9.61	2.51	0.02
EAS-US	2026-06-28 16:45:00	14.89	31.62	0.22	7.20	9.58	2.52	0.02
EAS-US	2026-06-28 17:00:00	14.92	31.71	0.15	6.94	9.56	2.51	0.02
EAS-US	2026-06-28 17:15:00	14.96	31.76	0.22	7.00	9.53	2.46	0.02
EAS-US	2026-06-28 17:30:00	14.99	31.87	0.22	7.02	9.46	2.50	0.02
EAS-US	2026-06-28 17:45:00	14.97	31.99	0.22	6.96	9.44	2.47	0.02

Woodfibre LNG (East Creek)								
Station	Date/Time	Temperature (C)	Specific Conductivity (µS/cm)	ORP (V)	pH (pH units)	Dissolved Oxygen (mg/L)	Turbidity (NTU)	Salinity (PSU)
EAS-US	2026-06-28 18:00:00	14.94	32.10	0.14	6.96	9.42	2.51	0.02
EAS-US	2026-06-28 18:15:00	14.90	32.19	0.21	7.13	9.38	2.54	0.02
EAS-US	2026-06-28 18:30:00	14.86	32.31	0.22	7.10	9.35	2.53	0.02
EAS-US	2026-06-28 18:45:00	14.82	32.43	0.22	7.10	9.33	2.51	0.02
EAS-US	2026-06-28 19:00:00	14.79	32.55	0.15	6.84	9.34	2.49	0.02
EAS-US	2026-06-28 19:15:00	14.75	32.63	0.23	6.89	9.34	2.52	0.02
EAS-US	2026-06-28 19:30:00	14.71	32.68	0.23	6.89	9.34	2.46	0.02
EAS-US	2026-06-28 19:45:00	14.67	32.75	0.23	6.90	9.35	2.48	0.02
EAS-US	2026-06-28 20:00:00	14.64	32.82	0.14	6.89	9.34	2.64	0.02
EAS-US	2026-06-28 20:15:00	14.60	32.82	0.23	7.07	9.34	3.06	0.02
EAS-US	2026-06-28 20:30:00	14.57	32.85	0.22	7.08	9.33	2.50	0.02
EAS-US	2026-06-28 20:45:00	14.54	32.90	0.23	7.06	9.33	2.50	0.02
EAS-US	2026-06-28 21:00:00	14.50	32.99	0.15	6.82	9.30	2.50	0.02
EAS-US	2026-06-28 21:15:00	14.47	33.00	0.23	6.88	9.30	2.54	0.02
EAS-US	2026-06-28 21:30:00	14.44	33.05	0.23	6.86	9.30	2.56	0.02
EAS-US	2026-06-28 21:45:00	14.41	33.09	0.23	6.90	9.29	5.32	0.02
EAS-US	2026-06-28 22:00:00	14.37	33.11	0.14	6.84	9.30	2.65	0.02
EAS-US	2026-06-28 22:15:00	14.34	33.09	0.23	7.07	9.29	2.61	0.02
EAS-US	2026-06-28 22:30:00	14.31	33.08	0.23	7.05	9.31	2.52	0.02
EAS-US	2026-06-28 22:45:00	14.28	33.07	0.23	7.05	9.31	2.55	0.02
EAS-US	2026-06-28 23:00:00	14.26	33.11	0.15	6.81	9.33	2.55	0.02
EAS-US	2026-06-28 23:15:00	14.23	33.06	0.23	6.87	9.31	2.53	0.02
EAS-US	2026-06-28 23:30:00	14.21	33.05	0.23	6.85	9.33	2.52	0.02
EAS-US	2026-06-28 23:45:00	14.18	33.01	0.23	6.81	9.33	2.46	0.02



 Eagle Mountain – Woodfibre Gas Pipeline Project Waste Discharge Permit PE-110163 Report	Reporting Week	June 22 to June 28, 2026
	Report #	118
	Appendix E	E-1

Appendix E:
Lab Documentation



Your P.O. #: 4800010213
 Your Project #: FORTIS11234/PE110163
 Site Location: WOODFIBRE PIPELINE PROJECT
 Your C.O.C. #: 133306

Attention: Saeesh Mangwani

HATFIELD CONSULTANTS
 N. VANCOUVER
 200-850 Harbourside Dr
 North Vancouver, BC
 Canada V7P 0A3

Report Date: 2026/07/02
 Report #: R3800883
 Version: 1 - Final

CERTIFICATE OF ANALYSIS

BUREAU VERITAS JOB #: C637815

Received: 2026/06/23, 17:51

Sample Matrix: Water
 # Samples Received: 4

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Analytical Method
Alkalinity @25C (pp, total), CO ₃ ,HCO ₃ ,OH	4	N/A	2026/06/25	BBY6SOP-00026	SM 24 2320 B m
Chloride/Sulphate by Auto Colourimetry	4	N/A	2026/06/25	BBY6SOP-00011 / BBY6SOP-00017	SM24-4500-Cl/SO ₄ -E m
Chromium III (Calc'd)	4	N/A	2026/07/02		
Total Hexavalent Chromium	4	N/A	2026/06/30	BBY6SOP-00054	SM 24 3500-Cr B m
Carbon (DOC) -Lab Filtered (1)	4	N/A	2026/06/25	BBY6SOP-00053	SM 24 5310 B m
Fluoride	4	N/A	2026/06/26	BBY6SOP-00037	SM 24 4500-F C m
Hardness Total (calculated as CaCO ₃) (2)	4	N/A	2026/06/30	BBY WI-00033	Auto Calc
Hardness (calculated as CaCO ₃)	4	N/A	2026/06/26	BBY WI-00033	Auto Calc
Mercury (Dissolved) by CV-Lab Filtered	4	2026/06/25	2026/06/25	BBY7SOP-00032	BCMOE LMAug2023 C m
Mercury (Total) by CV	4	2026/06/25	2026/06/25	BBY7SOP-00032	BCMOE LMAug2023 C m
Bromide as Bromine (Br) by ICPMS	4	N/A	2026/06/30	BBY7SOP-00002	EPA 6020B R2 m
Na, K, Ca, Mg, S by CRC ICPMS (diss.)	4	N/A	2026/06/26	BBY WI-00033	Auto Calc
Elements by ICPMS Low Level (lab filter) (3)	4	N/A	2026/06/26	BBY7SOP-00002	EPA 6020b R2 m
Elements by ICPMS Digested LL (total)	2	2026/06/27	2026/06/29	BBY7SOP-00003 / BBY7SOP-00002	EPA 6020b R2 m
Na, K, Ca, Mg, S by CRC ICPMS (total)	4	N/A	2026/06/30	BBY WI-00033	Auto Calc
Elements by ICPMS Low Level (total)	2	N/A	2026/06/29	BBY7SOP-00002	EPA 6020b R2 m
Nitrogen (Total)	4	N/A	2026/06/29	BBY6SOP-00016	SM 24 4500-N C m
Ammonia-N (Total)	4	N/A	2026/06/24	AB SOP-00007	SM 24 4500 NH ₃ A G m
Nitrate + Nitrite (N)	4	N/A	2026/06/25	BBY6SOP-00010	SM 24 4500-NO ₃ - H m
Nitrite (N) Regular Level Water	4	N/A	2026/06/25	BBY6SOP-00010	SM 24 4500-NO ₂ - m
Nitrogen - Nitrate (as N)	4	N/A	2026/06/26	BBY WI-00033	Auto Calc
pH @25°C (4)	4	N/A	2026/06/25	BBY6SOP-00026	SM 24 4500-H+ B m
Total Dissolved Solids (Filt. Residue)	4	2026/06/25	2026/06/26	BBY6SOP-00033	SM 24 2540 C m
Carbon (Total Organic) (5)	3	N/A	2026/06/27	BBY6SOP-00053	SM 24 5310 B m
Carbon (Total Organic) (5)	1	N/A	2026/06/29	BBY6SOP-00053	SM 24 5310 B m
Total Phosphorus Low Level Total	4	2026/06/29	2026/06/30	BBY6SOP-00013	SM 24 4500-P E m
Total Suspended Solids (NFR)	4	2026/06/25	2026/06/26	BBY6SOP-00034	SM 24 2540 D m
Field pH	4	N/A	2026/06/25	Field Test	Field Test
Field Temperature	4	N/A	2026/06/25	Field Test	Field Test



Your P.O. #: 4800010213
Your Project #: FORTIS11234/PE110163
Site Location: WOODFIBRE PIPELINE PROJECT
Your C.O.C. #: 133306

Attention: Saeesh Mangwani

HATFIELD CONSULTANTS
N. VANCOUVER
200-850 Harbourside Dr
North Vancouver, BC
Canada V7P 0A3

Report Date: 2026/07/02
Report #: R3800883
Version: 1 - Final

CERTIFICATE OF ANALYSIS

BUREAU VERITAS JOB #: C637815

Received: 2026/06/23, 17:51

Remarks:

Bureau Veritas is accredited to ISO/IEC 17025 for specific parameters on scopes of accreditation. Unless otherwise noted, procedures used by Bureau Veritas are based upon recognized Provincial, Federal or US method compendia such as CCME, EPA, APHA or the Quebec Ministry of Environment.

All work recorded herein has been done in accordance with procedures and practices ordinarily exercised by professionals in Bureau Veritas' profession using accepted testing methodologies, quality assurance and quality control procedures (except where otherwise agreed by the client and Bureau Veritas in writing). All data is in statistical control and has met quality control and method performance criteria unless otherwise noted. All method blanks are reported; unless indicated otherwise, associated sample data are not blank corrected. Where applicable, unless otherwise noted, Measurement Uncertainty has not been accounted for when stating conformity to the referenced standard.

Bureau Veritas liability is limited to the actual cost of the requested analyses, unless otherwise agreed in writing. There is no other warranty expressed or implied. Bureau Veritas has been retained to provide analysis of samples provided by the Client using the testing methodology referenced in this report. Interpretation and use of test results are the sole responsibility of the Client and are not within the scope of services provided by Bureau Veritas, unless otherwise agreed in writing. Bureau Veritas is not responsible for the accuracy or any data impacts, that result from the information provided by the customer or their agent.

Solid sample results, except biota, are based on dry weight unless otherwise indicated. Organic analyses are not recovery corrected except for isotope dilution methods.

Results relate to samples tested. When sampling is not conducted by Bureau Veritas, results relate to the supplied samples tested. This Certificate shall not be reproduced except in full, without the written approval of the laboratory.

Reference Method suffix "m" indicates test methods incorporate validated modifications from specific reference methods to improve performance.

* RPDs calculated using raw data. The rounding of final results may result in the apparent difference.

(1) DOC present in the sample should be considered as non-purgeable DOC. Dissolved > Total Imbalance: When applicable, Dissolved and Total results were reviewed and data quality meets acceptable levels unless otherwise noted.

(2) "Total Hardness" was calculated from Total Ca and Mg concentrations and may be biased high (Hardness, or Dissolved Hardness, calculated from Dissolved Ca and Mg, should be used for compliance if available).

(3) Samples were filtered and preserved at the lab. Values may not reflect concentrations at the time of sampling.

For Dissolved > Total Imbalance: When applicable, Dissolved and Total results were reviewed and data quality meets acceptable levels unless otherwise noted.

(4) The CCME method requires pH to be analysed within 15 minutes of sampling and therefore field analysis is required for compliance. All Laboratory pH analyses in this report are reported past the CCME holding time. Bureau Veritas endeavours to analyze samples as soon as possible after receipt.

(5) TOC present in the sample should be considered as non-purgeable TOC.



Your P.O. #: 4800010213
Your Project #: FORTIS11234/PE110163
Site Location: WOODFIBRE PIPELINE PROJECT
Your C.O.C. #: 133306

Attention: Saeesh Mangwani

HATFIELD CONSULTANTS
N. VANCOUVER
200-850 Harbourside Dr
North Vancouver, BC
Canada V7P 0A3

Report Date: 2026/07/02
Report #: R3800883
Version: 1 - Final

CERTIFICATE OF ANALYSIS

BUREAU VERITAS JOB #: C637815

Received: 2026/06/23, 17:51

Encryption Key

Please direct all questions regarding this Certificate of Analysis to:

Levi Manchak, Senior Project Manager
Email: Levi.MANCHAK@bureauveritas.com
Phone# (780)862-5634

=====

This report has been generated and distributed using a secure automated process.

Bureau Veritas has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per ISO/IEC 17025, signing the reports. For Service Group specific validation, please refer to the Validation Signatures page if included, otherwise available by request. For Department specific Analyst/Supervisor validation names, please refer to the Test Summary section if included, otherwise available by request. This report is authorized by Rob Gilbert, BBY General Manager responsible for British Columbia Environmental laboratory operations.



Bureau Veritas Job #: C637815
Report Date: 2026/07/02

HATFIELD CONSULTANTS
Client Project #: FORTIS11234/PE110163
Site Location: WOODFIBRE PIPELINE PROJECT
Your P.O. #: 4800010213

RESULTS OF CHEMICAL ANALYSES OF WATER

Bureau Veritas ID		EHJ247			EHJ247			EHJ248	EHJ249		
Sampling Date		2026/06/22 08:30			2026/06/22 08:30			2026/06/22 08:30	2026/06/22 08:30		
COC Number		133306			133306			133306	133306		
	UNITS	Q01	RDL	QC Batch	Q01 Lab-Dup	RDL	QC Batch	Q02	Q03	RDL	QC Batch
ANIONS											
Nitrite (N)	mg/L	ND	0.0050	C327852	ND	0.0050	C327852	ND	ND	0.0050	C327175
Calculated Parameters											
Total Chromium III	mg/L	ND	0.00099	C326243				ND	ND	0.00099	C326243
Dissolved Hardness (CaCO ₃)	mg/L	37.1	0.50	C326040				62.0	55.9	0.50	C326040
Total Hardness (CaCO ₃)	mg/L	37.5	0.50	C326037				61.8	58.2	0.50	C326037
Nitrate (N)	mg/L	0.089	0.020	C326251				0.149	0.215	0.020	C326251
Field Parameters											
Field pH	pH	6.87	N/A	ONSITE				6.73	6.33	N/A	ONSITE
Field Temperature	°C	14.4	N/A	ONSITE				13.1	11.2	N/A	ONSITE
Misc. Inorganics											
pH	pH	7.06	N/A	C327474	7.04	N/A	C327474	6.81	7.12	N/A	C327474
Total Organic Carbon (C)	mg/L	2.4	0.50	C331266				1.6	2.6	0.50	C329351
Total Dissolved Solids	mg/L	64	10	C327466				96	88	10	C327466
Total Suspended Solids	mg/L	2.4	1.0	C327479				3.6	13	1.0	C327479
Lab Filtered Inorganics											
Dissolved Organic Carbon (C)	mg/L	3.2	0.50	C327286				1.7	2.7	0.50	C327286
Anions											
Alkalinity (PP as CaCO ₃)	mg/L	ND	1.0	C327467	ND	1.0	C327467	ND	ND	1.0	C327467
Alkalinity (Total as CaCO ₃)	mg/L	46	1.0	C327467	46	1.0	C327467	68	68	1.0	C327467
Bicarbonate (HCO ₃)	mg/L	56	1.0	C327467	56	1.0	C327467	83	83	1.0	C327467
Carbonate (CO ₃)	mg/L	ND	1.0	C327467	ND	1.0	C327467	ND	ND	1.0	C327467
Fluoride (F)	mg/L	ND	0.050	C328741	ND	0.050	C328741	ND	ND	0.050	C328741
Hydroxide (OH)	mg/L	ND	1.0	C327467	ND	1.0	C327467	ND	ND	1.0	C327467
Chloride (Cl)	mg/L	ND	1.0	C327311	ND	1.0	C327311	3.7	6.5	1.0	C327333
Sulphate (SO ₄)	mg/L	ND	1.0	C327311	ND	1.0	C327311	8.2	7.0	1.0	C327333
Metals											
Total Hex. Chromium (Cr 6+)	mg/L	ND	0.00099	C332140				ND	ND	0.00099	C332140
Nutrients											
Total Ammonia (N)	mg/L	0.078	0.015	C326337	0.079	0.015	C326337	0.037	0.12	0.015	C326337
RDL = Reportable Detection Limit											
Lab-Dup = Laboratory Initiated Duplicate											
ND = Not Detected at a concentration equal or greater than the indicated Detection Limit.											
N/A = Not Applicable											



Bureau Veritas Job #: C637815
Report Date: 2026/07/02

HATFIELD CONSULTANTS
Client Project #: FORTIS11234/PE110163
Site Location: WOODFIBRE PIPELINE PROJECT
Your P.O. #: 4800010213

RESULTS OF CHEMICAL ANALYSES OF WATER

Bureau Veritas ID		EHJ247			EHJ247			EHJ248	EHJ249		
Sampling Date		2026/06/22 08:30			2026/06/22 08:30			2026/06/22 08:30	2026/06/22 08:30		
COC Number		133306			133306			133306	133306		
	UNITS	Q01	RDL	QC Batch	Q01 Lab-Dup	RDL	QC Batch	Q02	Q03	RDL	QC Batch
Total Phosphorus (P)	mg/L	0.0049	0.0010	C330916				0.0028	0.0041	0.0010	C330916
Nitrate plus Nitrite (N)	mg/L	0.089	0.020	C327849	0.087	0.020	C327849	0.149	0.215	0.020	C327173
Total Nitrogen (N)	mg/L	0.290	0.020	C328661				0.302	0.451	0.020	C328661
RDL = Reportable Detection Limit Lab-Dup = Laboratory Initiated Duplicate											



RESULTS OF CHEMICAL ANALYSES OF WATER

Bureau Veritas ID		EHJ250			EHJ250		
Sampling Date		2026/06/22 08:30			2026/06/22 08:30		
COC Number		133306			133306		
	UNITS	Q04	RDL	QC Batch	Q04 Lab-Dup	RDL	QC Batch
ANIONS							
Nitrite (N)	mg/L	ND	0.0050	C327175			
Calculated Parameters							
Total Chromium III	mg/L	ND	0.00099	C326243			
Dissolved Hardness (CaCO ₃)	mg/L	26.3	0.50	C326040			
Total Hardness (CaCO ₃)	mg/L	27.4	0.50	C326037			
Nitrate (N)	mg/L	0.043	0.020	C326251			
Field Parameters							
Field pH	pH	7.60	N/A	ONSITE			
Field Temperature	°C	14.4	N/A	ONSITE			
Misc. Inorganics							
pH	pH	7.05	N/A	C327474			
Total Organic Carbon (C)	mg/L	1.5	0.50	C329351			
Total Dissolved Solids	mg/L	48	10	C327466			
Total Suspended Solids	mg/L	2.0	1.0	C327479			
Lab Filtered Inorganics							
Dissolved Organic Carbon (C)	mg/L	1.5	0.50	C327286			
Anions							
Alkalinity (PP as CaCO ₃)	mg/L	ND	1.0	C327467			
Alkalinity (Total as CaCO ₃)	mg/L	31	1.0	C327467			
Bicarbonate (HCO ₃)	mg/L	38	1.0	C327467			
Carbonate (CO ₃)	mg/L	ND	1.0	C327467			
Fluoride (F)	mg/L	ND	0.050	C328741			
Hydroxide (OH)	mg/L	ND	1.0	C327467			
Chloride (Cl)	mg/L	ND	1.0	C327333			
Sulphate (SO ₄)	mg/L	2.6	1.0	C327333			
Metals							
Total Hex. Chromium (Cr 6+)	mg/L	ND	0.00099	C332140			
RDL = Reportable Detection Limit Lab-Dup = Laboratory Initiated Duplicate ND = Not Detected at a concentration equal or greater than the indicated Detection Limit. N/A = Not Applicable							



Bureau Veritas Job #: C637815
Report Date: 2026/07/02

HATFIELD CONSULTANTS
Client Project #: FORTIS11234/PE110163
Site Location: WOODFIBRE PIPELINE PROJECT
Your P.O. #: 4800010213

RESULTS OF CHEMICAL ANALYSES OF WATER

Bureau Veritas ID		EHJ250			EHJ250		
Sampling Date		2026/06/22 08:30			2026/06/22 08:30		
COC Number		133306			133306		
	UNITS	Q04	RDL	QC Batch	Q04 Lab-Dup	RDL	QC Batch
Nutrients							
Total Ammonia (N)	mg/L	ND	0.015	C326337			
Total Phosphorus (P)	mg/L	0.0031	0.0010	C330916			
Nitrate plus Nitrite (N)	mg/L	0.043	0.020	C327173			
Total Nitrogen (N)	mg/L	0.110	0.020	C328661	0.105	0.020	C328661
RDL = Reportable Detection Limit Lab-Dup = Laboratory Initiated Duplicate ND = Not Detected at a concentration equal or greater than the indicated Detection Limit.							



Bureau Veritas Job #: C637815
Report Date: 2026/07/02

HATFIELD CONSULTANTS
Client Project #: FORTIS11234/PE110163
Site Location: WOODFIBRE PIPELINE PROJECT
Your P.O. #: 4800010213

MERCURY BY COLD VAPOR (WATER)

Bureau Veritas ID		EHJ247			EHJ247			EHJ248	EHJ249		
Sampling Date		2026/06/22 08:30			2026/06/22 08:30			2026/06/22 08:30	2026/06/22 08:30		
COC Number		133306			133306			133306	133306		
	UNITS	Q01	RDL	QC Batch	Q01 Lab-Dup	RDL	QC Batch	Q02	Q03	RDL	QC Batch
Elements											
Total Mercury (Hg)	ug/L	ND	0.0019	C327270				ND	0.0022	0.0019	C327270
Lab Filtered Elements											
Dissolved Mercury (Hg)	ug/L	ND	0.0019	C327785	ND	0.0019	C327785	ND	ND	0.0019	C327785
RDL = Reportable Detection Limit Lab-Dup = Laboratory Initiated Duplicate ND = Not Detected at a concentration equal or greater than the indicated Detection Limit.											

Bureau Veritas ID		EHJ250		
Sampling Date		2026/06/22 08:30		
COC Number		133306		
	UNITS	Q04	RDL	QC Batch
Elements				
Total Mercury (Hg)	ug/L	ND	0.0019	C327270
Lab Filtered Elements				
Dissolved Mercury (Hg)	ug/L	ND	0.0019	C327785
RDL = Reportable Detection Limit ND = Not Detected at a concentration equal or greater than the indicated Detection Limit.				



Bureau Veritas Job #: C637815
Report Date: 2026/07/02

HATFIELD CONSULTANTS
Client Project #: FORTIS11234/PE110163
Site Location: WOODFIBRE PIPELINE PROJECT
Your P.O. #: 4800010213

ELEMENTS BY ATOMIC SPECTROSCOPY (WATER)

Bureau Veritas ID		EHJ247			EHJ247			EHJ248	EHJ249		
Sampling Date		2026/06/22 08:30			2026/06/22 08:30			2026/06/22 08:30	2026/06/22 08:30		
COC Number		133306			133306			133306	133306		
	UNITS	Q01	RDL	QC Batch	Q01 Lab-Dup	RDL	QC Batch	Q02	Q03	RDL	QC Batch

ANIONS											
Bromide (Br)	mg/L	0.069	0.010	C330924	0.068	0.010	C330924	0.086	0.135	0.010	C330924
Dissolved Metals by ICPMS											
Dissolved Calcium (Ca)	mg/L	13.5	0.050	C325676				22.8	19.5	0.050	C325676
Dissolved Magnesium (Mg)	mg/L	0.847	0.050	C325676				1.24	1.73	0.050	C325676
Dissolved Potassium (K)	mg/L	0.628	0.050	C325676				1.66	2.54	0.050	C325676
Dissolved Sodium (Na)	mg/L	2.11	0.050	C325676				6.17	10.2	0.050	C325676
Dissolved Sulphur (S)	mg/L	ND	3.0	C325676				3.1	ND	3.0	C325676
Lab Filtered Metals											
Dissolved Aluminum (Al)	ug/L	19.2	0.50	C328528				6.35	6.85	0.50	C328528
Dissolved Antimony (Sb)	ug/L	0.025	0.020	C328528				0.042	0.039	0.020	C328528
Dissolved Arsenic (As)	ug/L	0.084	0.020	C328528				0.049	0.090	0.020	C328528
Dissolved Barium (Ba)	ug/L	14.9	0.020	C328528				17.5	25.6	0.020	C328528
Dissolved Beryllium (Be)	ug/L	ND	0.010	C328528				ND	ND	0.010	C328528
Dissolved Bismuth (Bi)	ug/L	ND	0.0050	C328528				ND	ND	0.0050	C328528
Dissolved Boron (B)	ug/L	ND	10	C328528				11	12	10	C328528
Dissolved Cadmium (Cd)	ug/L	0.0101	0.0050	C328528				0.0191	0.0059	0.0050	C328528
Dissolved Cesium (Cs)	ug/L	ND	0.050	C328528				ND	0.066	0.050	C328528
Dissolved Chromium (Cr)	ug/L	ND	0.10	C328528				ND	ND	0.10	C328528
Dissolved Cobalt (Co)	ug/L	0.596	0.0050	C328528				0.724	1.47	0.0050	C328528
Dissolved Copper (Cu)	ug/L	0.450	0.050	C328528				0.357	0.207	0.050	C328528
Dissolved Iron (Fe)	ug/L	296	1.0	C328528				124	439	1.0	C328528
Dissolved Lead (Pb)	ug/L	0.0167	0.0050	C328528				ND	ND	0.0050	C328528
Dissolved Lithium (Li)	ug/L	ND	0.50	C328528				0.98	1.14	0.50	C328528
Dissolved Manganese (Mn)	ug/L	368	0.050	C328528				290	525	0.050	C328528
Dissolved Molybdenum (Mo)	ug/L	0.734	0.050	C328528				0.910	0.827	0.050	C328528
Dissolved Nickel (Ni)	ug/L	0.320	0.020	C328528				0.497	0.543	0.020	C328528
Dissolved Phosphorus (P)	ug/L	2.9	2.0	C328528				2.6	2.1	2.0	C328528
Dissolved Rubidium (Rb)	ug/L	1.47	0.050	C328528				2.80	4.85	0.050	C328528
Dissolved Selenium (Se)	ug/L	ND	0.040	C328528				ND	ND	0.040	C328528
Dissolved Silicon (Si)	ug/L	3490	50	C328528				4420	5540	50	C328528

RDL = Reportable Detection Limit

Lab-Dup = Laboratory Initiated Duplicate

ND = Not Detected at a concentration equal or greater than the indicated Detection Limit.



Bureau Veritas Job #: C637815
Report Date: 2026/07/02

HATFIELD CONSULTANTS
Client Project #: FORTIS11234/PE110163
Site Location: WOODFIBRE PIPELINE PROJECT
Your P.O. #: 4800010213

ELEMENTS BY ATOMIC SPECTROSCOPY (WATER)

Bureau Veritas ID		EHJ247			EHJ247			EHJ248	EHJ249		
Sampling Date		2026/06/22 08:30			2026/06/22 08:30			2026/06/22 08:30	2026/06/22 08:30		
COC Number		133306			133306			133306	133306		
	UNITS	Q01	RDL	QC Batch	Q01 Lab-Dup	RDL	QC Batch	Q02	Q03	RDL	QC Batch
Dissolved Silver (Ag)	ug/L	ND	0.0050	C328528				ND	ND	0.0050	C328528
Dissolved Strontium (Sr)	ug/L	48.6	0.050	C328528				87.6	74.9	0.050	C328528
Dissolved Tellurium (Te)	ug/L	ND	0.020	C328528				ND	ND	0.020	C328528
Dissolved Thallium (Tl)	ug/L	0.0035	0.0020	C328528				0.0077	0.0054	0.0020	C328528
Dissolved Thorium (Th)	ug/L	0.0054	0.0050	C328528				ND	0.0076	0.0050	C328528
Dissolved Tin (Sn)	ug/L	ND	0.20	C328528				ND	ND	0.20	C328528
Dissolved Titanium (Ti)	ug/L	ND	0.50	C328528				ND	ND	0.50	C328528
Dissolved Uranium (U)	ug/L	0.120	0.0020	C328528				0.669	0.248	0.0020	C328528
Dissolved Vanadium (V)	ug/L	ND	0.20	C328528				ND	ND	0.20	C328528
Dissolved Zinc (Zn)	ug/L	1.45	0.10	C328528				3.49	1.14	0.10	C328528
Dissolved Zirconium (Zr)	ug/L	ND	0.10	C328528				ND	ND	0.10	C328528
Total Metals by ICPMS											
Total Aluminum (Al)	ug/L	36.6	0.50	C329213	35.1	0.50	C329213	15.0	105	3.0	C329777
Total Antimony (Sb)	ug/L	0.026	0.020	C329213	0.024	0.020	C329213	0.051	0.072	0.020	C329777
Total Arsenic (As)	ug/L	0.097	0.020	C329213	0.101	0.020	C329213	0.054	0.127	0.020	C329777
Total Barium (Ba)	ug/L	14.8	0.020	C329213	14.9	0.020	C329213	17.4	28.0	0.050	C329777
Total Beryllium (Be)	ug/L	ND	0.010	C329213	ND	0.010	C329213	ND	ND	0.010	C329777
Total Bismuth (Bi)	ug/L	ND	0.0050	C329213	ND	0.0050	C329213	ND	ND	0.010	C329777
Total Boron (B)	ug/L	ND	10	C329213	ND	10	C329213	12	12	10	C329777
Total Cadmium (Cd)	ug/L	0.0080	0.0050	C329213	0.0111	0.0050	C329213	0.0182	0.0063	0.0050	C329777
Total Cesium (Cs)	ug/L	ND	0.050	C329213	ND	0.050	C329213	ND	0.079	0.050	C329777
Total Chromium (Cr)	ug/L	ND	0.10	C329213	ND	0.10	C329213	ND	0.14	0.10	C329777
Total Cobalt (Co)	ug/L	0.695	0.0050	C329213	0.677	0.0050	C329213	0.745	1.71	0.010	C329777
Total Copper (Cu)	ug/L	0.449	0.050	C329213	0.441	0.050	C329213	0.41	0.73	0.10	C329777
Total Iron (Fe)	ug/L	618	1.0	C329213	616	1.0	C329213	363	2580	5.0	C329777
Total Lead (Pb)	ug/L	0.0234	0.0050	C329213	0.0230	0.0050	C329213	ND	0.053	0.020	C329777
Total Lithium (Li)	ug/L	ND	0.50	C329213	ND	0.50	C329213	1.07	1.23	0.50	C329777
Total Manganese (Mn)	ug/L	380	0.050	C329213	382	0.050	C329213	279	539	0.10	C329777
Total Molybdenum (Mo)	ug/L	0.752	0.050	C329213	0.780	0.050	C329213	0.976	1.05	0.050	C329777
Total Nickel (Ni)	ug/L	0.340	0.020	C329213	0.322	0.020	C329213	0.47	0.71	0.10	C329777
Total Phosphorus (P)	ug/L	2.4	2.0	C329213	2.7	2.0	C329213	ND	5.3	5.0	C329777
RDL = Reportable Detection Limit											
Lab-Dup = Laboratory Initiated Duplicate											
ND = Not Detected at a concentration equal or greater than the indicated Detection Limit.											



Bureau Veritas Job #: C637815

Report Date: 2026/07/02

HATFIELD CONSULTANTS

Client Project #: FORTIS11234/PE110163

Site Location: WOODFIBRE PIPELINE PROJECT

Your P.O. #: 4800010213

ELEMENTS BY ATOMIC SPECTROSCOPY (WATER)

Bureau Veritas ID		EHJ247			EHJ247			EHJ248	EHJ249		
Sampling Date		2026/06/22 08:30			2026/06/22 08:30			2026/06/22 08:30	2026/06/22 08:30		
COC Number		133306			133306			133306	133306		
	UNITS	Q01	RDL	QC Batch	Q01 Lab-Dup	RDL	QC Batch	Q02	Q03	RDL	QC Batch
Total Rubidium (Rb)	ug/L	1.52	0.050	C329213	1.52	0.050	C329213	2.72	5.09	0.050	C329777
Total Selenium (Se)	ug/L	ND	0.040	C329213	ND	0.040	C329213	ND	ND	0.040	C329777
Total Silicon (Si)	ug/L	3620	50	C329213	3630	50	C329213	4440	6140	50	C329777
Total Silver (Ag)	ug/L	ND	0.0050	C329213	ND	0.0050	C329213	ND	ND	0.010	C329777
Total Strontium (Sr)	ug/L	51.8	0.050	C329213	51.5	0.050	C329213	90.6	82.7	0.050	C329777
Total Tellurium (Te)	ug/L	ND	0.020	C329213	ND	0.020	C329213	ND	ND	0.020	C329777
Total Thallium (Tl)	ug/L	0.0038	0.0020	C329213	0.0039	0.0020	C329213	0.0072	0.0056	0.0020	C329777
Total Thorium (Th)	ug/L	ND	0.050	C329213	ND	0.050	C329213	ND	ND	0.050	C329777
Total Tin (Sn)	ug/L	ND	0.20	C329213	ND	0.20	C329213	ND	ND	0.20	C329777
Total Titanium (Ti)	ug/L	0.84	0.50	C329213	0.82	0.50	C329213	ND	2.4	2.0	C329777
Total Uranium (U)	ug/L	0.140	0.0020	C329213	0.137	0.0020	C329213	0.727	0.350	0.0050	C329777
Total Vanadium (V)	ug/L	ND	0.20	C329213	ND	0.20	C329213	ND	0.26	0.20	C329777
Total Zinc (Zn)	ug/L	1.67	0.10	C329213	1.62	0.10	C329213	3.6	2.7	1.0	C329777
Total Zirconium (Zr)	ug/L	ND	0.10	C329213	ND	0.10	C329213	ND	ND	0.10	C329777
Total Calcium (Ca)	mg/L	13.5	0.050	C325678				22.6	20.3	0.25	C325678
Total Magnesium (Mg)	mg/L	0.894	0.050	C325678				1.27	1.83	0.25	C325678
Total Potassium (K)	mg/L	0.633	0.050	C325678				1.61	2.56	0.25	C325678
Total Sodium (Na)	mg/L	2.20	0.050	C325678				6.33	10.6	0.25	C325678
Total Sulphur (S)	mg/L	ND	3.0	C325678				ND	ND	3.0	C325678

RDL = Reportable Detection Limit

Lab-Dup = Laboratory Initiated Duplicate

ND = Not Detected at a concentration equal or greater than the indicated Detection Limit.



ELEMENTS BY ATOMIC SPECTROSCOPY (WATER)

Bureau Veritas ID		EHJ250		
Sampling Date		2026/06/22 08:30		
COC Number		133306		
	UNITS	Q04	RDL	QC Batch
ANIONS				
Bromide (Br)	mg/L	0.027	0.010	C330924
Dissolved Metals by ICPMS				
Dissolved Calcium (Ca)	mg/L	9.56	0.050	C325676
Dissolved Magnesium (Mg)	mg/L	0.602	0.050	C325676
Dissolved Potassium (K)	mg/L	0.562	0.050	C325676
Dissolved Sodium (Na)	mg/L	2.49	0.050	C325676
Dissolved Sulphur (S)	mg/L	ND	3.0	C325676
Lab Filtered Metals				
Dissolved Aluminum (Al)	ug/L	18.7	0.50	C328528
Dissolved Antimony (Sb)	ug/L	0.043	0.020	C328528
Dissolved Arsenic (As)	ug/L	0.080	0.020	C328528
Dissolved Barium (Ba)	ug/L	9.95	0.020	C328528
Dissolved Beryllium (Be)	ug/L	ND	0.010	C328528
Dissolved Bismuth (Bi)	ug/L	ND	0.0050	C328528
Dissolved Boron (B)	ug/L	ND	10	C328528
Dissolved Cadmium (Cd)	ug/L	ND	0.0050	C328528
Dissolved Cesium (Cs)	ug/L	ND	0.050	C328528
Dissolved Chromium (Cr)	ug/L	ND	0.10	C328528
Dissolved Cobalt (Co)	ug/L	0.0086	0.0050	C328528
Dissolved Copper (Cu)	ug/L	0.399	0.050	C328528
Dissolved Iron (Fe)	ug/L	11.4	1.0	C328528
Dissolved Lead (Pb)	ug/L	0.0061	0.0050	C328528
Dissolved Lithium (Li)	ug/L	ND	0.50	C328528
Dissolved Manganese (Mn)	ug/L	0.253	0.050	C328528
Dissolved Molybdenum (Mo)	ug/L	1.49	0.050	C328528
Dissolved Nickel (Ni)	ug/L	0.087	0.020	C328528
Dissolved Phosphorus (P)	ug/L	2.1	2.0	C328528
Dissolved Rubidium (Rb)	ug/L	1.28	0.050	C328528
Dissolved Selenium (Se)	ug/L	ND	0.040	C328528
Dissolved Silicon (Si)	ug/L	4170	50	C328528
RDL = Reportable Detection Limit ND = Not Detected at a concentration equal or greater than the indicated Detection Limit.				



ELEMENTS BY ATOMIC SPECTROSCOPY (WATER)

Bureau Veritas ID		EHJ250		
Sampling Date		2026/06/22 08:30		
COC Number		133306		
	UNITS	Q04	RDL	QC Batch
Dissolved Silver (Ag)	ug/L	ND	0.0050	C328528
Dissolved Strontium (Sr)	ug/L	37.0	0.050	C328528
Dissolved Tellurium (Te)	ug/L	ND	0.020	C328528
Dissolved Thallium (Tl)	ug/L	0.0039	0.0020	C328528
Dissolved Thorium (Th)	ug/L	0.0055	0.0050	C328528
Dissolved Tin (Sn)	ug/L	ND	0.20	C328528
Dissolved Titanium (Ti)	ug/L	ND	0.50	C328528
Dissolved Uranium (U)	ug/L	0.107	0.0020	C328528
Dissolved Vanadium (V)	ug/L	ND	0.20	C328528
Dissolved Zinc (Zn)	ug/L	0.41	0.10	C328528
Dissolved Zirconium (Zr)	ug/L	ND	0.10	C328528
Total Metals by ICPMS				
Total Aluminum (Al)	ug/L	46.3	0.50	C329213
Total Antimony (Sb)	ug/L	0.041	0.020	C329213
Total Arsenic (As)	ug/L	0.080	0.020	C329213
Total Barium (Ba)	ug/L	10.3	0.020	C329213
Total Beryllium (Be)	ug/L	ND	0.010	C329213
Total Bismuth (Bi)	ug/L	ND	0.0050	C329213
Total Boron (B)	ug/L	ND	10	C329213
Total Cadmium (Cd)	ug/L	ND	0.0050	C329213
Total Cesium (Cs)	ug/L	ND	0.050	C329213
Total Chromium (Cr)	ug/L	ND	0.10	C329213
Total Cobalt (Co)	ug/L	0.0194	0.0050	C329213
Total Copper (Cu)	ug/L	0.429	0.050	C329213
Total Iron (Fe)	ug/L	39.7	1.0	C329213
Total Lead (Pb)	ug/L	0.0220	0.0050	C329213
Total Lithium (Li)	ug/L	ND	0.50	C329213
Total Manganese (Mn)	ug/L	1.31	0.050	C329213
Total Molybdenum (Mo)	ug/L	1.55	0.050	C329213
Total Nickel (Ni)	ug/L	0.141	0.020	C329213
Total Phosphorus (P)	ug/L	2.9	2.0	C329213
RDL = Reportable Detection Limit ND = Not Detected at a concentration equal or greater than the indicated Detection Limit.				



ELEMENTS BY ATOMIC SPECTROSCOPY (WATER)

Bureau Veritas ID		EHJ250		
Sampling Date		2026/06/22 08:30		
COC Number		133306		
	UNITS	Q04	RDL	QC Batch
Total Rubidium (Rb)	ug/L	1.39	0.050	C329213
Total Selenium (Se)	ug/L	ND	0.040	C329213
Total Silicon (Si)	ug/L	4450	50	C329213
Total Silver (Ag)	ug/L	ND	0.0050	C329213
Total Strontium (Sr)	ug/L	40.2	0.050	C329213
Total Tellurium (Te)	ug/L	ND	0.020	C329213
Total Thallium (Tl)	ug/L	0.0035	0.0020	C329213
Total Thorium (Th)	ug/L	ND	0.050	C329213
Total Tin (Sn)	ug/L	ND	0.20	C329213
Total Titanium (Ti)	ug/L	1.16	0.50	C329213
Total Uranium (U)	ug/L	0.125	0.0020	C329213
Total Vanadium (V)	ug/L	ND	0.20	C329213
Total Zinc (Zn)	ug/L	0.51	0.10	C329213
Total Zirconium (Zr)	ug/L	ND	0.10	C329213
Total Calcium (Ca)	mg/L	9.86	0.050	C325678
Total Magnesium (Mg)	mg/L	0.665	0.050	C325678
Total Potassium (K)	mg/L	0.595	0.050	C325678
Total Sodium (Na)	mg/L	2.74	0.050	C325678
Total Sulphur (S)	mg/L	ND	3.0	C325678
RDL = Reportable Detection Limit ND = Not Detected at a concentration equal or greater than the indicated Detection Limit.				



Bureau Veritas Job #: C637815
Report Date: 2026/07/02

HATFIELD CONSULTANTS
Client Project #: FORTIS11234/PE110163
Site Location: WOODFIBRE PIPELINE PROJECT
Your P.O. #: 4800010213

GENERAL COMMENTS

Results relate only to the items tested.



Bureau Veritas Job #: C637815
Report Date: 2026/07/02

HATFIELD CONSULTANTS
Client Project #: FORTIS11234/PE110163
Site Location: WOODFIBRE PIPELINE PROJECT
Your P.O. #: 4800010213

QUALITY ASSURANCE REPORT

QA/QC Batch	Init	QC Type	Parameter	Date Analyzed	Value	Recovery	UNITS	QC Limits
C326337	TSO	Matrix Spike [EHJ247-10]	Total Ammonia (N)	2026/06/24		104	%	80 - 120
C326337	TSO	Spiked Blank	Total Ammonia (N)	2026/06/24		103	%	80 - 120
C326337	TSO	Method Blank	Total Ammonia (N)	2026/06/24	ND, RDL=0.015		mg/L	
C326337	TSO	RPD [EHJ247-10]	Total Ammonia (N)	2026/06/24	1.2		%	20
C327173	RLZ	Matrix Spike	Nitrate plus Nitrite (N)	2026/06/25		112	%	80 - 120
C327173	RLZ	Spiked Blank	Nitrate plus Nitrite (N)	2026/06/25		109	%	80 - 120
C327173	RLZ	Method Blank	Nitrate plus Nitrite (N)	2026/06/25	ND, RDL=0.020		mg/L	
C327173	RLZ	RPD	Nitrate plus Nitrite (N)	2026/06/25	NC		%	20
C327175	RLZ	Matrix Spike	Nitrite (N)	2026/06/25		108	%	80 - 120
C327175	RLZ	Spiked Blank	Nitrite (N)	2026/06/25		106	%	80 - 120
C327175	RLZ	Method Blank	Nitrite (N)	2026/06/25	ND, RDL=0.0050		mg/L	
C327175	RLZ	RPD	Nitrite (N)	2026/06/25	NC		%	20
C327270	IC4	Matrix Spike	Total Mercury (Hg)	2026/06/25		93	%	80 - 120
C327270	IC4	Spiked Blank	Total Mercury (Hg)	2026/06/25		101	%	80 - 120
C327270	IC4	Method Blank	Total Mercury (Hg)	2026/06/25	ND, RDL=0.0019		ug/L	
C327270	IC4	RPD	Total Mercury (Hg)	2026/06/25	NC		%	20
C327286	CJY	Spiked Blank	Dissolved Organic Carbon (C)	2026/06/25		108	%	80 - 120
C327286	CJY	Method Blank	Dissolved Organic Carbon (C)	2026/06/25	ND, RDL=0.50		mg/L	
C327311	JAV	Matrix Spike [EHJ247-01]	Chloride (Cl)	2026/06/25		107	%	80 - 120
			Sulphate (SO4)	2026/06/25		107	%	80 - 120
C327311	JAV	Spiked Blank	Chloride (Cl)	2026/06/25		98	%	80 - 120
			Sulphate (SO4)	2026/06/25		94	%	80 - 120
C327311	JAV	Method Blank	Chloride (Cl)	2026/06/25	ND, RDL=1.0		mg/L	
			Sulphate (SO4)	2026/06/25	ND, RDL=1.0		mg/L	
C327311	JAV	RPD [EHJ247-01]	Chloride (Cl)	2026/06/25	NC		%	20
			Sulphate (SO4)	2026/06/25	NC		%	20
C327333	JAV	Matrix Spike	Chloride (Cl)	2026/06/25		105	%	80 - 120
			Sulphate (SO4)	2026/06/25		110	%	80 - 120
C327333	JAV	Spiked Blank	Chloride (Cl)	2026/06/25		101	%	80 - 120
			Sulphate (SO4)	2026/06/25		93	%	80 - 120
C327333	JAV	Method Blank	Chloride (Cl)	2026/06/25	ND, RDL=1.0		mg/L	
			Sulphate (SO4)	2026/06/25	ND, RDL=1.0		mg/L	
C327333	JAV	RPD	Chloride (Cl)	2026/06/25	1.9		%	20
			Sulphate (SO4)	2026/06/25	NC		%	20
C327466	SPP	Matrix Spike [EHJ249-02]	Total Dissolved Solids	2026/06/26		98	%	80 - 120
C327466	SPP	Spiked Blank	Total Dissolved Solids	2026/06/26		98	%	80 - 120
C327466	SPP	Method Blank	Total Dissolved Solids	2026/06/26	ND, RDL=10		mg/L	
C327466	SPP	RPD	Total Dissolved Solids	2026/06/26	4.6		%	20
C327467	BTM	Spiked Blank	Alkalinity (Total as CaCO3)	2026/06/25		95	%	80 - 120
C327467	BTM	Method Blank	Alkalinity (PP as CaCO3)	2026/06/25	ND, RDL=1.0		mg/L	
			Alkalinity (Total as CaCO3)	2026/06/25	ND, RDL=1.0		mg/L	



Bureau Veritas Job #: C637815
Report Date: 2026/07/02

HATFIELD CONSULTANTS
Client Project #: FORTIS11234/PE110163
Site Location: WOODFIBRE PIPELINE PROJECT
Your P.O. #: 4800010213

QUALITY ASSURANCE REPORT(CONT'D)

QA/QC Batch	Init	QC Type	Parameter	Date Analyzed	Value	Recovery	UNITS	QC Limits
C327467	BTM	RPD [EHJ247-01]	Bicarbonate (HCO ₃)	2026/06/25	ND, RDL=1.0		mg/L	
			Carbonate (CO ₃)	2026/06/25	ND, RDL=1.0		mg/L	
			Hydroxide (OH)	2026/06/25	ND, RDL=1.0		mg/L	
			Alkalinity (PP as CaCO ₃)	2026/06/25	NC		%	20
			Alkalinity (Total as CaCO ₃)	2026/06/25	0.33		%	20
			Bicarbonate (HCO ₃)	2026/06/25	0.33		%	20
			Carbonate (CO ₃)	2026/06/25	NC		%	20
C327474	BTM	RPD [EHJ247-01]	Hydroxide (OH)	2026/06/25	NC		%	20
			pH	2026/06/25		100	%	97 - 103
			pH	2026/06/25	0.27		%	N/A
			Total Suspended Solids	2026/06/26		105	%	80 - 120
			Total Suspended Solids	2026/06/26		103	%	80 - 120
			Total Suspended Solids	2026/06/26	ND, RDL=1.0		mg/L	
			Total Suspended Solids	2026/06/26	0		%	20
C327785	IC4	Matrix Spike [EHJ247-11]	Dissolved Mercury (Hg)	2026/06/25		88	%	80 - 120
			Dissolved Mercury (Hg)	2026/06/25		95	%	80 - 120
			Dissolved Mercury (Hg)	2026/06/25	ND, RDL=0.0019		ug/L	
			Dissolved Mercury (Hg)	2026/06/25	NC		%	20
			Nitrate plus Nitrite (N)	2026/06/25		113	%	80 - 120
			Nitrate plus Nitrite (N)	2026/06/25		109	%	80 - 120
			Nitrate plus Nitrite (N)	2026/06/25	ND, RDL=0.020		mg/L	
C327849	RLZ	RPD [EHJ247-01]	Nitrate plus Nitrite (N)	2026/06/25	2.3		%	20
			Nitrite (N)	2026/06/25		113	%	80 - 120
			Nitrite (N)	2026/06/25		105	%	80 - 120
			Nitrite (N)	2026/06/25	ND, RDL=0.0050		mg/L	
			Nitrite (N)	2026/06/25	NC		%	20
			Dissolved Aluminum (Al)	2026/06/26		97	%	80 - 120
			Dissolved Antimony (Sb)	2026/06/26		101	%	80 - 120
C328528	AA1	Matrix Spike	Dissolved Arsenic (As)	2026/06/26		107	%	80 - 120
			Dissolved Barium (Ba)	2026/06/26		95	%	80 - 120
			Dissolved Beryllium (Be)	2026/06/26		90	%	80 - 120
			Dissolved Bismuth (Bi)	2026/06/26		107	%	80 - 120
			Dissolved Boron (B)	2026/06/26		93	%	80 - 120
			Dissolved Cadmium (Cd)	2026/06/26		100	%	80 - 120
			Dissolved Cesium (Cs)	2026/06/26		102	%	80 - 120
			Dissolved Chromium (Cr)	2026/06/26		97	%	80 - 120
			Dissolved Cobalt (Co)	2026/06/26		88	%	80 - 120
			Dissolved Copper (Cu)	2026/06/26		91	%	80 - 120
			Dissolved Iron (Fe)	2026/06/26		102	%	80 - 120
			Dissolved Lead (Pb)	2026/06/26		99	%	80 - 120
			Dissolved Lithium (Li)	2026/06/26		98	%	80 - 120
			Dissolved Manganese (Mn)	2026/06/26		95	%	80 - 120
			Dissolved Molybdenum (Mo)	2026/06/26		NC	%	80 - 120
			Dissolved Nickel (Ni)	2026/06/26		92	%	80 - 120
			Dissolved Phosphorus (P)	2026/06/26		103	%	80 - 120
			Dissolved Rubidium (Rb)	2026/06/26		101	%	80 - 120



Bureau Veritas Job #: C637815
Report Date: 2026/07/02

HATFIELD CONSULTANTS
Client Project #: FORTIS11234/PE110163
Site Location: WOODFIBRE PIPELINE PROJECT
Your P.O. #: 4800010213

QUALITY ASSURANCE REPORT(CONT'D)

QA/QC	Batch	Init	QC Type	Parameter	Date Analyzed	Value	Recovery	UNITS	QC Limits
C328528	AA1	Spiked Blank		Dissolved Selenium (Se)	2026/06/26		103	%	80 - 120
				Dissolved Silicon (Si)	2026/06/26		NC	%	80 - 120
				Dissolved Silver (Ag)	2026/06/26		99	%	80 - 120
				Dissolved Strontium (Sr)	2026/06/26		NC	%	80 - 120
				Dissolved Tellurium (Te)	2026/06/26		105	%	80 - 120
				Dissolved Thallium (Tl)	2026/06/26		107	%	80 - 120
				Dissolved Thorium (Th)	2026/06/26		108	%	80 - 120
				Dissolved Tin (Sn)	2026/06/26		102	%	80 - 120
				Dissolved Titanium (Ti)	2026/06/26		101	%	80 - 120
				Dissolved Uranium (U)	2026/06/26		91	%	80 - 120
				Dissolved Vanadium (V)	2026/06/26		100	%	80 - 120
				Dissolved Zinc (Zn)	2026/06/26		92	%	80 - 120
				Dissolved Zirconium (Zr)	2026/06/26		108	%	80 - 120
				Dissolved Aluminum (Al)	2026/06/26		101	%	80 - 120
				Dissolved Antimony (Sb)	2026/06/26		99	%	80 - 120
				Dissolved Arsenic (As)	2026/06/26		103	%	80 - 120
				Dissolved Barium (Ba)	2026/06/26		100	%	80 - 120
				Dissolved Beryllium (Be)	2026/06/26		93	%	80 - 120
				Dissolved Bismuth (Bi)	2026/06/26		112	%	80 - 120
				Dissolved Boron (B)	2026/06/26		95	%	80 - 120
				Dissolved Cadmium (Cd)	2026/06/26		102	%	80 - 120
				Dissolved Cesium (Cs)	2026/06/26		106	%	80 - 120
				Dissolved Chromium (Cr)	2026/06/26		101	%	80 - 120
				Dissolved Cobalt (Co)	2026/06/26		95	%	80 - 120
				Dissolved Copper (Cu)	2026/06/26		99	%	80 - 120
				Dissolved Iron (Fe)	2026/06/26		103	%	80 - 120
				Dissolved Lead (Pb)	2026/06/26		103	%	80 - 120
				Dissolved Lithium (Li)	2026/06/26		99	%	80 - 120
				Dissolved Manganese (Mn)	2026/06/26		100	%	80 - 120
				Dissolved Molybdenum (Mo)	2026/06/26		103	%	80 - 120
				Dissolved Nickel (Ni)	2026/06/26		101	%	80 - 120
				Dissolved Phosphorus (P)	2026/06/26		99	%	80 - 120
				Dissolved Rubidium (Rb)	2026/06/26		100	%	80 - 120
				Dissolved Selenium (Se)	2026/06/26		100	%	80 - 120
				Dissolved Silicon (Si)	2026/06/26		102	%	80 - 120
				Dissolved Silver (Ag)	2026/06/26		100	%	80 - 120
				Dissolved Strontium (Sr)	2026/06/26		100	%	80 - 120
				Dissolved Tellurium (Te)	2026/06/26		102	%	80 - 120
				Dissolved Thallium (Tl)	2026/06/26		110	%	80 - 120
				Dissolved Thorium (Th)	2026/06/26		105	%	80 - 120
				Dissolved Tin (Sn)	2026/06/26		104	%	80 - 120
				Dissolved Titanium (Ti)	2026/06/26		101	%	80 - 120
				Dissolved Uranium (U)	2026/06/26		91	%	80 - 120
				Dissolved Vanadium (V)	2026/06/26		101	%	80 - 120
				Dissolved Zinc (Zn)	2026/06/26		100	%	80 - 120
				Dissolved Zirconium (Zr)	2026/06/26		103	%	80 - 120
C328528	AA1	Method Blank		Dissolved Aluminum (Al)	2026/06/26	ND, RDL=0.50		ug/L	
				Dissolved Antimony (Sb)	2026/06/26	ND, RDL=0.020		ug/L	
				Dissolved Arsenic (As)	2026/06/26	ND, RDL=0.020		ug/L	



Bureau Veritas Job #: C637815
Report Date: 2026/07/02

HATFIELD CONSULTANTS
Client Project #: FORTIS11234/PE110163
Site Location: WOODFIBRE PIPELINE PROJECT
Your P.O. #: 4800010213

QUALITY ASSURANCE REPORT(CONT'D)

QA/QC Batch	Init	QC Type	Parameter	Date Analyzed	Value	Recovery	UNITS	QC Limits
			Dissolved Barium (Ba)	2026/06/26	ND, RDL=0.020		ug/L	
			Dissolved Beryllium (Be)	2026/06/26	ND, RDL=0.010		ug/L	
			Dissolved Bismuth (Bi)	2026/06/26	ND, RDL=0.0050		ug/L	
			Dissolved Boron (B)	2026/06/26	ND, RDL=10		ug/L	
			Dissolved Cadmium (Cd)	2026/06/26	ND, RDL=0.0050		ug/L	
			Dissolved Cesium (Cs)	2026/06/26	ND, RDL=0.050		ug/L	
			Dissolved Chromium (Cr)	2026/06/26	ND, RDL=0.10		ug/L	
			Dissolved Cobalt (Co)	2026/06/26	ND, RDL=0.0050		ug/L	
			Dissolved Copper (Cu)	2026/06/26	ND, RDL=0.050		ug/L	
			Dissolved Iron (Fe)	2026/06/26	ND, RDL=1.0		ug/L	
			Dissolved Lead (Pb)	2026/06/26	ND, RDL=0.0050		ug/L	
			Dissolved Lithium (Li)	2026/06/26	ND, RDL=0.50		ug/L	
			Dissolved Manganese (Mn)	2026/06/26	0.087, RDL=0.050 (1)		ug/L	
			Dissolved Molybdenum (Mo)	2026/06/26	ND, RDL=0.050		ug/L	
			Dissolved Nickel (Ni)	2026/06/26	ND, RDL=0.020		ug/L	
			Dissolved Phosphorus (P)	2026/06/26	ND, RDL=2.0		ug/L	
			Dissolved Rubidium (Rb)	2026/06/26	ND, RDL=0.050		ug/L	
			Dissolved Selenium (Se)	2026/06/26	ND, RDL=0.040		ug/L	
			Dissolved Silicon (Si)	2026/06/26	ND, RDL=50		ug/L	
			Dissolved Silver (Ag)	2026/06/26	ND, RDL=0.0050		ug/L	
			Dissolved Strontium (Sr)	2026/06/26	ND, RDL=0.050		ug/L	
			Dissolved Tellurium (Te)	2026/06/26	ND, RDL=0.020		ug/L	
			Dissolved Thallium (Tl)	2026/06/26	ND, RDL=0.0020		ug/L	
			Dissolved Thorium (Th)	2026/06/26	ND, RDL=0.0050		ug/L	
			Dissolved Tin (Sn)	2026/06/26	ND, RDL=0.20		ug/L	
			Dissolved Titanium (Ti)	2026/06/26	ND, RDL=0.50		ug/L	
			Dissolved Uranium (U)	2026/06/26	ND, RDL=0.0020		ug/L	



Bureau Veritas Job #: C637815
Report Date: 2026/07/02

HATFIELD CONSULTANTS
Client Project #: FORTIS11234/PE110163
Site Location: WOODFIBRE PIPELINE PROJECT
Your P.O. #: 4800010213

QUALITY ASSURANCE REPORT(CONT'D)

QA/QC Batch	Init	QC Type	Parameter	Date Analyzed	Value	Recovery	UNITS	QC Limits
C328528	AA1	RPD	Dissolved Vanadium (V)	2026/06/26	ND, RDL=0.20		ug/L	
			Dissolved Zinc (Zn)	2026/06/26	ND, RDL=0.10		ug/L	
			Dissolved Zirconium (Zr)	2026/06/26	ND, RDL=0.10		ug/L	
			Dissolved Aluminum (Al)	2026/06/26	NC		%	20
			Dissolved Antimony (Sb)	2026/06/26	0.46		%	20
			Dissolved Arsenic (As)	2026/06/26	1.7		%	20
			Dissolved Barium (Ba)	2026/06/26	0.27		%	20
			Dissolved Beryllium (Be)	2026/06/26	NC		%	20
			Dissolved Bismuth (Bi)	2026/06/26	NC		%	20
			Dissolved Boron (B)	2026/06/26	NC		%	20
			Dissolved Cadmium (Cd)	2026/06/26	NC		%	20
			Dissolved Chromium (Cr)	2026/06/26	12		%	20
			Dissolved Cobalt (Co)	2026/06/26	17		%	20
			Dissolved Copper (Cu)	2026/06/26	1.4		%	20
			Dissolved Iron (Fe)	2026/06/26	NC		%	20
			Dissolved Lead (Pb)	2026/06/26	NC		%	20
			Dissolved Lithium (Li)	2026/06/26	0.59		%	20
			Dissolved Manganese (Mn)	2026/06/26	0.084		%	20
			Dissolved Molybdenum (Mo)	2026/06/26	2.2		%	20
			Dissolved Nickel (Ni)	2026/06/26	7.9		%	20
			Dissolved Phosphorus (P)	2026/06/26	NC		%	20
			Dissolved Selenium (Se)	2026/06/26	2.6		%	20
			Dissolved Silicon (Si)	2026/06/26	0.86		%	20
			Dissolved Silver (Ag)	2026/06/26	NC		%	20
			Dissolved Strontium (Sr)	2026/06/26	0.050		%	20
			Dissolved Thallium (Tl)	2026/06/26	4.9		%	20
			Dissolved Tin (Sn)	2026/06/26	NC		%	20
			Dissolved Titanium (Ti)	2026/06/26	NC		%	20
			Dissolved Uranium (U)	2026/06/26	0.78		%	20
			Dissolved Vanadium (V)	2026/06/26	NC		%	20
			Dissolved Zinc (Zn)	2026/06/26	2.0		%	20
			Dissolved Zirconium (Zr)	2026/06/26	NC		%	20
C328661	TSO	Matrix Spike [EHJ250-09]	Total Nitrogen (N)	2026/06/29		105	%	80 - 120
C328661	TSO	Spiked Blank	Total Nitrogen (N)	2026/06/29		104	%	80 - 120
C328661	TSO	Method Blank	Total Nitrogen (N)	2026/06/29	ND, RDL=0.020		mg/L	
C328661	TSO	RPD [EHJ250-09]	Total Nitrogen (N)	2026/06/29	4.4		%	20
C328741	BTM	Matrix Spike	Dissolved Fluoride (F)	2026/06/26		91	%	80 - 120
C328741	BTM	Spiked Blank	Dissolved Fluoride (F)	2026/06/26		100	%	80 - 120
C328741	BTM	Method Blank	Dissolved Fluoride (F)	2026/06/26	ND, RDL=0.050		mg/L	
C328741	BTM	RPD [EHJ247-01]	Fluoride (F)	2026/06/26	NC		%	20
C329213	AA1	Matrix Spike [EHJ247-05]	Total Aluminum (Al)	2026/06/29		103	%	80 - 120
			Total Antimony (Sb)	2026/06/29		99	%	80 - 120
			Total Arsenic (As)	2026/06/29		104	%	80 - 120
			Total Barium (Ba)	2026/06/29		97	%	80 - 120
			Total Beryllium (Be)	2026/06/29		100	%	80 - 120
			Total Bismuth (Bi)	2026/06/29		95	%	80 - 120
			Total Boron (B)	2026/06/29		99	%	80 - 120
			Total Cadmium (Cd)	2026/06/29		100	%	80 - 120



Bureau Veritas Job #: C637815
Report Date: 2026/07/02

HATFIELD CONSULTANTS
Client Project #: FORTIS11234/PE110163
Site Location: WOODFIBRE PIPELINE PROJECT
Your P.O. #: 4800010213

QUALITY ASSURANCE REPORT(CONT'D)

QA/QC Batch	Init	QC Type	Parameter	Date Analyzed	Value	Recovery	UNITS	QC Limits
C329213	AA1	Spiked Blank	Total Cesium (Cs)	2026/06/29		99	%	80 - 120
			Total Chromium (Cr)	2026/06/29		97	%	80 - 120
			Total Cobalt (Co)	2026/06/29		96	%	80 - 120
			Total Copper (Cu)	2026/06/29		94	%	80 - 120
			Total Iron (Fe)	2026/06/29		NC	%	80 - 120
			Total Lead (Pb)	2026/06/29		94	%	80 - 120
			Total Lithium (Li)	2026/06/29		94	%	80 - 120
			Total Manganese (Mn)	2026/06/29		NC	%	80 - 120
			Total Molybdenum (Mo)	2026/06/29		105	%	80 - 120
			Total Nickel (Ni)	2026/06/29		95	%	80 - 120
			Total Phosphorus (P)	2026/06/29		104	%	80 - 120
			Total Rubidium (Rb)	2026/06/29		103	%	80 - 120
			Total Selenium (Se)	2026/06/29		99	%	80 - 120
			Total Silicon (Si)	2026/06/29		102	%	80 - 120
			Total Silver (Ag)	2026/06/29		99	%	80 - 120
			Total Strontium (Sr)	2026/06/29		NC	%	80 - 120
			Total Tellurium (Te)	2026/06/29		104	%	80 - 120
			Total Thallium (Tl)	2026/06/29		99	%	80 - 120
			Total Thorium (Th)	2026/06/29		99	%	80 - 120
			Total Tin (Sn)	2026/06/29		97	%	80 - 120
			Total Titanium (Ti)	2026/06/29		99	%	80 - 120
			Total Uranium (U)	2026/06/29		97	%	80 - 120
			Total Vanadium (V)	2026/06/29		98	%	80 - 120
			Total Zinc (Zn)	2026/06/29		96	%	80 - 120
			Total Zirconium (Zr)	2026/06/29		103	%	80 - 120
			Total Aluminum (Al)	2026/06/29		104	%	80 - 120
			Total Antimony (Sb)	2026/06/29		100	%	80 - 120
			Total Arsenic (As)	2026/06/29		101	%	80 - 120
			Total Barium (Ba)	2026/06/29		98	%	80 - 120
			Total Beryllium (Be)	2026/06/29		102	%	80 - 120
			Total Bismuth (Bi)	2026/06/29		98	%	80 - 120
			Total Boron (B)	2026/06/29		101	%	80 - 120
			Total Cadmium (Cd)	2026/06/29		99	%	80 - 120
			Total Cesium (Cs)	2026/06/29		100	%	80 - 120
			Total Chromium (Cr)	2026/06/29		99	%	80 - 120
			Total Cobalt (Co)	2026/06/29		99	%	80 - 120
			Total Copper (Cu)	2026/06/29		97	%	80 - 120
			Total Iron (Fe)	2026/06/29		100	%	80 - 120
			Total Lead (Pb)	2026/06/29		95	%	80 - 120
			Total Lithium (Li)	2026/06/29		95	%	80 - 120
			Total Manganese (Mn)	2026/06/29		99	%	80 - 120
			Total Molybdenum (Mo)	2026/06/29		104	%	80 - 120
			Total Nickel (Ni)	2026/06/29		98	%	80 - 120
			Total Phosphorus (P)	2026/06/29		102	%	80 - 120
			Total Rubidium (Rb)	2026/06/29		99	%	80 - 120
			Total Selenium (Se)	2026/06/29		97	%	80 - 120
			Total Silicon (Si)	2026/06/29		105	%	80 - 120
			Total Silver (Ag)	2026/06/29		99	%	80 - 120
			Total Strontium (Sr)	2026/06/29		101	%	80 - 120
			Total Tellurium (Te)	2026/06/29		104	%	80 - 120
			Total Thallium (Tl)	2026/06/29		100	%	80 - 120
			Total Thorium (Th)	2026/06/29		99	%	80 - 120
			Total Tin (Sn)	2026/06/29		100	%	80 - 120



Bureau Veritas Job #: C637815
Report Date: 2026/07/02

HATFIELD CONSULTANTS
Client Project #: FORTIS11234/PE110163
Site Location: WOODFIBRE PIPELINE PROJECT
Your P.O. #: 4800010213

QUALITY ASSURANCE REPORT(CONT'D)

QA/QC Batch	Init	QC Type	Parameter	Date Analyzed	Value	Recovery	UNITS	QC Limits
C329213	AA1	Method Blank	Total Titanium (Ti)	2026/06/29		102	%	80 - 120
			Total Uranium (U)	2026/06/29		98	%	80 - 120
			Total Vanadium (V)	2026/06/29		99	%	80 - 120
			Total Zinc (Zn)	2026/06/29		98	%	80 - 120
			Total Zirconium (Zr)	2026/06/29		101	%	80 - 120
			Total Aluminum (Al)	2026/06/29	ND, RDL=0.50		ug/L	
			Total Antimony (Sb)	2026/06/29	ND, RDL=0.020		ug/L	
			Total Arsenic (As)	2026/06/29	ND, RDL=0.020		ug/L	
			Total Barium (Ba)	2026/06/29	ND, RDL=0.020		ug/L	
			Total Beryllium (Be)	2026/06/29	ND, RDL=0.010		ug/L	
			Total Bismuth (Bi)	2026/06/29	ND, RDL=0.0050		ug/L	
			Total Boron (B)	2026/06/29	ND, RDL=10		ug/L	
			Total Cadmium (Cd)	2026/06/29	ND, RDL=0.0050		ug/L	
			Total Cesium (Cs)	2026/06/29	ND, RDL=0.050		ug/L	
			Total Chromium (Cr)	2026/06/29	ND, RDL=0.10		ug/L	
			Total Cobalt (Co)	2026/06/29	ND, RDL=0.0050		ug/L	
			Total Copper (Cu)	2026/06/29	ND, RDL=0.050		ug/L	
			Total Iron (Fe)	2026/06/29	ND, RDL=1.0		ug/L	
			Total Lead (Pb)	2026/06/29	ND, RDL=0.0050		ug/L	
			Total Lithium (Li)	2026/06/29	ND, RDL=0.50		ug/L	
			Total Manganese (Mn)	2026/06/29	ND, RDL=0.050		ug/L	
			Total Molybdenum (Mo)	2026/06/29	ND, RDL=0.050		ug/L	
			Total Nickel (Ni)	2026/06/29	ND, RDL=0.020		ug/L	
			Total Phosphorus (P)	2026/06/29	ND, RDL=2.0		ug/L	
			Total Rubidium (Rb)	2026/06/29	ND, RDL=0.050		ug/L	
			Total Selenium (Se)	2026/06/29	ND, RDL=0.040		ug/L	
			Total Silicon (Si)	2026/06/29	ND, RDL=50		ug/L	
			Total Silver (Ag)	2026/06/29	ND, RDL=0.0050		ug/L	
			Total Strontium (Sr)	2026/06/29	ND, RDL=0.050		ug/L	



Bureau Veritas Job #: C637815
Report Date: 2026/07/02

HATFIELD CONSULTANTS
Client Project #: FORTIS11234/PE110163
Site Location: WOODFIBRE PIPELINE PROJECT
Your P.O. #: 4800010213

QUALITY ASSURANCE REPORT(CONT'D)

QA/QC Batch	Init	QC Type	Parameter	Date Analyzed	Value	Recovery	UNITS	QC Limits
C329213	AA1	RPD [EHJ247-05]	Total Tellurium (Te)	2026/06/29	ND, RDL=0.020		ug/L	
			Total Thallium (Tl)	2026/06/29	ND, RDL=0.0020		ug/L	
			Total Thorium (Th)	2026/06/29	ND, RDL=0.050		ug/L	
			Total Tin (Sn)	2026/06/29	ND, RDL=0.20		ug/L	
			Total Titanium (Ti)	2026/06/29	ND, RDL=0.50		ug/L	
			Total Uranium (U)	2026/06/29	ND, RDL=0.0020		ug/L	
			Total Vanadium (V)	2026/06/29	ND, RDL=0.20		ug/L	
			Total Zinc (Zn)	2026/06/29	ND, RDL=0.10		ug/L	
			Total Zirconium (Zr)	2026/06/29	ND, RDL=0.10		ug/L	
			Total Aluminum (Al)	2026/06/29	4.3		%	20
			Total Antimony (Sb)	2026/06/29	8.9		%	20
			Total Arsenic (As)	2026/06/29	4.3		%	20
			Total Barium (Ba)	2026/06/29	0.50		%	20
			Total Beryllium (Be)	2026/06/29	NC		%	20
			Total Bismuth (Bi)	2026/06/29	NC		%	20
			Total Boron (B)	2026/06/29	NC		%	20
			Total Cadmium (Cd)	2026/06/29	NC		%	20
			Total Cesium (Cs)	2026/06/29	NC		%	20
			Total Chromium (Cr)	2026/06/29	NC		%	20
			Total Cobalt (Co)	2026/06/29	2.6		%	20
			Total Copper (Cu)	2026/06/29	1.9		%	20
			Total Iron (Fe)	2026/06/29	0.26		%	20
			Total Lead (Pb)	2026/06/29	1.7		%	20
			Total Lithium (Li)	2026/06/29	NC		%	20
			Total Manganese (Mn)	2026/06/29	0.72		%	20
			Total Molybdenum (Mo)	2026/06/29	3.6		%	20
			Total Nickel (Ni)	2026/06/29	5.3		%	20
			Total Phosphorus (P)	2026/06/29	11		%	20
			Total Rubidium (Rb)	2026/06/29	0.25		%	20
			Total Selenium (Se)	2026/06/29	NC		%	20
			Total Silicon (Si)	2026/06/29	0.39		%	20
			Total Silver (Ag)	2026/06/29	NC		%	20
			Total Strontium (Sr)	2026/06/29	0.57		%	20
			Total Tellurium (Te)	2026/06/29	NC		%	20
			Total Thallium (Tl)	2026/06/29	2.6		%	20
			Total Thorium (Th)	2026/06/29	NC		%	20
			Total Tin (Sn)	2026/06/29	NC		%	20
			Total Titanium (Ti)	2026/06/29	2.7		%	20
			Total Uranium (U)	2026/06/29	1.9		%	20
			Total Vanadium (V)	2026/06/29	NC		%	20
			Total Zinc (Zn)	2026/06/29	3.3		%	20
			Total Zirconium (Zr)	2026/06/29	NC		%	20
C329351	CBK	Matrix Spike	Total Organic Carbon (C)	2026/06/26		108	%	80 - 120
C329351	CBK	Spiked Blank	Total Organic Carbon (C)	2026/06/26		99	%	80 - 120



Bureau Veritas Job #: C637815
Report Date: 2026/07/02

HATFIELD CONSULTANTS
Client Project #: FORTIS11234/PE110163
Site Location: WOODFIBRE PIPELINE PROJECT
Your P.O. #: 4800010213

QUALITY ASSURANCE REPORT(CONT'D)

QA/QC Batch	Init	QC Type	Parameter	Date Analyzed	Value	Recovery	UNITS	QC Limits
C329351	CBK	Method Blank	Total Organic Carbon (C)	2026/06/26	ND, RDL=0.50		mg/L	
C329351	CBK	RPD	Total Organic Carbon (C)	2026/06/26	9.2		%	20
C329777	AA1	Matrix Spike	Total Aluminum (Al)	2026/06/29		102	%	80 - 120
			Total Antimony (Sb)	2026/06/29		102	%	80 - 120
			Total Arsenic (As)	2026/06/29		107	%	80 - 120
			Total Barium (Ba)	2026/06/29		NC	%	80 - 120
			Total Beryllium (Be)	2026/06/29		99	%	80 - 120
			Total Bismuth (Bi)	2026/06/29		97	%	80 - 120
			Total Boron (B)	2026/06/29		101	%	80 - 120
			Total Cadmium (Cd)	2026/06/29		102	%	80 - 120
			Total Cesium (Cs)	2026/06/29		103	%	80 - 120
			Total Chromium (Cr)	2026/06/29		98	%	80 - 120
			Total Cobalt (Co)	2026/06/29		95	%	80 - 120
			Total Copper (Cu)	2026/06/29		91	%	80 - 120
			Total Iron (Fe)	2026/06/29		103	%	80 - 120
			Total Lead (Pb)	2026/06/29		97	%	80 - 120
			Total Lithium (Li)	2026/06/29		94	%	80 - 120
			Total Manganese (Mn)	2026/06/29		NC	%	80 - 120
			Total Molybdenum (Mo)	2026/06/29		106	%	80 - 120
			Total Nickel (Ni)	2026/06/29		92	%	80 - 120
			Total Phosphorus (P)	2026/06/29		104	%	80 - 120
			Total Rubidium (Rb)	2026/06/29		106	%	80 - 120
			Total Selenium (Se)	2026/06/29		102	%	80 - 120
			Total Silicon (Si)	2026/06/29		NC	%	80 - 120
			Total Silver (Ag)	2026/06/29		100	%	80 - 120
			Total Strontium (Sr)	2026/06/29		NC	%	80 - 120
			Total Tellurium (Te)	2026/06/29		100	%	80 - 120
			Total Thallium (Tl)	2026/06/29		102	%	80 - 120
			Total Thorium (Th)	2026/06/29		106	%	80 - 120
			Total Tin (Sn)	2026/06/29		105	%	80 - 120
			Total Titanium (Ti)	2026/06/29		101	%	80 - 120
			Total Uranium (U)	2026/06/29		111	%	80 - 120
			Total Vanadium (V)	2026/06/29		101	%	80 - 120
			Total Zinc (Zn)	2026/06/29		94	%	80 - 120
			Total Zirconium (Zr)	2026/06/29		107	%	80 - 120
C329777	AA1	Spiked Blank	Total Aluminum (Al)	2026/06/29		102	%	80 - 120
			Total Antimony (Sb)	2026/06/29		99	%	80 - 120
			Total Arsenic (As)	2026/06/29		102	%	80 - 120
			Total Barium (Ba)	2026/06/29		99	%	80 - 120
			Total Beryllium (Be)	2026/06/29		102	%	80 - 120
			Total Bismuth (Bi)	2026/06/29		98	%	80 - 120
			Total Boron (B)	2026/06/29		101	%	80 - 120
			Total Cadmium (Cd)	2026/06/29		101	%	80 - 120
			Total Cesium (Cs)	2026/06/29		103	%	80 - 120
			Total Chromium (Cr)	2026/06/29		100	%	80 - 120
			Total Cobalt (Co)	2026/06/29		100	%	80 - 120
			Total Copper (Cu)	2026/06/29		98	%	80 - 120
			Total Iron (Fe)	2026/06/29		102	%	80 - 120
			Total Lead (Pb)	2026/06/29		95	%	80 - 120
			Total Lithium (Li)	2026/06/29		100	%	80 - 120
			Total Manganese (Mn)	2026/06/29		99	%	80 - 120
			Total Molybdenum (Mo)	2026/06/29		102	%	80 - 120



QUALITY ASSURANCE REPORT(CONT'D)

QA/QC Batch	Init	QC Type	Parameter	Date Analyzed	Value	Recovery	UNITS	QC Limits
C329777	AA1	Method Blank	Total Nickel (Ni)	2026/06/29		99	%	80 - 120
			Total Phosphorus (P)	2026/06/29		102	%	80 - 120
			Total Rubidium (Rb)	2026/06/29		101	%	80 - 120
			Total Selenium (Se)	2026/06/29		100	%	80 - 120
			Total Silicon (Si)	2026/06/29		106	%	80 - 120
			Total Silver (Ag)	2026/06/29		99	%	80 - 120
			Total Strontium (Sr)	2026/06/29		102	%	80 - 120
			Total Tellurium (Te)	2026/06/29		107	%	80 - 120
			Total Thallium (Tl)	2026/06/29		100	%	80 - 120
			Total Thorium (Th)	2026/06/29		102	%	80 - 120
			Total Tin (Sn)	2026/06/29		99	%	80 - 120
			Total Titanium (Ti)	2026/06/29		103	%	80 - 120
			Total Uranium (U)	2026/06/29		106	%	80 - 120
			Total Vanadium (V)	2026/06/29		100	%	80 - 120
			Total Zinc (Zn)	2026/06/29		100	%	80 - 120
			Total Zirconium (Zr)	2026/06/29		100	%	80 - 120
			Total Aluminum (Al)	2026/06/29	ND, RDL=3.0		ug/L	
			Total Antimony (Sb)	2026/06/29	ND, RDL=0.020		ug/L	
			Total Arsenic (As)	2026/06/29	ND, RDL=0.020		ug/L	
			Total Barium (Ba)	2026/06/29	ND, RDL=0.050		ug/L	
			Total Beryllium (Be)	2026/06/29	ND, RDL=0.010		ug/L	
			Total Bismuth (Bi)	2026/06/29	ND, RDL=0.010		ug/L	
			Total Boron (B)	2026/06/29	ND, RDL=10		ug/L	
			Total Cadmium (Cd)	2026/06/29	ND, RDL=0.0050		ug/L	
			Total Cesium (Cs)	2026/06/29	ND, RDL=0.050		ug/L	
			Total Chromium (Cr)	2026/06/29	ND, RDL=0.10		ug/L	
			Total Cobalt (Co)	2026/06/29	ND, RDL=0.010		ug/L	
			Total Copper (Cu)	2026/06/29	ND, RDL=0.10		ug/L	
			Total Iron (Fe)	2026/06/29	ND, RDL=5.0		ug/L	
			Total Lead (Pb)	2026/06/29	ND, RDL=0.020		ug/L	
			Total Lithium (Li)	2026/06/29	ND, RDL=0.50		ug/L	
			Total Manganese (Mn)	2026/06/29	ND, RDL=0.10		ug/L	
			Total Molybdenum (Mo)	2026/06/29	ND, RDL=0.050		ug/L	
			Total Nickel (Ni)	2026/06/29	ND, RDL=0.10		ug/L	
			Total Phosphorus (P)	2026/06/29	ND, RDL=5.0		ug/L	



Bureau Veritas Job #: C637815
Report Date: 2026/07/02

HATFIELD CONSULTANTS
Client Project #: FORTIS11234/PE110163
Site Location: WOODFIBRE PIPELINE PROJECT
Your P.O. #: 4800010213

QUALITY ASSURANCE REPORT(CONT'D)

QA/QC Batch	Init	QC Type	Parameter	Date Analyzed	Value	Recovery	UNITS	QC Limits
C329777	AA1	RPD	Total Rubidium (Rb)	2026/06/29	ND, RDL=0.050		ug/L	
			Total Selenium (Se)	2026/06/29	ND, RDL=0.040		ug/L	
			Total Silicon (Si)	2026/06/29	ND, RDL=50		ug/L	
			Total Silver (Ag)	2026/06/29	ND, RDL=0.010		ug/L	
			Total Strontium (Sr)	2026/06/29	ND, RDL=0.050		ug/L	
			Total Tellurium (Te)	2026/06/29	ND, RDL=0.020		ug/L	
			Total Thallium (Tl)	2026/06/29	ND, RDL=0.0020		ug/L	
			Total Thorium (Th)	2026/06/29	ND, RDL=0.050		ug/L	
			Total Tin (Sn)	2026/06/29	ND, RDL=0.20		ug/L	
			Total Titanium (Ti)	2026/06/29	ND, RDL=2.0		ug/L	
			Total Uranium (U)	2026/06/29	ND, RDL=0.0050		ug/L	
			Total Vanadium (V)	2026/06/29	ND, RDL=0.20		ug/L	
			Total Zinc (Zn)	2026/06/29	ND, RDL=1.0		ug/L	
			Total Zirconium (Zr)	2026/06/29	ND, RDL=0.10		ug/L	
			Total Aluminum (Al)	2026/06/29	17		%	20
			Total Antimony (Sb)	2026/06/29	11		%	20
			Total Arsenic (As)	2026/06/29	5.4		%	20
			Total Barium (Ba)	2026/06/29	7.6		%	20
			Total Beryllium (Be)	2026/06/29	NC		%	20
			Total Bismuth (Bi)	2026/06/29	NC		%	20
			Total Boron (B)	2026/06/29	7.0		%	20
			Total Cadmium (Cd)	2026/06/29	NC		%	20
			Total Chromium (Cr)	2026/06/29	NC		%	20
			Total Cobalt (Co)	2026/06/29	11		%	20
			Total Copper (Cu)	2026/06/29	0.81		%	20
			Total Iron (Fe)	2026/06/29	NC		%	20
			Total Lead (Pb)	2026/06/29	NC		%	20
			Total Lithium (Li)	2026/06/29	13		%	20
			Total Manganese (Mn)	2026/06/29	7.7		%	20
			Total Molybdenum (Mo)	2026/06/29	5.0		%	20
			Total Nickel (Ni)	2026/06/29	3.0		%	20
			Total Phosphorus (P)	2026/06/29	8.0		%	20
			Total Selenium (Se)	2026/06/29	NC		%	20
			Total Silicon (Si)	2026/06/29	9.3		%	20
			Total Silver (Ag)	2026/06/29	NC		%	20
			Total Strontium (Sr)	2026/06/29	8.8		%	20
			Total Thallium (Tl)	2026/06/29	15		%	20
			Total Tin (Sn)	2026/06/29	NC		%	20
			Total Titanium (Ti)	2026/06/29	NC		%	20



Bureau Veritas Job #: C637815
Report Date: 2026/07/02

HATFIELD CONSULTANTS
Client Project #: FORTIS11234/PE110163
Site Location: WOODFIBRE PIPELINE PROJECT
Your P.O. #: 4800010213

QUALITY ASSURANCE REPORT(CONT'D)

QA/QC Batch	Init	QC Type	Parameter	Date Analyzed	Value	Recovery	UNITS	QC Limits
C330916	KA5	Matrix Spike	Total Uranium (U)	2026/06/29	8.3		%	20
			Total Vanadium (V)	2026/06/29	NC		%	20
			Total Zinc (Zn)	2026/06/29	NC		%	20
			Total Zirconium (Zr)	2026/06/29	NC		%	20
			Total Phosphorus (P)	2026/06/30		107	%	N/A
			Total Phosphorus (P)	2026/06/30		113	%	80 - 120
			Total Phosphorus (P)	2026/06/30	ND, RDL=0.0010		mg/L	
			Total Phosphorus (P)	2026/06/30	0.16		%	20
			Bromide (Br)	2026/06/30		92	%	78 - 120
			Bromide (Br)	2026/06/30		91	%	80 - 120
C330924	MWU	Matrix Spike [EHJ247-01]	Bromide (Br)	2026/06/30	ND, RDL=0.010		mg/L	
C330924	MWU	Spiked Blank	Bromide (Br)	2026/06/30				
C330924	MWU	Method Blank	Bromide (Br)	2026/06/30				
C330924	MWU	RPD [EHJ247-01]	Bromide (Br)	2026/06/30	0.35		%	20
C331266	CJY	Matrix Spike	Total Organic Carbon (C)	2026/06/29		107	%	80 - 120
C331266	CJY	Spiked Blank	Total Organic Carbon (C)	2026/06/29		106	%	80 - 120
C331266	CJY	Method Blank	Total Organic Carbon (C)	2026/06/29	ND, RDL=0.50		mg/L	
C331266	CJY	RPD	Total Organic Carbon (C)	2026/06/29	15		%	20
C332140	JGL	Matrix Spike	Total Hex. Chromium (Cr 6+)	2026/06/30		87	%	80 - 120
C332140	JGL	Spiked Blank	Total Hex. Chromium (Cr 6+)	2026/06/30		113	%	80 - 120
C332140	JGL	Method Blank	Total Hex. Chromium (Cr 6+)	2026/06/30	ND, RDL=0.00099		mg/L	
C332140	JGL	RPD	Total Hex. Chromium (Cr 6+)	2026/06/30	NC		%	20

N/A = Not Applicable

Duplicate: Paired analysis of a separate portion of the same sample. Used to evaluate the variance in the measurement.

Matrix Spike: A sample to which a known amount of the analyte of interest has been added. Used to evaluate sample matrix interference.

Spiked Blank: A blank matrix sample to which a known amount of the analyte, usually from a second source, has been added. Used to evaluate method accuracy.

Method Blank: A blank matrix containing all reagents used in the analytical procedure. Used to identify laboratory contamination.

NC (Matrix Spike): The recovery in the matrix spike was not calculated. The relative difference between the concentration in the parent sample and the spike amount was too small to permit a reliable recovery calculation (matrix spike concentration was less than the native sample concentration)

NC (Duplicate RPD): The duplicate RPD was not calculated. The concentration in the sample and/or duplicate was too low to permit a reliable RPD calculation (absolute difference $\leq 2 \times$ RDL).

(1) Method blank exceeds acceptance limits- 2X RDL acceptable for low level metals determination.



Bureau Veritas Job #: C637815
Report Date: 2026/07/02

HATFIELD CONSULTANTS
Client Project #: FORTIS11234/PE110163
Site Location: WOODFIBRE PIPELINE PROJECT
Your P.O. #: 4800010213

VALIDATION SIGNATURE PAGE

The analytical data and all QC contained in this report were reviewed and validated by:


David Huang, M.Sc., P.Chem., QP, Scientific Services Manager

Levi Manchak, Senior Project Manager

Bureau Veritas has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per ISO/IEC 17025, signing the reports. For Service Group specific validation, please refer to the Validation Signatures page if included, otherwise available by request. For Department specific Analyst/Supervisor validation names, please refer to the Test Summary section if included, otherwise available by request. This report is authorized by Rob Gilbert, BBY General Manager responsible for British Columbia Environmental laboratory operations.



eCOC: W133306



Project Information: C637815
Job Received: 2026/06/23 17:51
Expected TAT: Standard TAT
Expected Arrival: 2026/06/22 14:30
Submitted By: Jackson Macpherson
Submitted To: Burnaby ENV: 4606
Canada Way

Invoice Information

Attn: Accounts Payable
Fortis BC Energy Inc
16705 Fraser Hwy
Surrey , BC , V4N 0E8
Email to:
einvoices@fortisbc.com

Report Information

Attn: Brett Lucas
HATFIELD CONSULTANTS
200-850 Harbourside Dr
North Vancouver , BC , V7P 0A3
Email to:
blucas@hatfieldgroup.com
danielle.samels@fortisbc.com
smangwani@hatfieldgroup.com
jmacpherson@hatfieldgroup.com
swolf@hatfieldgroup.com

Project Information

Quote #: C50083
PO/AFE#: 4800010213
Project #: Fortis11234/PE-110163
Site Location: Woodfibre Pipeline Project

Analytical Summary

A: Standard TAT

Client Sample ID	Clnt Ref	Sampling Date/Time	Matrix	#Cont	Woodfibre Quarry	Total Sulphide	Set Number
Q01	1	2026/06/22 08:30	WATER	14	A	A	1
Q02	2	2026/06/22 08:30	WATER	18	A	A	1
Q03	3	2026/06/22 08:30	WATER	14	A	A	1
Q04	4	2026/06/22 08:30	WATER	14	A	A	1
MLARD01	5	2026/06/22 08:30	WATER	14	A		2

Deadlines are estimates only and are subject to change. Please refer to your Job Confirmation report for final due dates.

Submission Information

of Samples: 5

Sample Set Listing

Set 1 (4 samples)	Set 2 (1 sample)
Q01 Q02 Q03 Q04	MLARD01



Your P.O. #: 4800010213
 Your Project #: FORTIS11234/PE110163
 Site Location: WOODFIBRE PIPELINE PROJECT
 Your C.O.C. #: 133303

Attention: Saeesh Mangwani

HATFIELD CONSULTANTS
 N. VANCOUVER
 200-850 Harbourside Dr
 North Vancouver, BC
 Canada V7P 0A3

Report Date: 2026/07/15
 Report #: R3805526
 Version: 2 - Revision

CERTIFICATE OF ANALYSIS – REVISED REPORT

BUREAU VERITAS JOB #: C637882

Received: 2026/06/23, 17:51

Sample Matrix: Water
 # Samples Received: 3

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Analytical Method
Alkalinity @25C (pp, total), CO ₃ ,HCO ₃ ,OH	3	N/A	2026/06/26	BBY6SOP-00026	SM 24 2320 B m
Chloride/Sulphate by Auto Colourimetry	3	N/A	2026/06/26	BBY6SOP-00011 / BBY6SOP-00017	SM24-4500-Cl/SO ₄ -E m
Chromium III (Calc'd)	3	N/A	2026/07/02		
Total Hexavalent Chromium	3	N/A	2026/06/30	BBY6SOP-00054	SM 24 3500-Cr B m
Carbon (DOC) -Lab Filtered (2)	3	N/A	2026/06/25	BBY6SOP-00053	SM 24 5310 B m
Fluoride	3	N/A	2026/06/26	BBY6SOP-00037	SM 24 4500-F C m
Glycols in Water by GC/FID (1)	1	N/A	2026/06/29	CAL SOP-00093	BCMOE Glycols 09/17
Sulphide (as H ₂ S) (1)	3	N/A	2026/06/30		Auto Calc
Un-ionized Hydrogen Sulphide as S Calc	3	N/A	2026/06/30	BBY WI-00033	Auto Calc
Hardness Total (calculated as CaCO ₃) (3)	3	N/A	2026/06/30	BBY WI-00033	Auto Calc
Hardness (calculated as CaCO ₃)	3	N/A	2026/06/26	BBY WI-00033	Auto Calc
Mercury (Dissolved) by CV-Lab Filtered	3	2026/06/25	2026/06/25	BBY7SOP-00032	BCMOE LMAug2023 C m
Mercury (Total) by CV	2	2026/06/26	2026/06/26	BBY7SOP-00032	BCMOE LMAug2023 C m
Mercury (Total) by CV	1	2026/07/13	2026/07/14	BBY7SOP-00032	BCMOE LMAug2023 C m
Bromide as Bromine (Br) by ICPMS	3	N/A	2026/06/30	BBY7SOP-00002	EPA 6020B R2 m
EPH in Water when PAH required	1	2026/06/25	2026/06/25	BBY8SOP-00029	BCMOE BCLM Sep2017 m
Na, K, Ca, Mg, S by CRC ICPMS (diss.)	3	N/A	2026/06/26	BBY WI-00033	Auto Calc
Elements by ICPMS Low Level (lab filter) (4)	3	N/A	2026/06/26	BBY7SOP-00002	EPA 6020b R2 m
Na, K, Ca, Mg, S by CRC ICPMS (total)	3	N/A	2026/06/30	BBY WI-00033	Auto Calc
Elements by ICPMS Low Level (total)	3	N/A	2026/06/29	BBY7SOP-00002	EPA 6020b R2 m
Nitrogen (Total)	3	N/A	2026/06/29	BBY6SOP-00016	SM 24 4500-N C m
Ammonia-N (Total)	3	N/A	2026/06/24	AB SOP-00007	SM 24 4500 NH ₃ A G m
Nitrate + Nitrite (N)	1	N/A	2026/06/25	BBY6SOP-00010	SM 24 4500-NO ₃ - H m
Nitrate + Nitrite (N)	2	N/A	2026/06/26	BBY6SOP-00010	SM 24 4500-NO ₃ - H m
Nitrite (N) Regular Level Water	1	N/A	2026/06/25	BBY6SOP-00010	SM 24 4500-NO ₂ - m
Nitrite (N) Regular Level Water	2	N/A	2026/06/26	BBY6SOP-00010	SM 24 4500-NO ₂ - m
Nitrogen - Nitrate (as N)	1	N/A	2026/06/26	BBY WI-00033	Auto Calc
Nitrogen - Nitrate (as N)	2	N/A	2026/06/30	BBY WI-00033	Auto Calc
PAH in Water by GC/MS (SIM)	1	2026/06/25	2026/06/25	BBY8SOP-00021	BCMOE BCLM Jul2017m
Total LMW, HMW, Total PAH Calc (5)	1	N/A	2026/06/29	BBY WI-00033	Auto Calc



Your P.O. #: 4800010213
 Your Project #: FORTIS11234/PE110163
 Site Location: WOODFIBRE PIPELINE PROJECT
 Your C.O.C. #: 133303

Attention: Saeesh Mangwani

HATFIELD CONSULTANTS
 N. VANCOUVER
 200-850 Harbourside Dr
 North Vancouver, BC
 Canada V7P 0A3

Report Date: 2026/07/15
 Report #: R3805526
 Version: 2 - Revision

CERTIFICATE OF ANALYSIS – REVISED REPORT

BUREAU VERITAS JOB #: C637882

Received: 2026/06/23, 17:51

Sample Matrix: Water
 # Samples Received: 3

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Analytical Method
pH @25°C (6)	3	N/A	2026/06/26	BBY6SOP-00026	SM 24 4500-H+ B m
Phenols (4-AAP) (1)	1	N/A	2026/06/30	AB SOP-00088	EPA 9066 R0 m
Total Sulphide (1)	3	2026/06/29	2026/06/30	AB SOP-00080	SM 24 4500 S2-A D Fm
Total Dissolved Solids (Filt. Residue)	3	2026/06/25	2026/06/26	BBY6SOP-00033	SM 24 2540 C m
EPH less PAH in Water by GC/FID (7)	1	N/A	2026/06/29	BBY WI-00033	Auto Calc
Carbon (Total Organic) (8)	3	N/A	2026/06/27	BBY6SOP-00053	SM 24 5310 B m
Total Phosphorus Low Level Total	3	2026/06/29	2026/06/30	BBY6SOP-00013	SM 24 4500-P E m
Total Suspended Solids (NFR)	3	2026/06/25	2026/06/26	BBY6SOP-00034	SM 24 2540 D m
Field pH	3	N/A	2026/06/25	Field Test	Field Test
Field Temperature	3	N/A	2026/06/25	Field Test	Field Test
VOCs, VH, F1, LH in Water by HS GC/MS	1	N/A	2026/06/27	BBY8SOP-00009 / BBY8SOP-00011 / BBY8SOP-00012	BCMOE BCLM Jul2017 m
Volatile HC-BTEX (9)	1	N/A	2026/06/29	BBY WI-00033	Auto Calc

Remarks:

Bureau Veritas is accredited to ISO/IEC 17025 for specific parameters on scopes of accreditation. Unless otherwise noted, procedures used by Bureau Veritas are based upon recognized Provincial, Federal or US method compendia such as CCME, EPA, APHA or the Quebec Ministry of Environment.

All work recorded herein has been done in accordance with procedures and practices ordinarily exercised by professionals in Bureau Veritas' profession using accepted testing methodologies, quality assurance and quality control procedures (except where otherwise agreed by the client and Bureau Veritas in writing). All data is in statistical control and has met quality control and method performance criteria unless otherwise noted. All method blanks are reported; unless indicated otherwise, associated sample data are not blank corrected. Where applicable, unless otherwise noted, Measurement Uncertainty has not been accounted for when stating conformity to the referenced standard.

Bureau Veritas liability is limited to the actual cost of the requested analyses, unless otherwise agreed in writing. There is no other warranty expressed or implied. Bureau Veritas has been retained to provide analysis of samples provided by the Client using the testing methodology referenced in this report. Interpretation and use of test results are the sole responsibility of the Client and are not within the scope of services provided by Bureau Veritas, unless otherwise agreed in writing. Bureau Veritas is not responsible for the accuracy or any data impacts, that result from the information provided by the customer or their agent.

Solid sample results, except biota, are based on dry weight unless otherwise indicated. Organic analyses are not recovery corrected except for isotope dilution methods.



Your P.O. #: 4800010213
Your Project #: FORTIS11234/PE110163
Site Location: WOODFIBRE PIPELINE PROJECT
Your C.O.C. #: 133303

Attention: Saeesh Mangwani

HATFIELD CONSULTANTS
N. VANCOUVER
200-850 Harbourside Dr
North Vancouver, BC
Canada V7P 0A3

Report Date: 2026/07/15
Report #: R3805526
Version: 2 - Revision

CERTIFICATE OF ANALYSIS – REVISED REPORT

BUREAU VERITAS JOB #: C637882

Received: 2026/06/23, 17:51

Results relate to samples tested. When sampling is not conducted by Bureau Veritas, results relate to the supplied samples tested.

This Certificate shall not be reproduced except in full, without the written approval of the laboratory.

Reference Method suffix "m" indicates test methods incorporate validated modifications from specific reference methods to improve performance.

* RPDs calculated using raw data. The rounding of final results may result in the apparent difference.

- (1) This test was performed by Bureau Veritas Calgary, 4000 - 19 St. , Calgary, AB, T2E 6P8
- (2) DOC present in the sample should be considered as non-purgeable DOC. Dissolved > Total Imbalance: When applicable, Dissolved and Total results were reviewed and data quality meets acceptable levels unless otherwise noted.
- (3) "Total Hardness" was calculated from Total Ca and Mg concentrations and may be biased high (Hardness, or Dissolved Hardness, calculated from Dissolved Ca and Mg, should be used for compliance if available).
- (4) Samples were filtered and preserved at the lab. Values may not reflect concentrations at the time of sampling.
For Dissolved > Total Imbalance: When applicable, Dissolved and Total results were reviewed and data quality meets acceptable levels unless otherwise noted.
- (5) Total PAHs in Water include: Quinoline, Naphthalene, 1-Methylnaphthalene, 2-Methylnaphthalene, Acenaphthylene, Acenaphthene, Fluorene, Phenanthrene, Anthracene, Acridine, Fluoranthene, Pyrene, Benzo(a)anthracene, Chrysene, Benzo(b,j)fluoranthene, Benzo(k)fluoranthene, Benzo(a)pyrene, Indeno(1,2,3-cd)pyrene, Dibenz(a,h)anthracene, and Benzo(g,h,i)perylene.
- (6) The CCME method requires pH to be analysed within 15 minutes of sampling and therefore field analysis is required for compliance. All Laboratory pH analyses in this report are reported past the CCME holding time. Bureau Veritas endeavours to analyze samples as soon as possible after receipt.
- (7) LEPH = EPH (C10 to C19) - (Acenaphthene + Acridine + Anthracene + Fluorene + Naphthalene + Phenanthrene)
HEPH = EPH (C19 to C32) - (Benzo(a)anthracene + Benzo(a)pyrene + Fluoranthene + Pyrene)
- (8) TOC present in the sample should be considered as non-purgeable TOC.
- (9) VPH = VH - (Benzene + Toluene + Ethylbenzene + m & p-Xylene + o-Xylene + Styrene)

Encryption Key

Please direct all questions regarding this Certificate of Analysis to:

Levi Manchak, Senior Project Manager
Email: Levi.MANCHAK@bureauveritas.com
Phone# (780)862-5634

=====

Bureau Veritas has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per ISO/IEC 17025, signing the reports. For Service Group specific validation, please refer to the Validation Signatures page if included, otherwise available by request. For Department specific Analyst/Supervisor validation names, please refer to the Test Summary section if included, otherwise available by request. This report is authorized by Rob Gilbert, BBY General Manager responsible for British Columbia Environmental laboratory operations.



Bureau Veritas Job #: C637882

Report Date: 2026/07/15

HATFIELD CONSULTANTS

Client Project #: FORTIS11234/PE110163

Site Location: WOODFIBRE PIPELINE PROJECT

Your P.O. #: 4800010213

RESULTS OF CHEMICAL ANALYSES OF WATER

Bureau Veritas ID		EHJ679			EHJ680			EHJ680		
Sampling Date		2026/06/23 08:30			2026/06/23 08:30			2026/06/23 08:30		
COC Number		133303			133303			133303		
	UNITS	WLNG-DS	RDL	QC Batch	WLNG -EOP	RDL	QC Batch	WLNG -EOP Lab-Dup	RDL	QC Batch

ANIONS

Nitrite (N)	mg/L	ND	0.0050	C327628	ND	0.0050	C328376			
-------------	------	----	--------	---------	----	--------	---------	--	--	--

Calculated Parameters

Total Chromium III	mg/L	ND	0.00099	C326243	ND	0.00099	C326243			
Dissolved Hardness (CaCO ₃)	mg/L	57.9	0.50	C326040	58.5	0.50	C326040			
Total Hardness (CaCO ₃)	mg/L	58.1	0.50	C326037	60.8	0.50	C326037			
Nitrate (N)	mg/L	0.066	0.020	C326251	0.063	0.020	C326251			
Sulphide (as H ₂ S)	mg/L	ND	0.0020	C325579	ND	0.0020	C325579			

Field Parameters

Field pH	pH	7.6	N/A	ONSITE	7.4	N/A	ONSITE			
Field Temperature	°C	14.3	N/A	ONSITE	14.8	N/A	ONSITE			

Misc. Inorganics

pH	pH	7.66	N/A	C327529	7.59	N/A	C327529			
Total Organic Carbon (C)	mg/L	0.98	0.50	C329351	1.1	0.50	C329351			
Total Dissolved Solids	mg/L	100	10	C327946	100	10	C327946	110	10	C327946
Total Suspended Solids	mg/L	2.0	1.0	C327499	3.6	1.0	C327499			

Lab Filtered Inorganics

Dissolved Organic Carbon (C)	mg/L	0.66	0.50	C327286	0.83	0.50	C327286			
------------------------------	------	------	------	---------	------	------	---------	--	--	--

Anions

Alkalinity (PP as CaCO ₃)	mg/L	ND	1.0	C327526	ND	1.0	C327526			
Alkalinity (Total as CaCO ₃)	mg/L	48	1.0	C327526	49	1.0	C327526			
Bicarbonate (HCO ₃)	mg/L	59	1.0	C327526	60	1.0	C327526			
Carbonate (CO ₃)	mg/L	ND	1.0	C327526	ND	1.0	C327526			
Fluoride (F)	mg/L	0.33	0.050	C328741	0.32	0.050	C328741			
Hydroxide (OH)	mg/L	ND	1.0	C327526	ND	1.0	C327526			
Total Sulphide	mg/L	ND	0.0018	C330956	ND	0.0018	C330956			
Chloride (Cl)	mg/L	11	1.0	C328274	9.5	1.0	C328274			
Sulphate (SO ₄)	mg/L	14	1.0	C328274	15	1.0	C328274			

RDL = Reportable Detection Limit

Lab-Dup = Laboratory Initiated Duplicate

ND = Not Detected at a concentration equal or greater than the indicated Detection Limit.

N/A = Not Applicable



Bureau Veritas Job #: C637882
Report Date: 2026/07/15

HATFIELD CONSULTANTS
Client Project #: FORTIS11234/PE110163
Site Location: WOODFIBRE PIPELINE PROJECT
Your P.O. #: 4800010213

RESULTS OF CHEMICAL ANALYSES OF WATER

Bureau Veritas ID		EHJ679			EHJ680			EHJ680		
Sampling Date		2026/06/23 08:30			2026/06/23 08:30			2026/06/23 08:30		
COC Number		133303			133303			133303		
	UNITS	WLNG-DS	RDL	QC Batch	WLNG -EOP	RDL	QC Batch	WLNG -EOP Lab-Dup	RDL	QC Batch
Metals										
Total Hex. Chromium (Cr 6+)	mg/L	ND	0.00099	C332140	ND	0.00099	C332140			
Nutrients										
Total Ammonia (N)	mg/L	0.026	0.015	C326337	ND	0.015	C326337			
Total Phosphorus (P)	mg/L	0.0037	0.0010	C330916	0.0039	0.0010	C330916			
Nitrate plus Nitrite (N)	mg/L	0.066	0.020	C327625	0.063	0.020	C328374			
Total Nitrogen (N)	mg/L	0.254	0.020	C328703	0.276	0.020	C328703			
Misc. Organics										
Phenols	mg/L				ND	0.0015	C332057	ND	0.0015	C332057
RDL = Reportable Detection Limit Lab-Dup = Laboratory Initiated Duplicate ND = Not Detected at a concentration equal or greater than the indicated Detection Limit.										



RESULTS OF CHEMICAL ANALYSES OF WATER

Bureau Veritas ID		EHJ681		
Sampling Date		2026/06/23 08:30		
COC Number		133303		
	UNITS	WLNG-US	RDL	QC Batch
ANIONS				
Nitrite (N)	mg/L	ND	0.0050	C328372
Calculated Parameters				
Total Chromium III	mg/L	ND	0.00099	C326243
Dissolved Hardness (CaCO ₃)	mg/L	7.40	0.50	C326040
Total Hardness (CaCO ₃)	mg/L	7.55	0.50	C326037
Nitrate (N)	mg/L	ND	0.020	C326251
Sulphide (as H ₂ S)	mg/L	ND	0.0020	C325579
Field Parameters				
Field pH	pH	7.8	N/A	ONSITE
Field Temperature	°C	15.9	N/A	ONSITE
Misc. Inorganics				
pH	pH	6.67	N/A	C327529
Total Organic Carbon (C)	mg/L	1.5	0.50	C329351
Total Dissolved Solids	mg/L	40	10	C327946
Total Suspended Solids	mg/L	ND	1.0	C327499
Lab Filtered Inorganics				
Dissolved Organic Carbon (C)	mg/L	1.8	0.50	C327286
Anions				
Alkalinity (PP as CaCO ₃)	mg/L	ND	1.0	C327526
Alkalinity (Total as CaCO ₃)	mg/L	7.5	1.0	C327526
Bicarbonate (HCO ₃)	mg/L	9.2	1.0	C327526
Carbonate (CO ₃)	mg/L	ND	1.0	C327526
Fluoride (F)	mg/L	ND	0.050	C328741
Hydroxide (OH)	mg/L	ND	1.0	C327526
Total Sulphide	mg/L	ND	0.0018	C330956
Chloride (Cl)	mg/L	ND	1.0	C328274
Sulphate (SO ₄)	mg/L	2.3	1.0	C328274
RDL = Reportable Detection Limit ND = Not Detected at a concentration equal or greater than the indicated Detection Limit. N/A = Not Applicable				



Bureau Veritas Job #: C637882
Report Date: 2026/07/15

HATFIELD CONSULTANTS
Client Project #: FORTIS11234/PE110163
Site Location: WOODFIBRE PIPELINE PROJECT
Your P.O. #: 4800010213

RESULTS OF CHEMICAL ANALYSES OF WATER

Bureau Veritas ID		EHJ681		
Sampling Date		2026/06/23 08:30		
COC Number		133303		
	UNITS	WLNG-US	RDL	QC Batch
Metals				
Total Hex. Chromium (Cr 6+)	mg/L	ND	0.00099	C332140
Nutrients				
Total Ammonia (N)	mg/L	ND	0.015	C326337
Total Phosphorus (P)	mg/L	0.013	0.0010	C330916
Nitrate plus Nitrite (N)	mg/L	ND	0.020	C328370
Total Nitrogen (N)	mg/L	0.069	0.020	C328703
RDL = Reportable Detection Limit ND = Not Detected at a concentration equal or greater than the indicated Detection Limit.				



Bureau Veritas Job #: C637882
Report Date: 2026/07/15

HATFIELD CONSULTANTS
Client Project #: FORTIS11234/PE110163
Site Location: WOODFIBRE PIPELINE PROJECT
Your P.O. #: 4800010213

GLYCOLS BY GC-FID (WATER)

Bureau Veritas ID		EHJ680		
Sampling Date		2026/06/23 08:30		
COC Number		133303		
	UNITS	WLNG -EOP	RDL	QC Batch
Glycols				
Ethylene Glycol	mg/L	ND	3.0	C331268
Diethylene Glycol	mg/L	ND	5.0	C331268
Triethylene Glycol	mg/L	ND	5.0	C331268
Propylene Glycol	mg/L	ND	5.0	C331268
Surrogate Recovery (%)				
Methyl Sulfone (sur.)	%	98		C331268
RDL = Reportable Detection Limit ND = Not Detected at a concentration equal or greater than the indicated Detection Limit.				



Bureau Veritas Job #: C637882
Report Date: 2026/07/15

HATFIELD CONSULTANTS
Client Project #: FORTIS11234/PE110163
Site Location: WOODFIBRE PIPELINE PROJECT
Your P.O. #: 4800010213

MERCURY BY COLD VAPOR (WATER)

Bureau Veritas ID		EHJ679		EHJ680	EHJ681		
Sampling Date		2026/06/23 08:30		2026/06/23 08:30	2026/06/23 08:30		
COC Number		133303		133303	133303		
	UNITS	WLNG-DS	QC Batch	WLNG -EOP	WLNG-US	RDL	QC Batch
Elements							
Total Mercury (Hg)	ug/L	ND	C343681	ND	ND	0.0019	C327986
Lab Filtered Elements							
Dissolved Mercury (Hg)	ug/L	ND (1)	C327785	ND (1)	ND (1)	0.0019	C327785
RDL = Reportable Detection Limit ND = Not Detected at a concentration equal or greater than the indicated Detection Limit. (1) Sample received was not in compliance with BC CSR sampling requirements for Mercury in water. ND = Not Detected at a concentration equal or greater than the indicated Detection Limit.							



ELEMENTS BY ATOMIC SPECTROSCOPY (WATER)

Bureau Veritas ID		EHJ679	EHJ680	EHJ681		
Sampling Date		2026/06/23 08:30	2026/06/23 08:30	2026/06/23 08:30		
COC Number		133303	133303	133303		
	UNITS	WLNG-DS	WLNG-EOP	WLNG-US	RDL	QC Batch
ANIONS						
Bromide (Br)	mg/L	ND	ND	ND	0.010	C330917
Dissolved Metals by ICPMS						
Dissolved Calcium (Ca)	mg/L	21.4	21.6	2.55	0.050	C325676
Dissolved Magnesium (Mg)	mg/L	1.09	1.09	0.251	0.050	C325676
Dissolved Potassium (K)	mg/L	2.02	2.03	0.166	0.050	C325676
Dissolved Sodium (Na)	mg/L	6.69	6.70	1.66	0.050	C325676
Dissolved Sulphur (S)	mg/L	5.1	4.3	ND	3.0	C325676
Lab Filtered Metals						
Dissolved Aluminum (Al)	ug/L	72.4	50.5	32.1	0.50	C328528
Dissolved Antimony (Sb)	ug/L	0.616	0.630	ND	0.020	C328528
Dissolved Arsenic (As)	ug/L	0.789	0.796	0.107	0.020	C328528
Dissolved Barium (Ba)	ug/L	4.42	4.37	4.20	0.020	C328528
Dissolved Beryllium (Be)	ug/L	ND	ND	ND	0.010	C328528
Dissolved Bismuth (Bi)	ug/L	ND	ND	ND	0.0050	C328528
Dissolved Boron (B)	ug/L	11	11	ND	10	C328528
Dissolved Cadmium (Cd)	ug/L	ND	ND	0.0058	0.0050	C328528
Dissolved Cesium (Cs)	ug/L	ND	ND	ND	0.050	C328528
Dissolved Chromium (Cr)	ug/L	0.12	0.12	ND	0.10	C328528
Dissolved Cobalt (Co)	ug/L	0.0246	0.0317	0.0125	0.0050	C328528
Dissolved Copper (Cu)	ug/L	0.086	0.085	0.510	0.050	C328528
Dissolved Iron (Fe)	ug/L	1.6	ND	23.3	1.0	C328528
Dissolved Lead (Pb)	ug/L	ND	ND	0.0107	0.0050	C328528
Dissolved Lithium (Li)	ug/L	7.53	7.66	ND	0.50	C328528
Dissolved Manganese (Mn)	ug/L	17.8	23.0	0.724	0.050	C328528
Dissolved Molybdenum (Mo)	ug/L	32.0	32.2	0.435	0.050	C328528
Dissolved Nickel (Ni)	ug/L	0.086	0.106	0.202	0.020	C328528
Dissolved Phosphorus (P)	ug/L	4.7	ND	10.6	2.0	C328528
Dissolved Rubidium (Rb)	ug/L	4.00	3.89	0.359	0.050	C328528
Dissolved Selenium (Se)	ug/L	ND	0.042	ND	0.040	C328528
Dissolved Silicon (Si)	ug/L	6730	6600	4440	50	C328528
RDL = Reportable Detection Limit						
ND = Not Detected at a concentration equal or greater than the indicated Detection Limit.						



Bureau Veritas Job #: C637882

Report Date: 2026/07/15

HATFIELD CONSULTANTS

Client Project #: FORTIS11234/PE110163

Site Location: WOODFIBRE PIPELINE PROJECT

Your P.O. #: 4800010213

ELEMENTS BY ATOMIC SPECTROSCOPY (WATER)

Bureau Veritas ID		EHJ679	EHJ680	EHJ681		
Sampling Date		2026/06/23 08:30	2026/06/23 08:30	2026/06/23 08:30		
COC Number		133303	133303	133303		
	UNITS	WLNG-DS	WLNG-EOP	WLNG-US	RDL	QC Batch
Dissolved Silver (Ag)	ug/L	ND	ND	ND	0.0050	C328528
Dissolved Strontium (Sr)	ug/L	44.9	44.9	13.3	0.050	C328528
Dissolved Tellurium (Te)	ug/L	ND	ND	ND	0.020	C328528
Dissolved Thallium (Tl)	ug/L	0.0126	0.0107	0.0022	0.0020	C328528
Dissolved Thorium (Th)	ug/L	ND	0.0061	0.0068	0.0050	C328528
Dissolved Tin (Sn)	ug/L	ND	ND	ND	0.20	C328528
Dissolved Titanium (Ti)	ug/L	ND	ND	ND	0.50	C328528
Dissolved Uranium (U)	ug/L	0.466	0.475	0.0428	0.0020	C328528
Dissolved Vanadium (V)	ug/L	0.22	ND	ND	0.20	C328528
Dissolved Zinc (Zn)	ug/L	0.74	1.31	0.63	0.10	C328528
Dissolved Zirconium (Zr)	ug/L	ND	ND	ND	0.10	C328528
Total Metals by ICPMS						
Total Aluminum (Al)	ug/L	181	268	41.2	0.50	C329213
Total Antimony (Sb)	ug/L	0.644	0.756	ND	0.020	C329213
Total Arsenic (As)	ug/L	0.843	0.891	0.098	0.020	C329213
Total Barium (Ba)	ug/L	4.54	5.43	4.21	0.020	C329213
Total Beryllium (Be)	ug/L	ND	ND	ND	0.010	C329213
Total Bismuth (Bi)	ug/L	ND	ND	ND	0.0050	C329213
Total Boron (B)	ug/L	14	12	ND	10	C329213
Total Cadmium (Cd)	ug/L	ND	ND	0.0056	0.0050	C329213
Total Cesium (Cs)	ug/L	ND	ND	ND	0.050	C329213
Total Chromium (Cr)	ug/L	0.14	0.16	ND	0.10	C329213
Total Cobalt (Co)	ug/L	0.0284	0.0468	0.0240	0.0050	C329213
Total Copper (Cu)	ug/L	0.087	0.179	0.562	0.050	C329213
Total Iron (Fe)	ug/L	14.1	57.3	35.8	1.0	C329213
Total Lead (Pb)	ug/L	0.0086	0.0277	0.0164	0.0050	C329213
Total Lithium (Li)	ug/L	7.42	7.87	ND	0.50	C329213
Total Manganese (Mn)	ug/L	20.1	25.2	1.24	0.050	C329213
Total Molybdenum (Mo)	ug/L	33.1	34.1	0.453	0.050	C329213
Total Nickel (Ni)	ug/L	0.112	0.133	0.229	0.020	C329213
Total Phosphorus (P)	ug/L	4.4	5.8	9.9	2.0	C329213
RDL = Reportable Detection Limit						
ND = Not Detected at a concentration equal or greater than the indicated Detection Limit.						



Bureau Veritas Job #: C637882
Report Date: 2026/07/15

HATFIELD CONSULTANTS
Client Project #: FORTIS11234/PE110163
Site Location: WOODFIBRE PIPELINE PROJECT
Your P.O. #: 4800010213

ELEMENTS BY ATOMIC SPECTROSCOPY (WATER)

Bureau Veritas ID		EHJ679	EHJ680	EHJ681		
Sampling Date		2026/06/23 08:30	2026/06/23 08:30	2026/06/23 08:30		
COC Number		133303	133303	133303		
	UNITS	WLNG-DS	WLNG-EOP	WLNG-US	RDL	QC Batch
Total Rubidium (Rb)	ug/L	4.13	4.32	0.389	0.050	C329213
Total Selenium (Se)	ug/L	0.043	0.049	ND	0.040	C329213
Total Silicon (Si)	ug/L	7040	7050	4680	50	C329213
Total Silver (Ag)	ug/L	ND	ND	ND	0.0050	C329213
Total Strontium (Sr)	ug/L	47.2	48.6	14.7	0.050	C329213
Total Tellurium (Te)	ug/L	ND	ND	ND	0.020	C329213
Total Thallium (Tl)	ug/L	0.0113	0.0113	ND	0.0020	C329213
Total Thorium (Th)	ug/L	ND	ND	ND	0.050	C329213
Total Tin (Sn)	ug/L	ND	ND	ND	0.20	C329213
Total Titanium (Ti)	ug/L	ND	2.30	0.51	0.50	C329213
Total Uranium (U)	ug/L	0.488	0.553	0.0442	0.0020	C329213
Total Vanadium (V)	ug/L	0.20	0.25	ND	0.20	C329213
Total Zinc (Zn)	ug/L	1.42	1.97	0.64	0.10	C329213
Total Zirconium (Zr)	ug/L	ND	ND	ND	0.10	C329213
Total Calcium (Ca)	mg/L	21.4	22.4	2.58	0.050	C325678
Total Magnesium (Mg)	mg/L	1.14	1.18	0.268	0.050	C325678
Total Potassium (K)	mg/L	2.04	2.15	0.172	0.050	C325678
Total Sodium (Na)	mg/L	7.04	7.35	1.75	0.050	C325678
Total Sulphur (S)	mg/L	4.9	5.0	ND	3.0	C325678
RDL = Reportable Detection Limit						
ND = Not Detected at a concentration equal or greater than the indicated Detection Limit.						



Bureau Veritas Job #: C637882
Report Date: 2026/07/15

HATFIELD CONSULTANTS
Client Project #: FORTIS11234/PE110163
Site Location: WOODFIBRE PIPELINE PROJECT
Your P.O. #: 4800010213

MISCELLANEOUS (WATER)

Bureau Veritas ID		EHJ679	EHJ680	EHJ681		
Sampling Date		2026/06/23 08:30	2026/06/23 08:30	2026/06/23 08:30		
COC Number		133303	133303	133303		
	UNITS	WLNG-DS	WLNG -EOP	WLNG-US	RDL	QC Batch
Calculated Parameters						
Total Un-ionized Hydrogen Sulfide as S	mg/L	ND	ND	ND	0.0018	C326245
Total Un-ionized Hydrogen Sulfide as H2S	mg/L	ND	ND	ND	0.0019	C326245
RDL = Reportable Detection Limit ND = Not Detected at a concentration equal or greater than the indicated Detection Limit.						



LEPH & HEPH WITH CSR/CCME PAH IN WATER (WATER)

Bureau Veritas ID		EHJ680		
Sampling Date		2026/06/23 08:30		
COC Number		133303		
	UNITS	WLNG -EOP	RDL	QC Batch
Calculated Parameters				
Low Molecular Weight PAH's	ug/L	ND	0.10	C325075
High Molecular Weight PAH's	ug/L	ND	0.050	C325075
Total PAH	ug/L	ND	0.10	C325075
Polycyclic Aromatics				
Quinoline	ug/L	ND	0.020	C326699
Naphthalene	ug/L	ND	0.10	C326699
1-Methylnaphthalene	ug/L	ND	0.050	C326699
2-Methylnaphthalene	ug/L	ND	0.10	C326699
Acenaphthylene	ug/L	ND	0.050	C326699
Acenaphthene	ug/L	ND	0.050	C326699
Fluorene	ug/L	ND	0.050	C326699
Phenanthrene	ug/L	ND	0.050	C326699
Anthracene	ug/L	ND	0.010	C326699
Acridine	ug/L	ND	0.050	C326699
Fluoranthene	ug/L	ND	0.020	C326699
Pyrene	ug/L	ND	0.020	C326699
Benzo(a)anthracene	ug/L	ND	0.010	C326699
Chrysene	ug/L	ND	0.020	C326699
Benzo(b&j)fluoranthene	ug/L	ND	0.030	C326699
Benzo(k)fluoranthene	ug/L	ND	0.050	C326699
Benzo(a)pyrene	ug/L	ND	0.0050	C326699
Indeno(1,2,3-cd)pyrene	ug/L	ND	0.050	C326699
Dibenz(a,h)anthracene	ug/L	ND	0.0030	C326699
Benzo(g,h,i)perylene	ug/L	ND	0.050	C326699
Calculated Parameters				
LEPH (C10-C19 less PAH)	mg/L	ND	0.20	C325078
HEPH (C19-C32 less PAH)	mg/L	ND	0.20	C325078
Ext. Pet. Hydrocarbon				
EPH (C10-C19)	mg/L	ND	0.20	C326702
EPH (C19-C32)	mg/L	ND	0.20	C326702
RDL = Reportable Detection Limit ND = Not Detected at a concentration equal or greater than the indicated Detection Limit.				



Bureau Veritas Job #: C637882
Report Date: 2026/07/15

HATFIELD CONSULTANTS
Client Project #: FORTIS11234/PE110163
Site Location: WOODFIBRE PIPELINE PROJECT
Your P.O. #: 4800010213

LEPH & HEPH WITH CSR/CCME PAH IN WATER (WATER)

Bureau Veritas ID		EHJ680		
Sampling Date		2026/06/23 08:30		
COC Number		133303		
	UNITS	WLNG -EOP	RDL	QC Batch
Surrogate Recovery (%)				
O-TERPHENYL (sur.)	%	107		C326702
D10-ANTHRACENE (sur.)	%	108		C326699
D8-ACENAPHTHYLENE (sur.)	%	97		C326699
D8-NAPHTHALENE (sur.)	%	86		C326699
TERPHENYL-D14 (sur.)	%	104		C326699
RDL = Reportable Detection Limit				



CSR VOC + VPH IN WATER (WATER)

Bureau Veritas ID		EHJ680		
Sampling Date		2026/06/23 08:30		
COC Number		133303		
	UNITS	WLNG -EOP	RDL	QC Batch
Calculated Parameters				
VPH (VH6 to 10 - BTEX)	ug/L	ND	300	C325079
Volatiles				
VH C6-C10	ug/L	ND	300	C327177
1,1,1,2-tetrachloroethane	ug/L	ND	0.50	C327177
1,1,1-trichloroethane	ug/L	ND	0.50	C327177
1,1,2,2-tetrachloroethane	ug/L	ND	0.50	C327177
1,1,2Trichloro-1,2,2Trifluoroethane	ug/L	ND	2.0	C327177
1,1,2-trichloroethane	ug/L	ND	0.50	C327177
1,1-dichloroethane	ug/L	ND	0.50	C327177
1,1-dichloroethene	ug/L	ND	0.50	C327177
1,2,3-trichlorobenzene	ug/L	ND	2.0	C327177
1,2,4-trichlorobenzene	ug/L	ND	2.0	C327177
1,2-dibromoethane	ug/L	ND	0.20	C327177
1,2-dichlorobenzene	ug/L	ND	0.50	C327177
1,2-dichloroethane	ug/L	ND	0.50	C327177
1,2-dichloropropane	ug/L	ND	0.50	C327177
1,3,5-trimethylbenzene	ug/L	ND	2.0	C327177
1,3-Butadiene	ug/L	ND	0.50	C327177
1,3-dichlorobenzene	ug/L	ND	0.50	C327177
1,3-dichloropropane	ug/L	ND	1.0	C327177
1,4-dichlorobenzene	ug/L	ND	0.50	C327177
Benzene	ug/L	ND	0.40	C327177
Bromobenzene	ug/L	ND	2.0	C327177
Bromodichloromethane	ug/L	ND	1.0	C327177
Bromoform	ug/L	ND	1.0	C327177
Bromomethane	ug/L	ND	1.0	C327177
Carbon tetrachloride	ug/L	ND	0.50	C327177
Chlorobenzene	ug/L	ND	0.50	C327177
Dibromochloromethane	ug/L	ND	1.0	C327177
Chloroethane	ug/L	ND	1.0	C327177
RDL = Reportable Detection Limit ND = Not Detected at a concentration equal or greater than the indicated Detection Limit.				



CSR VOC + VPH IN WATER (WATER)

Bureau Veritas ID		EHJ680		
Sampling Date		2026/06/23 08:30		
COC Number		133303		
	UNITS	WLNG -EOP	RDL	QC Batch
Chloroform	ug/L	ND	1.0	C327177
Chloromethane	ug/L	ND	1.0	C327177
cis-1,2-dichloroethene	ug/L	ND	1.0	C327177
cis-1,3-dichloropropene	ug/L	ND	1.0	C327177
Dichlorodifluoromethane	ug/L	ND	2.0	C327177
Dichloromethane	ug/L	ND	2.0	C327177
Ethylbenzene	ug/L	ND	0.40	C327177
Hexachlorobutadiene	ug/L	ND	0.50	C327177
Isopropylbenzene	ug/L	ND	2.0	C327177
Methyl-tert-butylether (MTBE)	ug/L	ND	4.0	C327177
Styrene	ug/L	ND	0.50	C327177
Tetrachloroethene	ug/L	ND	0.50	C327177
Toluene	ug/L	ND	0.40	C327177
trans-1,2-dichloroethene	ug/L	ND	1.0	C327177
trans-1,3-dichloropropene	ug/L	ND	1.0	C327177
Trichloroethene	ug/L	ND	0.50	C327177
Trichlorofluoromethane	ug/L	ND	4.0	C327177
Vinyl chloride	ug/L	ND	0.50	C327177
m & p-Xylene	ug/L	ND	0.40	C327177
o-Xylene	ug/L	ND	0.40	C327177
Xylenes (Total)	ug/L	ND	0.40	C327177
Surrogate Recovery (%)				
1,4-Difluorobenzene (sur.)	%	107		C327177
4-Bromofluorobenzene (sur.)	%	76		C327177
D4-1,2-Dichloroethane (sur.)	%	108		C327177
RDL = Reportable Detection Limit ND = Not Detected at a concentration equal or greater than the indicated Detection Limit.				



Bureau Veritas Job #: C637882
Report Date: 2026/07/15

HATFIELD CONSULTANTS
Client Project #: FORTIS11234/PE110163
Site Location: WOODFIBRE PIPELINE PROJECT
Your P.O. #: 4800010213

GENERAL COMMENTS

Revision: Report includes revised detection limit for Total Mercury on sample EHJ679/WLNG-DS. Request for re-analysis was received from client on 2026/07/10.

Results relate only to the items tested.



Bureau Veritas Job #: C637882
Report Date: 2026/07/15

HATFIELD CONSULTANTS
Client Project #: FORTIS11234/PE110163
Site Location: WOODFIBRE PIPELINE PROJECT
Your P.O. #: 4800010213

QUALITY ASSURANCE REPORT

QA/QC	Batch	Init	QC Type	Parameter	Date Analyzed	Value	Recovery	UNITS	QC Limits
	C326337	TSO	Matrix Spike	Total Ammonia (N)	2026/06/24		104	%	80 - 120
	C326337	TSO	Spiked Blank	Total Ammonia (N)	2026/06/24		103	%	80 - 120
	C326337	TSO	Method Blank	Total Ammonia (N)	2026/06/24	ND, RDL=0.015		mg/L	
	C326337	TSO	RPD	Total Ammonia (N)	2026/06/24	1.2		%	20
	C326699	JP1	Spiked Blank	D10-ANTHRACENE (sur.)	2026/06/25		102	%	50 - 140
				D8-ACENAPHTHYLENE (sur.)	2026/06/25		94	%	50 - 140
				D8-NAPHTHALENE (sur.)	2026/06/25		77	%	50 - 140
				TERPHENYL-D14 (sur.)	2026/06/25		101	%	50 - 140
				Quinoline	2026/06/25		86	%	50 - 140
				Naphthalene	2026/06/25		68	%	50 - 140
				1-Methylnaphthalene	2026/06/25		69	%	50 - 140
				2-Methylnaphthalene	2026/06/25		68	%	50 - 140
				Acenaphthylene	2026/06/25		79	%	50 - 140
				Acenaphthene	2026/06/25		78	%	50 - 140
				Fluorene	2026/06/25		79	%	50 - 140
				Phenanthrene	2026/06/25		77	%	50 - 140
				Anthracene	2026/06/25		86	%	50 - 140
				Acridine	2026/06/25		107	%	50 - 140
				Fluoranthene	2026/06/25		88	%	50 - 140
				Pyrene	2026/06/25		86	%	50 - 140
				Benzo(a)anthracene	2026/06/25		87	%	50 - 140
				Chrysene	2026/06/25		86	%	50 - 140
				Benzo(b&j)fluoranthene	2026/06/25		87	%	50 - 140
				Benzo(k)fluoranthene	2026/06/25		91	%	50 - 140
				Benzo(a)pyrene	2026/06/25		86	%	50 - 140
				Indeno(1,2,3-cd)pyrene	2026/06/25		87	%	50 - 140
				Dibenz(a,h)anthracene	2026/06/25		88	%	50 - 140
				Benzo(g,h,i)perylene	2026/06/25		89	%	50 - 140
	C326699	JP1	Method Blank	D10-ANTHRACENE (sur.)	2026/06/25		109	%	50 - 140
				D8-ACENAPHTHYLENE (sur.)	2026/06/25		98	%	50 - 140
				D8-NAPHTHALENE (sur.)	2026/06/25		83	%	50 - 140
				TERPHENYL-D14 (sur.)	2026/06/25		108	%	50 - 140
				Quinoline	2026/06/25	ND, RDL=0.020		ug/L	
				Naphthalene	2026/06/25	ND, RDL=0.10		ug/L	
				1-Methylnaphthalene	2026/06/25	ND, RDL=0.050		ug/L	
				2-Methylnaphthalene	2026/06/25	ND, RDL=0.10		ug/L	
				Acenaphthylene	2026/06/25	ND, RDL=0.050		ug/L	
				Acenaphthene	2026/06/25	ND, RDL=0.050		ug/L	
				Fluorene	2026/06/25	ND, RDL=0.050		ug/L	
				Phenanthrene	2026/06/25	ND, RDL=0.050		ug/L	
				Anthracene	2026/06/25	ND, RDL=0.010		ug/L	
				Acridine	2026/06/25	ND, RDL=0.050		ug/L	



Bureau Veritas Job #: C637882
Report Date: 2026/07/15

HATFIELD CONSULTANTS
Client Project #: FORTIS11234/PE110163
Site Location: WOODFIBRE PIPELINE PROJECT
Your P.O. #: 4800010213

QUALITY ASSURANCE REPORT(CONT'D)

QA/QC Batch	Init	QC Type	Parameter	Date Analyzed	Value	Recovery	UNITS	QC Limits
			Fluoranthene	2026/06/25	ND, RDL=0.020		ug/L	
			Pyrene	2026/06/25	ND, RDL=0.020		ug/L	
			Benzo(a)anthracene	2026/06/25	ND, RDL=0.010		ug/L	
			Chrysene	2026/06/25	ND, RDL=0.020		ug/L	
			Benzo(b&j)fluoranthene	2026/06/25	ND, RDL=0.030		ug/L	
			Benzo(k)fluoranthene	2026/06/25	ND, RDL=0.050		ug/L	
			Benzo(a)pyrene	2026/06/25	ND, RDL=0.0050		ug/L	
			Indeno(1,2,3-cd)pyrene	2026/06/25	ND, RDL=0.050		ug/L	
			Dibenz(a,h)anthracene	2026/06/25	ND, RDL=0.0030		ug/L	
			Benzo(g,h,i)perylene	2026/06/25	ND, RDL=0.050		ug/L	
C326702	RYA	Spiked Blank	O-TERPHENYL (sur.)	2026/06/25		108	%	60 - 140
			EPH (C10-C19)	2026/06/25		91	%	70 - 130
			EPH (C19-C32)	2026/06/25		102	%	70 - 130
C326702	RYA	Method Blank	O-TERPHENYL (sur.)	2026/06/25		107	%	60 - 140
			EPH (C10-C19)	2026/06/25	ND, RDL=0.20		mg/L	
			EPH (C19-C32)	2026/06/25	ND, RDL=0.20		mg/L	
C326702	RYA	RPD	EPH (C10-C19)	2026/06/25	NC		%	30
			EPH (C19-C32)	2026/06/25	NC		%	30
C327177	KPA	Matrix Spike	1,4-Difluorobenzene (sur.)	2026/06/26		97	%	50 - 140
			4-Bromofluorobenzene (sur.)	2026/06/26		96	%	50 - 140
			D4-1,2-Dichloroethane (sur.)	2026/06/26		96	%	50 - 140
			1,1,1,2-tetrachloroethane	2026/06/26		85	%	50 - 140
			1,1,1-trichloroethane	2026/06/26		86	%	50 - 140
			1,1,2,2-tetrachloroethane	2026/06/26		88	%	50 - 140
			1,1,2Trichloro-1,2,2Trifluoroethane	2026/06/26		81	%	50 - 140
			1,1,2-trichloroethane	2026/06/26		81	%	50 - 140
			1,1-dichloroethane	2026/06/26		90	%	50 - 140
			1,1-dichloroethene	2026/06/26		95	%	50 - 140
			1,2,3-trichlorobenzene	2026/06/26		83	%	50 - 140
			1,2,4-trichlorobenzene	2026/06/26		81	%	50 - 140
			1,2-dibromoethane	2026/06/26		81	%	50 - 140
			1,2-dichlorobenzene	2026/06/26		91	%	50 - 140
			1,2-dichloroethane	2026/06/26		81	%	50 - 140
			1,2-dichloropropane	2026/06/26		84	%	50 - 140
			1,3,5-trimethylbenzene	2026/06/26		94	%	50 - 140
			1,3-Butadiene	2026/06/26		61	%	50 - 140
			1,3-dichlorobenzene	2026/06/26		94	%	50 - 140
			1,3-dichloropropane	2026/06/26		82	%	50 - 140
			1,4-dichlorobenzene	2026/06/26		97	%	50 - 140
			Benzene	2026/06/26		82	%	50 - 140
			Bromobenzene	2026/06/26		89	%	50 - 140



Bureau Veritas Job #: C637882
Report Date: 2026/07/15

HATFIELD CONSULTANTS
Client Project #: FORTIS11234/PE110163
Site Location: WOODFIBRE PIPELINE PROJECT
Your P.O. #: 4800010213

QUALITY ASSURANCE REPORT(CONT'D)

QA/QC	Batch	Init	QC Type	Parameter	Date Analyzed	Value	Recovery	UNITS	QC Limits
C327177	KPA	Spiked Blank		Bromodichloromethane	2026/06/26		81	%	50 - 140
				Bromoform	2026/06/26		85	%	50 - 140
				Bromomethane	2026/06/26		78	%	50 - 140
				Carbon tetrachloride	2026/06/26		84	%	50 - 140
				Chlorobenzene	2026/06/26		79	%	50 - 140
				Dibromochloromethane	2026/06/26		81	%	50 - 140
				Chloroethane	2026/06/26		87	%	50 - 140
				Chloroform	2026/06/26		81	%	50 - 140
				Chloromethane	2026/06/26		85	%	50 - 140
				cis-1,2-dichloroethene	2026/06/26		80	%	50 - 140
				cis-1,3-dichloropropene	2026/06/26		74	%	50 - 140
				Dichlorodifluoromethane	2026/06/26		96	%	50 - 140
				Dichloromethane	2026/06/26		85	%	50 - 140
				Ethylbenzene	2026/06/26		83	%	50 - 140
				Hexachlorobutadiene	2026/06/26		83	%	50 - 140
				Isopropylbenzene	2026/06/26		83	%	50 - 140
				Methyl-tert-butylether (MTBE)	2026/06/26		70	%	50 - 140
				Styrene	2026/06/26		83	%	50 - 140
				Tetrachloroethene	2026/06/26		78	%	50 - 140
				Toluene	2026/06/26		79	%	50 - 140
				trans-1,2-dichloroethene	2026/06/26		84	%	50 - 140
				trans-1,3-dichloropropene	2026/06/26		70	%	50 - 140
				Trichloroethene	2026/06/26		78	%	50 - 140
				Trichlorofluoromethane	2026/06/26		81	%	50 - 140
				Vinyl chloride	2026/06/26		87	%	50 - 140
				m & p-Xylene	2026/06/26		98	%	50 - 140
				o-Xylene	2026/06/26		87	%	50 - 140
				1,4-Difluorobenzene (sur.)	2026/06/26		101	%	50 - 140
				4-Bromofluorobenzene (sur.)	2026/06/26		103	%	50 - 140
				D4-1,2-Dichloroethane (sur.)	2026/06/26		109	%	50 - 140
				VH C6-C10	2026/06/26		93	%	70 - 130
				1,1,1,2-tetrachloroethane	2026/06/26		96	%	60 - 130
				1,1,1-trichloroethane	2026/06/26		105	%	60 - 130
				1,1,2,2-tetrachloroethane	2026/06/26		100	%	60 - 130
				1,1,2Trichloro-1,2,2Trifluoroethane	2026/06/26		96	%	60 - 130
				1,1,2-trichloroethane	2026/06/26		97	%	60 - 130
				1,1-dichloroethane	2026/06/26		108	%	60 - 130
				1,1-dichloroethene	2026/06/26		108	%	60 - 130
				1,2,3-trichlorobenzene	2026/06/26		97	%	60 - 130
				1,2,4-trichlorobenzene	2026/06/26		93	%	60 - 130
				1,2-dibromoethane	2026/06/26		99	%	60 - 130
				1,2-dichlorobenzene	2026/06/26		105	%	60 - 130
				1,2-dichloroethane	2026/06/26		100	%	60 - 130
				1,2-dichloropropane	2026/06/26		100	%	60 - 130
				1,3,5-trimethylbenzene	2026/06/26		120	%	60 - 130
				1,3-Butadiene	2026/06/26		67	%	50 - 140
				1,3-dichlorobenzene	2026/06/26		107	%	60 - 130
				1,3-dichloropropane	2026/06/26		97	%	60 - 130
				1,4-dichlorobenzene	2026/06/26		103	%	60 - 130
				Benzene	2026/06/26		100	%	60 - 130
				Bromobenzene	2026/06/26		104	%	60 - 130
				Bromodichloromethane	2026/06/26		99	%	60 - 130
				Bromoform	2026/06/26		96	%	60 - 130



Bureau Veritas Job #: C637882
Report Date: 2026/07/15

HATFIELD CONSULTANTS
Client Project #: FORTIS11234/PE110163
Site Location: WOODFIBRE PIPELINE PROJECT
Your P.O. #: 4800010213

QUALITY ASSURANCE REPORT(CONT'D)

QA/QC Batch	Init	QC Type	Parameter	Date Analyzed	Value	Recovery	UNITS	QC Limits
C327177	KPA	Method Blank	Bromomethane	2026/06/26		95	%	50 - 140
			Carbon tetrachloride	2026/06/26		102	%	60 - 130
			Chlorobenzene	2026/06/26		95	%	60 - 130
			Dibromochloromethane	2026/06/26		98	%	60 - 130
			Chloroethane	2026/06/26		99	%	50 - 140
			Chloroform	2026/06/26		99	%	60 - 130
			Chloromethane	2026/06/26		90	%	50 - 140
			cis-1,2-dichloroethene	2026/06/26		97	%	60 - 130
			cis-1,3-dichloropropene	2026/06/26		88	%	50 - 140
			Dichlorodifluoromethane	2026/06/26		104	%	50 - 140
			Dichloromethane	2026/06/26		102	%	60 - 130
			Ethylbenzene	2026/06/26		106	%	60 - 130
			Hexachlorobutadiene	2026/06/26		95	%	60 - 130
			Isopropylbenzene	2026/06/26		101	%	60 - 130
			Methyl-tert-butylether (MTBE)	2026/06/26		86	%	60 - 130
			Styrene	2026/06/26		119	%	60 - 130
			Tetrachloroethene	2026/06/26		93	%	60 - 130
			Toluene	2026/06/26		98	%	60 - 130
			trans-1,2-dichloroethene	2026/06/26		102	%	60 - 130
			trans-1,3-dichloropropene	2026/06/26		85	%	50 - 140
			Trichloroethene	2026/06/26		95	%	60 - 130
			Trichlorofluoromethane	2026/06/26		97	%	60 - 130
			Vinyl chloride	2026/06/26		98	%	50 - 140
			m & p-Xylene	2026/06/26		116	%	60 - 130
			o-Xylene	2026/06/26		109	%	60 - 130
			1,4-Difluorobenzene (sur.)	2026/06/26		107	%	50 - 140
			4-Bromofluorobenzene (sur.)	2026/06/26		79	%	50 - 140
			D4-1,2-Dichloroethane (sur.)	2026/06/26		105	%	50 - 140
			VH C6-C10	2026/06/26	ND, RDL=300		ug/L	
			1,1,1,2-tetrachloroethane	2026/06/26	ND, RDL=0.50		ug/L	
			1,1,1-trichloroethane	2026/06/26	ND, RDL=0.50		ug/L	
			1,1,2,2-tetrachloroethane	2026/06/26	ND, RDL=0.50		ug/L	
			1,1,2Trichloro-1,2,2Trifluoroethane	2026/06/26	ND, RDL=2.0		ug/L	
			1,1,2-trichloroethane	2026/06/26	ND, RDL=0.50		ug/L	
			1,1-dichloroethane	2026/06/26	ND, RDL=0.50		ug/L	
			1,1-dichloroethene	2026/06/26	ND, RDL=0.50		ug/L	
			1,2,3-trichlorobenzene	2026/06/26	ND, RDL=2.0		ug/L	
			1,2,4-trichlorobenzene	2026/06/26	ND, RDL=2.0		ug/L	
			1,2-dibromoethane	2026/06/26	ND, RDL=0.20		ug/L	
			1,2-dichlorobenzene	2026/06/26	ND, RDL=0.50		ug/L	



Bureau Veritas Job #: C637882
Report Date: 2026/07/15

HATFIELD CONSULTANTS
Client Project #: FORTIS11234/PE110163
Site Location: WOODFIBRE PIPELINE PROJECT
Your P.O. #: 4800010213

QUALITY ASSURANCE REPORT(CONT'D)

QA/QC Batch	Init	QC Type	Parameter	Date Analyzed	Value	Recovery	UNITS	QC Limits
			1,2-dichloroethane	2026/06/26	ND, RDL=0.50		ug/L	
			1,2-dichloropropane	2026/06/26	ND, RDL=0.50		ug/L	
			1,3,5-trimethylbenzene	2026/06/26	ND, RDL=2.0		ug/L	
			1,3-Butadiene	2026/06/26	ND, RDL=0.50		ug/L	
			1,3-dichlorobenzene	2026/06/26	ND, RDL=0.50		ug/L	
			1,3-dichloropropane	2026/06/26	ND, RDL=1.0		ug/L	
			1,4-dichlorobenzene	2026/06/26	ND, RDL=0.50		ug/L	
			Benzene	2026/06/26	ND, RDL=0.40		ug/L	
			Bromobenzene	2026/06/26	ND, RDL=2.0		ug/L	
			Bromodichloromethane	2026/06/26	ND, RDL=1.0		ug/L	
			Bromoform	2026/06/26	ND, RDL=1.0		ug/L	
			Bromomethane	2026/06/26	ND, RDL=1.0		ug/L	
			Carbon tetrachloride	2026/06/26	ND, RDL=0.50		ug/L	
			Chlorobenzene	2026/06/26	ND, RDL=0.50		ug/L	
			Dibromochloromethane	2026/06/26	ND, RDL=1.0		ug/L	
			Chloroethane	2026/06/26	ND, RDL=1.0		ug/L	
			Chloroform	2026/06/26	ND, RDL=1.0		ug/L	
			Chloromethane	2026/06/26	ND, RDL=1.0		ug/L	
			cis-1,2-dichloroethene	2026/06/26	ND, RDL=1.0		ug/L	
			cis-1,3-dichloropropene	2026/06/26	ND, RDL=1.0		ug/L	
			Dichlorodifluoromethane	2026/06/26	ND, RDL=2.0		ug/L	
			Dichloromethane	2026/06/26	ND, RDL=2.0		ug/L	
			Ethylbenzene	2026/06/26	ND, RDL=0.40		ug/L	
			Hexachlorobutadiene	2026/06/26	ND, RDL=0.50		ug/L	
			Isopropylbenzene	2026/06/26	ND, RDL=2.0		ug/L	
			Methyl-tert-butylether (MTBE)	2026/06/26	ND, RDL=4.0		ug/L	
			Styrene	2026/06/26	ND, RDL=0.50		ug/L	



Bureau Veritas Job #: C637882
Report Date: 2026/07/15

HATFIELD CONSULTANTS
Client Project #: FORTIS11234/PE110163
Site Location: WOODFIBRE PIPELINE PROJECT
Your P.O. #: 4800010213

QUALITY ASSURANCE REPORT(CONT'D)

QA/QC Batch	Init	QC Type	Parameter	Date Analyzed	Value	Recovery	UNITS	QC Limits
C327177	KPA	RPD	Tetrachloroethene	2026/06/26	ND, RDL=0.50		ug/L	
			Toluene	2026/06/26	ND, RDL=0.40		ug/L	
			trans-1,2-dichloroethene	2026/06/26	ND, RDL=1.0		ug/L	
			trans-1,3-dichloropropene	2026/06/26	ND, RDL=1.0		ug/L	
			Trichloroethene	2026/06/26	ND, RDL=0.50		ug/L	
			Trichlorofluoromethane	2026/06/26	ND, RDL=4.0		ug/L	
			Vinyl chloride	2026/06/26	ND, RDL=0.50		ug/L	
			m & p-Xylene	2026/06/26	ND, RDL=0.40		ug/L	
			o-Xylene	2026/06/26	ND, RDL=0.40		ug/L	
			Xylenes (Total)	2026/06/26	ND, RDL=0.40		ug/L	
			1,1-dichloroethene	2026/06/26	NC		%	30
			1,2-dichlorobenzene	2026/06/26	NC		%	30
			1,2-dichloroethane	2026/06/26	NC		%	30
			1,4-dichlorobenzene	2026/06/26	NC		%	30
			Benzene	2026/06/26	NC		%	30
			Carbon tetrachloride	2026/06/26	NC		%	30
			Chlorobenzene	2026/06/26	NC		%	30
			Dichloromethane	2026/06/26	0.98		%	30
			Ethylbenzene	2026/06/26	NC		%	30
			Methyl-tert-butylether (MTBE)	2026/06/26	NC		%	30
C327286	CJY	Spiked Blank	Dissolved Organic Carbon (C)	2026/06/25		108	%	80 - 120
		Method Blank	Dissolved Organic Carbon (C)	2026/06/25	ND, RDL=0.50		mg/L	
C327499	SPP	Matrix Spike	Total Suspended Solids	2026/06/26		105	%	80 - 120
C327499	SPP	Spiked Blank	Total Suspended Solids	2026/06/26		102	%	80 - 120
C327499	SPP	Method Blank	Total Suspended Solids	2026/06/26	ND, RDL=1.0		mg/L	
C327499	SPP	RPD	Total Suspended Solids	2026/06/26	NC		%	20
C327526	BTM	Spiked Blank	Alkalinity (Total as CaCO3)	2026/06/26		94	%	80 - 120
C327526	BTM	Method Blank	Alkalinity (PP as CaCO3)	2026/06/26	ND, RDL=1.0		mg/L	
			Alkalinity (Total as CaCO3)	2026/06/26	ND, RDL=1.0		mg/L	
			Bicarbonate (HCO3)	2026/06/26	ND, RDL=1.0		mg/L	
			Carbonate (CO3)	2026/06/26	ND, RDL=1.0		mg/L	



Bureau Veritas Job #: C637882
Report Date: 2026/07/15

HATFIELD CONSULTANTS
Client Project #: FORTIS11234/PE110163
Site Location: WOODFIBRE PIPELINE PROJECT
Your P.O. #: 4800010213

QUALITY ASSURANCE REPORT(CONT'D)

QA/QC Batch	Init	QC Type	Parameter	Date Analyzed	Value	Recovery	UNITS	QC Limits
C327526	BTM	RPD	Hydroxide (OH)	2026/06/26	ND, RDL=1.0		mg/L	
			Alkalinity (PP as CaCO ₃)	2026/06/26	NC		%	20
			Alkalinity (Total as CaCO ₃)	2026/06/26	3.5		%	20
			Bicarbonate (HCO ₃)	2026/06/26	3.5		%	20
			Carbonate (CO ₃)	2026/06/26	NC		%	20
C327529	BTM	Spiked Blank	Hydroxide (OH)	2026/06/26	NC		%	20
			pH	2026/06/26		100	%	97 - 103
			pH	2026/06/26	0.79		%	N/A
			Nitrate plus Nitrite (N)	2026/06/25		123 (1)	%	80 - 120
			Nitrate plus Nitrite (N)	2026/06/25		109	%	80 - 120
C327625	RLZ	Method Blank	Nitrate plus Nitrite (N)	2026/06/25	ND, RDL=0.020		mg/L	
			Nitrate plus Nitrite (N)	2026/06/25	NC		%	20
			Nitrite (N)	2026/06/25		125 (1)	%	80 - 120
			Nitrite (N)	2026/06/25		104	%	80 - 120
			Nitrite (N)	2026/06/25	ND, RDL=0.0050		mg/L	
C327628	RLZ	Method Blank	Nitrite (N)	2026/06/25	NC		%	20
			Dissolved Mercury (Hg)	2026/06/25		88	%	80 - 120
			Dissolved Mercury (Hg)	2026/06/25		95	%	80 - 120
			Dissolved Mercury (Hg)	2026/06/25	ND, RDL=0.0019		ug/L	
			Dissolved Mercury (Hg)	2026/06/25	NC		%	20
C327946	SPP	Method Blank	Total Dissolved Solids	2026/06/26		97	%	80 - 120
			Total Dissolved Solids	2026/06/26		106	%	80 - 120
			Total Dissolved Solids	2026/06/26	ND, RDL=10		mg/L	
			Total Dissolved Solids	2026/06/26	3.8		%	20
			Total Mercury (Hg)	2026/06/26		109	%	80 - 120
C327986	RLC	Method Blank	Total Mercury (Hg)	2026/06/26		105	%	80 - 120
			Total Mercury (Hg)	2026/06/26	ND, RDL=0.0019		ug/L	
			Total Mercury (Hg)	2026/06/26	0.63		%	20
			Chloride (Cl)	2026/06/26		101	%	80 - 120
			Sulphate (SO ₄)	2026/06/26		NC	%	80 - 120
C328274	JAV	Method Blank	Chloride (Cl)	2026/06/26		99	%	80 - 120
			Sulphate (SO ₄)	2026/06/26		90	%	80 - 120
			Chloride (Cl)	2026/06/26	ND, RDL=1.0		mg/L	
			Sulphate (SO ₄)	2026/06/26	ND, RDL=1.0		mg/L	
			Chloride (Cl)	2026/06/26	NC		%	20
C328370	JGL	Method Blank	Sulphate (SO ₄)	2026/06/26	1.8		%	20
			Nitrate plus Nitrite (N)	2026/06/26		111	%	80 - 120
			Nitrate plus Nitrite (N)	2026/06/26		108	%	80 - 120
			Nitrate plus Nitrite (N)	2026/06/26	ND, RDL=0.020		mg/L	
			Nitrate plus Nitrite (N)	2026/06/26	3.3		%	20
C328372	JGL	Method Blank	Nitrite (N)	2026/06/26		114	%	80 - 120
			Nitrite (N)	2026/06/26		103	%	80 - 120
			Nitrite (N)	2026/06/26	ND, RDL=0.0050		mg/L	
			Nitrite (N)	2026/06/26				
			Nitrite (N)	2026/06/26				



Bureau Veritas Job #: C637882
Report Date: 2026/07/15

HATFIELD CONSULTANTS
Client Project #: FORTIS11234/PE110163
Site Location: WOODFIBRE PIPELINE PROJECT
Your P.O. #: 4800010213

QUALITY ASSURANCE REPORT(CONT'D)

QA/QC Batch	Init	QC Type	Parameter	Date Analyzed	Value	Recovery	UNITS	QC Limits
C328372	JGL	RPD	Nitrite (N)	2026/06/26	1.7		%	20
C328374	JGL	Matrix Spike	Nitrate plus Nitrite (N)	2026/06/26		NC	%	80 - 120
C328374	JGL	Spiked Blank	Nitrate plus Nitrite (N)	2026/06/26		105	%	80 - 120
C328374	JGL	Method Blank	Nitrate plus Nitrite (N)	2026/06/26	ND, RDL=0.020		mg/L	
C328374	JGL	RPD	Nitrate plus Nitrite (N)	2026/06/26	0.37		%	20
C328376	JGL	Matrix Spike	Nitrite (N)	2026/06/26		106	%	80 - 120
C328376	JGL	Spiked Blank	Nitrite (N)	2026/06/26		104	%	80 - 120
C328376	JGL	Method Blank	Nitrite (N)	2026/06/26	ND, RDL=0.0050		mg/L	
C328376	JGL	RPD	Nitrite (N)	2026/06/26	NC		%	20
C328528	AA1	Matrix Spike	Dissolved Aluminum (Al)	2026/06/26		97	%	80 - 120
			Dissolved Antimony (Sb)	2026/06/26		101	%	80 - 120
			Dissolved Arsenic (As)	2026/06/26		107	%	80 - 120
			Dissolved Barium (Ba)	2026/06/26		95	%	80 - 120
			Dissolved Beryllium (Be)	2026/06/26		90	%	80 - 120
			Dissolved Bismuth (Bi)	2026/06/26		107	%	80 - 120
			Dissolved Boron (B)	2026/06/26		93	%	80 - 120
			Dissolved Cadmium (Cd)	2026/06/26		100	%	80 - 120
			Dissolved Cesium (Cs)	2026/06/26		102	%	80 - 120
			Dissolved Chromium (Cr)	2026/06/26		97	%	80 - 120
			Dissolved Cobalt (Co)	2026/06/26		88	%	80 - 120
			Dissolved Copper (Cu)	2026/06/26		91	%	80 - 120
			Dissolved Iron (Fe)	2026/06/26		102	%	80 - 120
			Dissolved Lead (Pb)	2026/06/26		99	%	80 - 120
			Dissolved Lithium (Li)	2026/06/26		98	%	80 - 120
			Dissolved Manganese (Mn)	2026/06/26		95	%	80 - 120
			Dissolved Molybdenum (Mo)	2026/06/26		NC	%	80 - 120
			Dissolved Nickel (Ni)	2026/06/26		92	%	80 - 120
			Dissolved Phosphorus (P)	2026/06/26		103	%	80 - 120
			Dissolved Rubidium (Rb)	2026/06/26		101	%	80 - 120
			Dissolved Selenium (Se)	2026/06/26		103	%	80 - 120
			Dissolved Silicon (Si)	2026/06/26		NC	%	80 - 120
			Dissolved Silver (Ag)	2026/06/26		99	%	80 - 120
			Dissolved Strontium (Sr)	2026/06/26		NC	%	80 - 120
			Dissolved Tellurium (Te)	2026/06/26		105	%	80 - 120
			Dissolved Thallium (Tl)	2026/06/26		107	%	80 - 120
			Dissolved Thorium (Th)	2026/06/26		108	%	80 - 120
			Dissolved Tin (Sn)	2026/06/26		102	%	80 - 120
			Dissolved Titanium (Ti)	2026/06/26		101	%	80 - 120
			Dissolved Uranium (U)	2026/06/26		91	%	80 - 120
			Dissolved Vanadium (V)	2026/06/26		100	%	80 - 120
			Dissolved Zinc (Zn)	2026/06/26		92	%	80 - 120
			Dissolved Zirconium (Zr)	2026/06/26		108	%	80 - 120
C328528	AA1	Spiked Blank	Dissolved Aluminum (Al)	2026/06/26		101	%	80 - 120
			Dissolved Antimony (Sb)	2026/06/26		99	%	80 - 120
			Dissolved Arsenic (As)	2026/06/26		103	%	80 - 120
			Dissolved Barium (Ba)	2026/06/26		100	%	80 - 120
			Dissolved Beryllium (Be)	2026/06/26		93	%	80 - 120
			Dissolved Bismuth (Bi)	2026/06/26		112	%	80 - 120
			Dissolved Boron (B)	2026/06/26		95	%	80 - 120
			Dissolved Cadmium (Cd)	2026/06/26		102	%	80 - 120
			Dissolved Cesium (Cs)	2026/06/26		106	%	80 - 120



Bureau Veritas Job #: C637882
Report Date: 2026/07/15

HATFIELD CONSULTANTS
Client Project #: FORTIS11234/PE110163
Site Location: WOODFIBRE PIPELINE PROJECT
Your P.O. #: 4800010213

QUALITY ASSURANCE REPORT(CONT'D)

QA/QC Batch	Init	QC Type	Parameter	Date Analyzed	Value	Recovery	UNITS	QC Limits
C328528	AA1	Method Blank	Dissolved Chromium (Cr)	2026/06/26		101	%	80 - 120
			Dissolved Cobalt (Co)	2026/06/26		95	%	80 - 120
			Dissolved Copper (Cu)	2026/06/26		99	%	80 - 120
			Dissolved Iron (Fe)	2026/06/26		103	%	80 - 120
			Dissolved Lead (Pb)	2026/06/26		103	%	80 - 120
			Dissolved Lithium (Li)	2026/06/26		99	%	80 - 120
			Dissolved Manganese (Mn)	2026/06/26		100	%	80 - 120
			Dissolved Molybdenum (Mo)	2026/06/26		103	%	80 - 120
			Dissolved Nickel (Ni)	2026/06/26		101	%	80 - 120
			Dissolved Phosphorus (P)	2026/06/26		99	%	80 - 120
			Dissolved Rubidium (Rb)	2026/06/26		100	%	80 - 120
			Dissolved Selenium (Se)	2026/06/26		100	%	80 - 120
			Dissolved Silicon (Si)	2026/06/26		102	%	80 - 120
			Dissolved Silver (Ag)	2026/06/26		100	%	80 - 120
			Dissolved Strontium (Sr)	2026/06/26		100	%	80 - 120
			Dissolved Tellurium (Te)	2026/06/26		102	%	80 - 120
			Dissolved Thallium (Tl)	2026/06/26		110	%	80 - 120
			Dissolved Thorium (Th)	2026/06/26		105	%	80 - 120
			Dissolved Tin (Sn)	2026/06/26		104	%	80 - 120
			Dissolved Titanium (Ti)	2026/06/26		101	%	80 - 120
			Dissolved Uranium (U)	2026/06/26		91	%	80 - 120
			Dissolved Vanadium (V)	2026/06/26		101	%	80 - 120
			Dissolved Zinc (Zn)	2026/06/26		100	%	80 - 120
			Dissolved Zirconium (Zr)	2026/06/26		103	%	80 - 120
			Dissolved Aluminum (Al)	2026/06/26	ND, RDL=0.50		ug/L	
			Dissolved Antimony (Sb)	2026/06/26	ND, RDL=0.020		ug/L	
			Dissolved Arsenic (As)	2026/06/26	ND, RDL=0.020		ug/L	
			Dissolved Barium (Ba)	2026/06/26	ND, RDL=0.020		ug/L	
			Dissolved Beryllium (Be)	2026/06/26	ND, RDL=0.010		ug/L	
			Dissolved Bismuth (Bi)	2026/06/26	ND, RDL=0.0050		ug/L	
			Dissolved Boron (B)	2026/06/26	ND, RDL=10		ug/L	
			Dissolved Cadmium (Cd)	2026/06/26	ND, RDL=0.0050		ug/L	
			Dissolved Cesium (Cs)	2026/06/26	ND, RDL=0.050		ug/L	
			Dissolved Chromium (Cr)	2026/06/26	ND, RDL=0.10		ug/L	
			Dissolved Cobalt (Co)	2026/06/26	ND, RDL=0.0050		ug/L	
			Dissolved Copper (Cu)	2026/06/26	ND, RDL=0.050		ug/L	
			Dissolved Iron (Fe)	2026/06/26	ND, RDL=1.0		ug/L	
			Dissolved Lead (Pb)	2026/06/26	ND, RDL=0.0050		ug/L	
			Dissolved Lithium (Li)	2026/06/26	ND, RDL=0.50		ug/L	



Bureau Veritas Job #: C637882
Report Date: 2026/07/15

HATFIELD CONSULTANTS
Client Project #: FORTIS11234/PE110163
Site Location: WOODFIBRE PIPELINE PROJECT
Your P.O. #: 4800010213

QUALITY ASSURANCE REPORT(CONT'D)

QA/QC Batch	Init	QC Type	Parameter	Date Analyzed	Value	Recovery	UNITS	QC Limits
C328528	AA1	RPD	Dissolved Manganese (Mn)	2026/06/26	0.087, RDL=0.050 (2)		ug/L	
			Dissolved Molybdenum (Mo)	2026/06/26	ND, RDL=0.050		ug/L	
			Dissolved Nickel (Ni)	2026/06/26	ND, RDL=0.020		ug/L	
			Dissolved Phosphorus (P)	2026/06/26	ND, RDL=2.0		ug/L	
			Dissolved Rubidium (Rb)	2026/06/26	ND, RDL=0.050		ug/L	
			Dissolved Selenium (Se)	2026/06/26	ND, RDL=0.040		ug/L	
			Dissolved Silicon (Si)	2026/06/26	ND, RDL=50		ug/L	
			Dissolved Silver (Ag)	2026/06/26	ND, RDL=0.0050		ug/L	
			Dissolved Strontium (Sr)	2026/06/26	ND, RDL=0.050		ug/L	
			Dissolved Tellurium (Te)	2026/06/26	ND, RDL=0.020		ug/L	
			Dissolved Thallium (Tl)	2026/06/26	ND, RDL=0.0020		ug/L	
			Dissolved Thorium (Th)	2026/06/26	ND, RDL=0.0050		ug/L	
			Dissolved Tin (Sn)	2026/06/26	ND, RDL=0.20		ug/L	
			Dissolved Titanium (Ti)	2026/06/26	ND, RDL=0.50		ug/L	
			Dissolved Uranium (U)	2026/06/26	ND, RDL=0.0020		ug/L	
			Dissolved Vanadium (V)	2026/06/26	ND, RDL=0.20		ug/L	
			Dissolved Zinc (Zn)	2026/06/26	ND, RDL=0.10		ug/L	
			Dissolved Zirconium (Zr)	2026/06/26	ND, RDL=0.10		ug/L	
			Dissolved Aluminum (Al)	2026/06/26	NC		%	20
			Dissolved Antimony (Sb)	2026/06/26	0.46		%	20
			Dissolved Arsenic (As)	2026/06/26	1.7		%	20
			Dissolved Barium (Ba)	2026/06/26	0.27		%	20
			Dissolved Beryllium (Be)	2026/06/26	NC		%	20
			Dissolved Bismuth (Bi)	2026/06/26	NC		%	20
			Dissolved Boron (B)	2026/06/26	NC		%	20
			Dissolved Cadmium (Cd)	2026/06/26	NC		%	20
			Dissolved Chromium (Cr)	2026/06/26	12		%	20
			Dissolved Cobalt (Co)	2026/06/26	17		%	20
			Dissolved Copper (Cu)	2026/06/26	1.4		%	20
			Dissolved Iron (Fe)	2026/06/26	NC		%	20
			Dissolved Lead (Pb)	2026/06/26	NC		%	20
			Dissolved Lithium (Li)	2026/06/26	0.59		%	20
			Dissolved Manganese (Mn)	2026/06/26	0.084		%	20
			Dissolved Molybdenum (Mo)	2026/06/26	2.2		%	20
			Dissolved Nickel (Ni)	2026/06/26	7.9		%	20
			Dissolved Phosphorus (P)	2026/06/26	NC		%	20



Bureau Veritas Job #: C637882
Report Date: 2026/07/15

HATFIELD CONSULTANTS
Client Project #: FORTIS11234/PE110163
Site Location: WOODFIBRE PIPELINE PROJECT
Your P.O. #: 4800010213

QUALITY ASSURANCE REPORT(CONT'D)

QA/QC Batch	Init	QC Type	Parameter	Date Analyzed	Value	Recovery	UNITS	QC Limits
			Dissolved Selenium (Se)	2026/06/26	2.6		%	20
			Dissolved Silicon (Si)	2026/06/26	0.86		%	20
			Dissolved Silver (Ag)	2026/06/26	NC		%	20
			Dissolved Strontium (Sr)	2026/06/26	0.050		%	20
			Dissolved Thallium (Tl)	2026/06/26	4.9		%	20
			Dissolved Tin (Sn)	2026/06/26	NC		%	20
			Dissolved Titanium (Ti)	2026/06/26	NC		%	20
			Dissolved Uranium (U)	2026/06/26	0.78		%	20
			Dissolved Vanadium (V)	2026/06/26	NC		%	20
			Dissolved Zinc (Zn)	2026/06/26	2.0		%	20
			Dissolved Zirconium (Zr)	2026/06/26	NC		%	20
C328703	TSO	Matrix Spike	Total Nitrogen (N)	2026/06/29		103	%	80 - 120
C328703	TSO	Spiked Blank	Total Nitrogen (N)	2026/06/29		105	%	80 - 120
C328703	TSO	Method Blank	Total Nitrogen (N)	2026/06/29	ND, RDL=0.020		mg/L	
C328703	TSO	RPD	Total Nitrogen (N)	2026/06/29	NC		%	20
C328741	BTM	Matrix Spike	Dissolved Fluoride (F)	2026/06/26		91	%	80 - 120
C328741	BTM	Spiked Blank	Dissolved Fluoride (F)	2026/06/26		100	%	80 - 120
C328741	BTM	Method Blank	Dissolved Fluoride (F)	2026/06/26	ND, RDL=0.050		mg/L	
C328741	BTM	RPD	Fluoride (F)	2026/06/26	NC		%	20
C329213	AA1	Matrix Spike	Total Aluminum (Al)	2026/06/29		103	%	80 - 120
			Total Antimony (Sb)	2026/06/29		99	%	80 - 120
			Total Arsenic (As)	2026/06/29		104	%	80 - 120
			Total Barium (Ba)	2026/06/29		97	%	80 - 120
			Total Beryllium (Be)	2026/06/29		100	%	80 - 120
			Total Bismuth (Bi)	2026/06/29		95	%	80 - 120
			Total Boron (B)	2026/06/29		99	%	80 - 120
			Total Cadmium (Cd)	2026/06/29		100	%	80 - 120
			Total Cesium (Cs)	2026/06/29		99	%	80 - 120
			Total Chromium (Cr)	2026/06/29		97	%	80 - 120
			Total Cobalt (Co)	2026/06/29		96	%	80 - 120
			Total Copper (Cu)	2026/06/29		94	%	80 - 120
			Total Iron (Fe)	2026/06/29		NC	%	80 - 120
			Total Lead (Pb)	2026/06/29		94	%	80 - 120
			Total Lithium (Li)	2026/06/29		94	%	80 - 120
			Total Manganese (Mn)	2026/06/29		NC	%	80 - 120
			Total Molybdenum (Mo)	2026/06/29		105	%	80 - 120
			Total Nickel (Ni)	2026/06/29		95	%	80 - 120
			Total Phosphorus (P)	2026/06/29		104	%	80 - 120
			Total Rubidium (Rb)	2026/06/29		103	%	80 - 120
			Total Selenium (Se)	2026/06/29		99	%	80 - 120
			Total Silicon (Si)	2026/06/29		102	%	80 - 120
			Total Silver (Ag)	2026/06/29		99	%	80 - 120
			Total Strontium (Sr)	2026/06/29		NC	%	80 - 120
			Total Tellurium (Te)	2026/06/29		104	%	80 - 120
			Total Thallium (Tl)	2026/06/29		99	%	80 - 120
			Total Thorium (Th)	2026/06/29		99	%	80 - 120
			Total Tin (Sn)	2026/06/29		97	%	80 - 120
			Total Titanium (Ti)	2026/06/29		99	%	80 - 120
			Total Uranium (U)	2026/06/29		97	%	80 - 120
			Total Vanadium (V)	2026/06/29		98	%	80 - 120
			Total Zinc (Zn)	2026/06/29		96	%	80 - 120



Bureau Veritas Job #: C637882
Report Date: 2026/07/15

HATFIELD CONSULTANTS
Client Project #: FORTIS11234/PE110163
Site Location: WOODFIBRE PIPELINE PROJECT
Your P.O. #: 4800010213

QUALITY ASSURANCE REPORT(CONT'D)

QA/QC Batch	Init	QC Type	Parameter	Date Analyzed	Value	Recovery	UNITS	QC Limits
C329213	AA1	Spiked Blank	Total Zirconium (Zr)	2026/06/29		103	%	80 - 120
			Total Aluminum (Al)	2026/06/29		104	%	80 - 120
			Total Antimony (Sb)	2026/06/29		100	%	80 - 120
			Total Arsenic (As)	2026/06/29		101	%	80 - 120
			Total Barium (Ba)	2026/06/29		98	%	80 - 120
			Total Beryllium (Be)	2026/06/29		102	%	80 - 120
			Total Bismuth (Bi)	2026/06/29		98	%	80 - 120
			Total Boron (B)	2026/06/29		101	%	80 - 120
			Total Cadmium (Cd)	2026/06/29		99	%	80 - 120
			Total Cesium (Cs)	2026/06/29		100	%	80 - 120
			Total Chromium (Cr)	2026/06/29		99	%	80 - 120
			Total Cobalt (Co)	2026/06/29		99	%	80 - 120
			Total Copper (Cu)	2026/06/29		97	%	80 - 120
			Total Iron (Fe)	2026/06/29		100	%	80 - 120
			Total Lead (Pb)	2026/06/29		95	%	80 - 120
			Total Lithium (Li)	2026/06/29		95	%	80 - 120
			Total Manganese (Mn)	2026/06/29		99	%	80 - 120
			Total Molybdenum (Mo)	2026/06/29		104	%	80 - 120
			Total Nickel (Ni)	2026/06/29		98	%	80 - 120
			Total Phosphorus (P)	2026/06/29		102	%	80 - 120
			Total Rubidium (Rb)	2026/06/29		99	%	80 - 120
			Total Selenium (Se)	2026/06/29		97	%	80 - 120
			Total Silicon (Si)	2026/06/29		105	%	80 - 120
			Total Silver (Ag)	2026/06/29		99	%	80 - 120
			Total Strontium (Sr)	2026/06/29		101	%	80 - 120
			Total Tellurium (Te)	2026/06/29		104	%	80 - 120
			Total Thallium (Tl)	2026/06/29		100	%	80 - 120
			Total Thorium (Th)	2026/06/29		99	%	80 - 120
			Total Tin (Sn)	2026/06/29		100	%	80 - 120
			Total Titanium (Ti)	2026/06/29		102	%	80 - 120
			Total Uranium (U)	2026/06/29		98	%	80 - 120
			Total Vanadium (V)	2026/06/29		99	%	80 - 120
			Total Zinc (Zn)	2026/06/29		98	%	80 - 120
			Total Zirconium (Zr)	2026/06/29		101	%	80 - 120
C329213	AA1	Method Blank	Total Aluminum (Al)	2026/06/29	ND, RDL=0.50		ug/L	
			Total Antimony (Sb)	2026/06/29	ND, RDL=0.020		ug/L	
			Total Arsenic (As)	2026/06/29	ND, RDL=0.020		ug/L	
			Total Barium (Ba)	2026/06/29	ND, RDL=0.020		ug/L	
			Total Beryllium (Be)	2026/06/29	ND, RDL=0.010		ug/L	
			Total Bismuth (Bi)	2026/06/29	ND, RDL=0.0050		ug/L	
			Total Boron (B)	2026/06/29	ND, RDL=10		ug/L	
			Total Cadmium (Cd)	2026/06/29	ND, RDL=0.0050		ug/L	
			Total Cesium (Cs)	2026/06/29	ND, RDL=0.050		ug/L	



Bureau Veritas Job #: C637882
Report Date: 2026/07/15

HATFIELD CONSULTANTS
Client Project #: FORTIS11234/PE110163
Site Location: WOODFIBRE PIPELINE PROJECT
Your P.O. #: 4800010213

QUALITY ASSURANCE REPORT(CONT'D)

QA/QC Batch	Init	QC Type	Parameter	Date Analyzed	Value	Recovery	UNITS	QC Limits
C329213	AA1	RPD	Total Chromium (Cr)	2026/06/29	ND, RDL=0.10		ug/L	
			Total Cobalt (Co)	2026/06/29	ND, RDL=0.0050		ug/L	
			Total Copper (Cu)	2026/06/29	ND, RDL=0.050		ug/L	
			Total Iron (Fe)	2026/06/29	ND, RDL=1.0		ug/L	
			Total Lead (Pb)	2026/06/29	ND, RDL=0.0050		ug/L	
			Total Lithium (Li)	2026/06/29	ND, RDL=0.50		ug/L	
			Total Manganese (Mn)	2026/06/29	ND, RDL=0.050		ug/L	
			Total Molybdenum (Mo)	2026/06/29	ND, RDL=0.050		ug/L	
			Total Nickel (Ni)	2026/06/29	ND, RDL=0.020		ug/L	
			Total Phosphorus (P)	2026/06/29	ND, RDL=2.0		ug/L	
			Total Rubidium (Rb)	2026/06/29	ND, RDL=0.050		ug/L	
			Total Selenium (Se)	2026/06/29	ND, RDL=0.040		ug/L	
			Total Silicon (Si)	2026/06/29	ND, RDL=50		ug/L	
			Total Silver (Ag)	2026/06/29	ND, RDL=0.0050		ug/L	
			Total Strontium (Sr)	2026/06/29	ND, RDL=0.050		ug/L	
			Total Tellurium (Te)	2026/06/29	ND, RDL=0.020		ug/L	
			Total Thallium (Tl)	2026/06/29	ND, RDL=0.0020		ug/L	
			Total Thorium (Th)	2026/06/29	ND, RDL=0.050		ug/L	
			Total Tin (Sn)	2026/06/29	ND, RDL=0.20		ug/L	
			Total Titanium (Ti)	2026/06/29	ND, RDL=0.50		ug/L	
			Total Uranium (U)	2026/06/29	ND, RDL=0.0020		ug/L	
			Total Vanadium (V)	2026/06/29	ND, RDL=0.20		ug/L	
			Total Zinc (Zn)	2026/06/29	ND, RDL=0.10		ug/L	
			Total Zirconium (Zr)	2026/06/29	ND, RDL=0.10		ug/L	
			Total Aluminum (Al)	2026/06/29	4.3		%	20
			Total Antimony (Sb)	2026/06/29	8.9		%	20
			Total Arsenic (As)	2026/06/29	4.3		%	20
			Total Barium (Ba)	2026/06/29	0.50		%	20
			Total Beryllium (Be)	2026/06/29	NC		%	20
			Total Bismuth (Bi)	2026/06/29	NC		%	20



Bureau Veritas Job #: C637882
Report Date: 2026/07/15

HATFIELD CONSULTANTS
Client Project #: FORTIS11234/PE110163
Site Location: WOODFIBRE PIPELINE PROJECT
Your P.O. #: 4800010213

QUALITY ASSURANCE REPORT(CONT'D)

QA/QC Batch	Init	QC Type	Parameter	Date Analyzed	Value	Recovery	UNITS	QC Limits
			Total Boron (B)	2026/06/29	NC		%	20
			Total Cadmium (Cd)	2026/06/29	NC		%	20
			Total Cesium (Cs)	2026/06/29	NC		%	20
			Total Chromium (Cr)	2026/06/29	NC		%	20
			Total Cobalt (Co)	2026/06/29	2.6		%	20
			Total Copper (Cu)	2026/06/29	1.9		%	20
			Total Iron (Fe)	2026/06/29	0.26		%	20
			Total Lead (Pb)	2026/06/29	1.7		%	20
			Total Lithium (Li)	2026/06/29	NC		%	20
			Total Manganese (Mn)	2026/06/29	0.72		%	20
			Total Molybdenum (Mo)	2026/06/29	3.6		%	20
			Total Nickel (Ni)	2026/06/29	5.3		%	20
			Total Phosphorus (P)	2026/06/29	11		%	20
			Total Rubidium (Rb)	2026/06/29	0.25		%	20
			Total Selenium (Se)	2026/06/29	NC		%	20
			Total Silicon (Si)	2026/06/29	0.39		%	20
			Total Silver (Ag)	2026/06/29	NC		%	20
			Total Strontium (Sr)	2026/06/29	0.57		%	20
			Total Tellurium (Te)	2026/06/29	NC		%	20
			Total Thallium (Tl)	2026/06/29	2.6		%	20
			Total Thorium (Th)	2026/06/29	NC		%	20
			Total Tin (Sn)	2026/06/29	NC		%	20
			Total Titanium (Ti)	2026/06/29	2.7		%	20
			Total Uranium (U)	2026/06/29	1.9		%	20
			Total Vanadium (V)	2026/06/29	NC		%	20
			Total Zinc (Zn)	2026/06/29	3.3		%	20
			Total Zirconium (Zr)	2026/06/29	NC		%	20
C329351	CBK	Matrix Spike	Total Organic Carbon (C)	2026/06/26		108	%	80 - 120
C329351	CBK	Spiked Blank	Total Organic Carbon (C)	2026/06/26		99	%	80 - 120
C329351	CBK	Method Blank	Total Organic Carbon (C)	2026/06/26	ND, RDL=0.50		mg/L	
C329351	CBK	RPD	Total Organic Carbon (C)	2026/06/26	9.2		%	20
C330916	KA5	Matrix Spike	Total Phosphorus (P)	2026/06/30		107	%	N/A
C330916	KA5	Spiked Blank	Total Phosphorus (P)	2026/06/30		113	%	80 - 120
C330916	KA5	Method Blank	Total Phosphorus (P)	2026/06/30	ND, RDL=0.0010		mg/L	
C330916	KA5	RPD	Total Phosphorus (P)	2026/06/30	0.16		%	20
C330917	MWU	Matrix Spike	Bromide (Br)	2026/06/30		95	%	78 - 120
C330917	MWU	Spiked Blank	Bromide (Br)	2026/06/30		95	%	80 - 120
C330917	MWU	Method Blank	Bromide (Br)	2026/06/30	ND, RDL=0.010		mg/L	
C330917	MWU	RPD	Bromide (Br)	2026/06/30	NC		%	20
C330956	NJD	Matrix Spike	Total Sulphide	2026/06/30		19 (1)	%	80 - 120
C330956	NJD	Spiked Blank	Total Sulphide	2026/06/30		106	%	80 - 120
C330956	NJD	Method Blank	Total Sulphide	2026/06/30	ND, RDL=0.0018		mg/L	
C330956	NJD	RPD	Total Sulphide	2026/06/30	NC		%	20
C331268	AAX	Matrix Spike	Methyl Sulfone (sur.)	2026/06/29		91	%	50 - 140
			Ethylene Glycol	2026/06/29		78	%	60 - 140
			Diethylene Glycol	2026/06/29		96	%	60 - 140
			Triethylene Glycol	2026/06/29		76	%	60 - 140
			Propylene Glycol	2026/06/29		84	%	60 - 140
C331268	AAX	Spiked Blank	Methyl Sulfone (sur.)	2026/06/29		97	%	50 - 140



QUALITY ASSURANCE REPORT(CONT'D)

QA/QC Batch	Init	QC Type	Parameter	Date Analyzed	Value	Recovery	UNITS	QC Limits
C331268	AAX	Method Blank	Ethylene Glycol	2026/06/29		79	%	70 - 130
			Diethylene Glycol	2026/06/29		93	%	70 - 130
			Triethylene Glycol	2026/06/29		75	%	70 - 130
			Propylene Glycol	2026/06/29		85	%	70 - 130
			Methyl Sulfone (sur.)	2026/06/29		97	%	50 - 140
			Ethylene Glycol	2026/06/29	ND, RDL=3.0		mg/L	
			Diethylene Glycol	2026/06/29	ND, RDL=5.0		mg/L	
			Triethylene Glycol	2026/06/29	ND, RDL=5.0		mg/L	
			Propylene Glycol	2026/06/29	ND, RDL=5.0		mg/L	
C331268	AAX	RPD	Ethylene Glycol	2026/06/29	NC		%	30
			Diethylene Glycol	2026/06/29	NC		%	30
			Triethylene Glycol	2026/06/29	NC		%	30
			Propylene Glycol	2026/06/29	NC		%	30
C332057	STB	Matrix Spike [EHJ680-13]	Phenols	2026/06/30		106	%	80 - 120
C332057	STB	Spiked Blank	Phenols	2026/06/30		103	%	80 - 120
C332057	STB	Method Blank	Phenols	2026/06/30	ND, RDL=0.0015		mg/L	
C332057	STB	RPD [EHJ680-13]	Phenols	2026/06/30	NC		%	20
C332140	JGL	Matrix Spike	Total Hex. Chromium (Cr 6+)	2026/06/30		87	%	80 - 120
C332140	JGL	Spiked Blank	Total Hex. Chromium (Cr 6+)	2026/06/30		113	%	80 - 120
C332140	JGL	Method Blank	Total Hex. Chromium (Cr 6+)	2026/06/30	ND, RDL=0.00099		mg/L	
C332140	JGL	RPD	Total Hex. Chromium (Cr 6+)	2026/06/30	NC		%	20
C343681	IC4	Matrix Spike	Total Mercury (Hg)	2026/07/14		101	%	80 - 120
C343681	IC4	Spiked Blank	Total Mercury (Hg)	2026/07/14		99	%	80 - 120
C343681	IC4	Method Blank	Total Mercury (Hg)	2026/07/14	ND, RDL=0.0019		ug/L	
C343681	IC4	RPD	Total Mercury (Hg)	2026/07/14	NC		%	20

N/A = Not Applicable

Duplicate: Paired analysis of a separate portion of the same sample. Used to evaluate the variance in the measurement.

Matrix Spike: A sample to which a known amount of the analyte of interest has been added. Used to evaluate sample matrix interference.

Spiked Blank: A blank matrix sample to which a known amount of the analyte, usually from a second source, has been added. Used to evaluate method accuracy.

Method Blank: A blank matrix containing all reagents used in the analytical procedure. Used to identify laboratory contamination.

Surrogate: A pure or isotopically labeled compound whose behavior mirrors the analytes of interest. Used to evaluate extraction efficiency.

NC (Matrix Spike): The recovery in the matrix spike was not calculated. The relative difference between the concentration in the parent sample and the spike amount was too small to permit a reliable recovery calculation (matrix spike concentration was less than the native sample concentration)

NC (Duplicate RPD): The duplicate RPD was not calculated. The concentration in the sample and/or duplicate was too low to permit a reliable RPD calculation (absolute difference <= 2x RDL).

(1) Recovery or RPD for this parameter is outside control limits. The overall quality control for this analysis meets acceptability criteria.

(2) Method blank exceeds acceptance limits- 2X RDL acceptable for low level metals determination.



Bureau Veritas Job #: C637882
Report Date: 2026/07/15

HATFIELD CONSULTANTS
Client Project #: FORTIS11234/PE110163
Site Location: WOODFIBRE PIPELINE PROJECT
Your P.O. #: 4800010213

VALIDATION SIGNATURE PAGE

The analytical data and all QC contained in this report were reviewed and validated by:

David Huang, M.Sc., P.Chem., QP, Scientific Services Manager

Levi Manchak, Senior Project Manager

Mauro Oselin, P.Chem., QP, Scientific Specialist

Pushpa Gurung, Laboratory Supervisor

Suwan (Sze Yeung) Fock, B.Sc., Scientific Specialist

Bureau Veritas has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per ISO/IEC 17025, signing the reports. For Service Group specific validation, please refer to the Validation Signatures page if included, otherwise available by request. For Department specific Analyst/Supervisor validation names, please refer to the Test Summary section if included, otherwise available by request. This report is authorized by Rob Gilbert, BBY General Manager responsible for British Columbia Environmental laboratory operations.



Custody Tracking Form

eCOC Number
W133803

Please use this form for custody tracking when submitting the work instructions via eCOC (electronic Chain of Custody). Please ensure your form has a barcode or a Bureau Veritas eCOC confirmation number in the top right hand side. This number links your electronic submission to your samples. This form should be placed in the cooler with your samples.

Relinquished By		Received By	
Hayley Masson	JPM	Basil Dochow	JF
Date	2026/06/23	Date	2026/06/23
Time (24 HR)	17:50	Time (24 HR)	17:51
Date		Date	
Time (24 HR)		Time (24 HR)	
Date		Date	
Time (24 HR)		Time (24 HR)	

Unless otherwise agreed to, submissions and use of services are governed by Bureau Veritas' standard terms and conditions which can be found at www.bvna.com.


Sample Information			
Sampled By (Print)	# of Coolers/Pkgs	Brush ☐	Immediate Test ☐
Hayley Masson	1 Zin	Micro ☐	Food Residue ☐
			Food Chemistry ☐

*** Laboratory Use Only ***			
Received At:	Lab Comments:	Custody Seal	
BBT		Present (Y/N)	Intact (Y/N)
Labeled By:		N	N
Verified By:		X	
		Cooling Media	
		Present (Y/N)	Temperature °C
			1 2 3
			20 20 20
		Drinking Water Metals Preservation Check Done (Circle) YES NO	



MVAN-2026-06-2006


EPH in Water when PAH required Chromatogram



Note: This information is provided for reference purposes only. Should detailed chemist interpretation or fingerprinting be required, please contact the laboratory.



eCOC: W133303



Project Information: C637882
Job Received: 2026/06/23 17:51
Expected TAT: Standard TAT
Expected Arrival: 2026/06/23 14:30
Submitted By: Jackson Macpherson
Submitted To: Burnaby ENV: 4606
Canada Way

Invoice Information

Attn: Accounts Payable
Fortis BC Energy Inc
16705 Fraser Hwy
Surrey , BC , V4N 0E8
Email to:
einvoices@fortisbc.com

Report Information

Attn: Brett Lucas
HATFIELD CONSULTANTS
200-850 Harbourside Dr
North Vancouver , BC , V7P 0A3
Email to:
blucas@hatfieldgroup.com
danielle.samels@fortisbc.com
smangwani@hatfieldgroup.com
jmacpherson@hatfieldgroup.com
swolf@hatfieldgroup.com

Project Information

Quote #: C50083
PO/AFE#: 4800010213
Project #: Fortis11234/PE-110163
Site Location: Woodfibre Pipeline Project

Analytical Summary

A: Standard TAT

Client Sample ID	Cint Ref	Sampling Date/Time	Matrix	#Cont	Woodfibre	Woodfibre Additional	Woodfibre Blank	Set Number
WLNG-DS	1	2026/06/23 08:30	WATER	14	A			1
WLNG -EOP	2	2026/06/23 08:30	WATER	18	A	A		2
WLNG-US	3	2026/06/23 08:30	WATER	14	A			1
Field Blank	4	2026/06/23 08:30	WATER	14			A	3
Trip Blank	5	2026/06/23 08:30	WATER	14			A	3

Deadlines are estimates only and are subject to change. Please refer to your Job Confirmation report for final due dates.

Submission Information

of Samples: 5

Sample Set Listing

Set 1 (2 samples)	Set 2 (1 sample)	Set 3 (2 samples)
WLNG-DS WLNG-US	WLNG -EOP	Field Blank Trip Blank